

c-10

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001


No F 6 / DFS / MS / School/2021/ 365

Dated: 10/5/2021

FIRE SAFETY CERTIFICATE

Certified that the **M.C. Primary School** located at **New Police Line, D- Block, Kingsway Camp, Delhi-110009** comprised of **Ground floor only** (hut type) owned/occupied by **M.C. Primary School** was granted FSC by this department vide letter no. **No.F6/DFS/MS/School/2018/WZ/745** dated **20.04.2018**. The premises was re-inspected by the officer concerned of this department on **16.04.2021** in presence of **Smt. Sunita Aggarwal (Inchage)** and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/premise is fit for occupancy class Group B Educational with effect from ...10/5/21.... for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on ...10/5/21..... at New Delhi by


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
Ph.-011-25156707

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Principal, M.C. Primary School, New Police Line, D- Block, Kingsway Camp, Delhi-09.

Conditions for the validity of Fire Safety Certificate:

- 1 All the means of escape/entry/exit shall be kept free from any obstruction.
- 2 All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
- 3 All the staff members must know the correct method of operation of firefighting system.
- 4 The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on http://delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms.
- 5 This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
- 6 "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

1. Name & address of the building : M.C. Primary School, New Police Line, D- Block, Kingsway camp, Delhi-09.
 2. Type of Occupancy : Educational
 3. Type of Case : Renewal (Ground floors only)
 4. Details of previous NOC : F6/DFS/MS/School/2018/1966 Dated: 20.04.2018
 5. Fire Safety directives letter No : Director of Education Circular dated 01.03.2011
 6. Date of inspection : 16.04.2021
 7. Name of the Inspecting Officers : ADO (RN)
 8. Name and designation of officers
 from the building side : Smt. Sunita Aggarwal (Incharge)
 9. Year of Construction : 2001
 10. Applicant's letter No. : Online E-mail ID dated: 13.04.2021

Covered Area: 600m2 No of class rooms -10 nos. No of students---278nos.

	Minimum Standards on fire prevention and fire safety U/R 33	Director of education	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06m	06m	MR
	• Gate width	4.5m	3.0m	MR(old case)
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace			
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1 m	1m	MR
	3	Compartmentation.		
• Fire check door		NA	NA	NA
• Sealing of electrical shafts		NA	NA	NA
• Fire Rating of shaft door		NA	NA	NA
• Water Curtain		NA	NA	NA
• Fire Dampers		NA	NA	NA
4	Smoke Management System.			
	• Basements	12 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	NA	NA
5	Fire Extinguishers			
	• Total numbers	02nos	03nos	MR
	• Types	ABC/Co2	ABC-03	MR
	• ISI marking	ISI Marked	Provided	MR


6	First-Aid Hose Reels.				
	• Total numbers on each floor	NA	NA	NA	
	• Length of hose reel hose	NA	NA	NA	
	• Nozzle diameter	NA	NA	NA	
7	Automatic fire detection and alarming system.				
	• Type of detectors	NA	NA	NA	
	• Location of Main Panel	NA	NA	NA	
	• Location of Repeater Panel	NA	NA	NA	
	• Alternate source of power	NA	NA	NA	
	• Hooters' Location	NA	NA	NA	
8	MOEFA				
9	Public Address System.				
10	Automatic Sprinkler System.				
	• Basement	NA	NA	NA	
	• Upper Floor	NA	NA	NA	
	• Sprinkler above false ceiling	NA	NA	NA	
11	Internal Hydrants				
	• Size of riser/down-comer	NA	NA	NA	
	• Number of hydrants per floor	NA	NA	NA	
	• Hose Box	NA	NA	NA	
12	Yard Hydrants.				
	• Total number of hydrants	NA	NA	NA	
	• Hose Box	NA	NA	NA	
13	Pumping Arrangements.				
	• Ground Level	➤ Discharge of main Pump	N/A	N/A	N/A
		➤ Head of Main pump	N/A	N/A	N/A
		➤ Number of main pumps	N/A	N/A	N/A
		➤ Jockey Pump out put	NA	NA	NA
		➤ Jockey pump head	NA	NA	NA
		➤ Standby Pump out put	NA	NA	NA
		➤ Standby Pump Head	N/A	N/A	N/A
		➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	• Terrace level	➤ Discharge of pump	N/A	N/A	N/A
		➤ Head of the pump	NA	NA	NA
		➤ Power Supply	NA	NA	NA
		➤ Auto Starting of pump	NA	NA	NA
		➤ Discharge of pump	NA	NA	NA
		➤ Head of the pump	NA	NA	NA
		➤ Power Supply	NA	NA	NA
➤ Auto Starting of pump		NA	NA	NA	
14	Captive Water Storage for fire fighting.				
	• Underground tank capacity	NA	NA	NA	
	➤ Draw-off connection	NA	NA	NA	
	➤ Fire service inlet	NA	NA	NA	
	➤ Access to tank	NA	NA	NA	


	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.


Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in Director of Education Circular , the FSC issued vide letter of even no.745 dated 20.04.2018 renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended


DO(NW) - ON leave
 by CFO(WZ)
 h F.T.



 19/04/2021
 Signature of the Inspecting Officer
 Name :- C.L. Meena
 Designation:- ADO/RN



As approved, F.T. letter is being
 for your signature pl.


 CFO (WZ)


 21/5/2021


 03/05/2021

ms/cell