

C-15

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**


No.F.6 DFS/MS/School/2021/SZ/ 333

Dated: 16 / 4 / 2021

FIRE SAFETY CERTIFICATE

Certified that **New Sangam Convent School** located at **G- 1312, Veer Bazar Road, Sangam Vihar, New Delhi 110080** comprised of **Ground plus one upper floor** was granted Fire Safety Certificate by this department vide letter No. F6/MS/DFS/School/2018/SZ/766 Dated 20/04/2018. The said premise was re-inspected by officer concerned of this department on 27/03/2021 in presence of Sh. Anil Rastogi (Manager) of the school and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular No F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 issued by Director of Education, Govt. of NCT of Delhi and that the building is fit for occupancy class "**Educational Building Group – B**" with effect from 16 / 4 / 2021 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 16 / 4 / 2021 at New Delhi by


(Sunil Chawdhary)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service

Copy to: -

1. The Principal, New Sangam Convent School located at G- 1312, Veer Bazar Road, Sangam Vihar, New Delhi 110080
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.


Conditions for the validity of Fire Safety Certificate


1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
2. All the staff members must know the correct method of operation of firefighting system.
3. This certificate cannot be treated as regularization of unauthorized construction, if any.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."


INSPECTION REPORT


1	Name & Address of the Building	New Sangam Convent School, G-1312, Veer Bazar Road, Sangam Vihar, New Delhi- 110080		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	Ground + one upper floor.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/MS/DFS/School/2018/SZ/766 Dated 20-04-2018		
6	Fire Safety Directives Letter No	DOE Circular 01/03/2011		
7	Date of Inspection	27/03/2021		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Sh. Anil Rastogi (Manager)		
10	Year of construction	2004 & 2010		
11	Applicant letter No.	Outdoor diary 11905 dated 15/03/2021		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC requirements	Provided at Site	Remarks MR/NMR
1.	Access to Building.			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<ul style="list-style-type: none"> Accessible -NA- -NA- 	<ul style="list-style-type: none"> 6 mtr -NA- -NA- 	<ul style="list-style-type: none"> MR -NA- -NA-
2.	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	<ul style="list-style-type: none"> ➤ Upper floors. ➤ Basement floor. 	<ul style="list-style-type: none"> 01 No -NA- 	<ul style="list-style-type: none"> 02 Nos -NA- 	<ul style="list-style-type: none"> MR -NA-
	b) Width of Staircase			
	<ul style="list-style-type: none"> ➤ Upper floors ➤ Basement floor 	<ul style="list-style-type: none"> 1.5 m / 0.75 m -NA- 	<ul style="list-style-type: none"> 1.50 m & 1.45 m -NA- 	<ul style="list-style-type: none"> MR -NA-
	c) Protection of exits			
	<ul style="list-style-type: none"> ➤ Fire check door ➤ Pressurization 	<ul style="list-style-type: none"> -NA- -NA- 	<ul style="list-style-type: none"> -NA- -NA- 	<ul style="list-style-type: none"> -NA- -NA-
	d) No. of continuous staircase to terrace	-NA-	-NA-	-NA-
	e) Width of corridor	-NA-	-NA-	-NA-
	f) Door size	-NA-	-NA-	-NA-
3.	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door. • Sealing of electrical shafts. • Fire rating of shaft door. • Water curtain • Fire dampers. 	<ul style="list-style-type: none"> -NA- -NA- -NA- -NA- -NA- 	<ul style="list-style-type: none"> -NA- -NA- -NA- -NA- -NA- 	<ul style="list-style-type: none"> -NA- -NA- -NA- -NA- -NA-
4.	Smoke Management system.			
	<ul style="list-style-type: none"> • Basement • Upper floors 	<ul style="list-style-type: none"> 30 ACPH 12 ACPH 	<ul style="list-style-type: none"> -NA- NA 	<ul style="list-style-type: none"> -NA- NA
5.	Fire Extinguishers.			
	<ul style="list-style-type: none"> • Total numbers • Types • ISI Marking 	<ul style="list-style-type: none"> Required ABC / CO2 ISI marked 	<ul style="list-style-type: none"> 04 Nos ABC & CO2 Provided 	<ul style="list-style-type: none"> MR MR MR
6.	First Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor. • Length of hose-reel hose. • Nozzle Diameter 	<ul style="list-style-type: none"> -NA- -NA- -NA- 	<ul style="list-style-type: none"> -NA- -NA- -NA- 	<ul style="list-style-type: none"> -NA- -NA- -NA-
7.	Automatic fire detection & alarming system.			
	<ul style="list-style-type: none"> • Type of detectors 	-NA-	-NA-	-NA-

	<ul style="list-style-type: none"> • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooter's location 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
8.	MOEFA	-NA-	-NA-	-NA-
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basement • Upper floors • Sprinkler above false ceiling 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
11.	Internal Hydrants.			
	<ul style="list-style-type: none"> • Size of Riser/Down-comer • Number of Hydrant per floor • Hose box. 	NA	-NA-	NA
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> • Total number of hydrants. • Hose box. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
13.	Pumping arrangements.			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main pump. ➤ Head of main pump. ➤ Number of main pumps. ➤ Jockey Pump output. ➤ Jockey Pump head. ➤ Standby Pump output. ➤ Standby Pump head. ➤ Auto Starting/Manual Stopping. ➤ Pump house access. • Terrace Level <ul style="list-style-type: none"> ➤ Discharge of pump. ➤ Head of pump. ➤ Power supply. ➤ Auto starting of pump. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
14.	Captive water storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity. <ul style="list-style-type: none"> ➤ Draw-off connection. ➤ Fire Service Inlet. ➤ Access to tank. • Overhead tank capacity. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of lift shaft. • Pressurization of lift lobby. • Communication in lift car. • Fireman's switch. • Lift signage. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
17.	Standby Power Supply	-NA-	-NA-	-NA-
18.	Refuge Area			
	<ul style="list-style-type: none"> • Total area • Location 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
19.	Fire Control Room.			
	<ul style="list-style-type: none"> • Detector system panel. 	-NA-	-NA-	-NA-

	• Flow switch panel.	-NA-	-NA-	-NA-
	• PA system panel.	-NA-	-NA-	-NA-
	• Battery backup.	-NA-	-NA-	-NA-
	• Building floor plan.	-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.			-NA-
<p>The fire protection systems provided in the premises were test checked at random and found functional at the time of inspection.</p> <p>Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F6/MS/DFS/School/2018/SZ/766 Dated 20-04-2018, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.</p> <p>Accordingly DFA is put up for approval and signature please.</p> <p style="text-align: right;">  Signature of the Inspecting Officer Name: Sh. Rajesh Kumar Design: ADO (BCP) </p>				


DO (SD) 


DFO (S2)  F.F.



ADO (BCP)

As approved, F.F. letter is put up for your signature @


12/5

DFO/S2 

M.S. all