

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001


No F.6/DFS/MS/School/2021/WZ/ 378

Dated: 17/5/21

FIRE SAFETY CERTIFICATE

Certified that the **Queen's Convent School** located at **Sector-25, Rohini, Delhi-110085** comprised of **Ground + 03 upper floors** owned/ occupied by **Queen's Convent School** was issued Fire Safety Certificated vide this office letter no. **F.6/DFS/MS/2017/School/1733** dated **01.12.2017**. The premise was re-inspected by the officer concerned of this department on **01.04.2021** in the presence of **Mr. Brij Dixit, Care taker** and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition and there is no additional construction. The premise have therefore deemed complied with the requirements under rule 33 of the Delhi Fire Service Rules, 2010 and the building premise is fit for occupancy under **Educational "Group B"** with effect from **17.5.21**..... for a period of **three years** in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010,

Issued on **17.5.21**..... at New Delhi


(Dhrampal Bhardwaj)
Dy. Chief Fire Officer
Tel:-01123414250

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sect. Delhi - 110054. ok
2. The Principal, Queen's Convent School, Sec-25, Rohini, Delhi-110085. Chy

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. Temporary rooms at terrace shall not be used until complied with approved building plans recommendations of this department for addition/ alteration.
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
9. The temporary structure on terrace shall be removed after completion of civil work, within 6 month otherwise the FSC shall stand null & void

WWW.dfs.Delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Queen's Convent School, Sector-25, Rohini, Delhi-85.
2. Type of Occupancy : Educational
3. Type of Case : Renewal (**Ground+03Upper Floor**)
4. Details of previous NOC : F-6/DFS/MS/2017/School/1733 dated 01.12.2017
5. Fire Safety directives letter No : NBC Part-4
6. Date of inspection : 01.04.2021
7. Name of the Inspecting Officers : A.K.Sharma ADO (Rohini)
8. Name and designation of officers
from the building side : Mr. Brij (Care Taker)
9. Year of Construction : 2002
10. Applicant's letter No. : Online mail dated

	Minimum Standards on fire prevention and fire safety U/R 33	DOE Circular dated 17.01.2005	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	6 m	MR
	• Gate width	4.5m	4.10 m	MR (old case)
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50m	1.5m	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	02	02	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1 m	Provided	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Natural Ventilated	MR

5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types ISI marking 	15 nos	30nos	MR
		ABC/Co2	ABC-30	MR
		ISI Marked	Yes	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01	Provided	MR
		30m	Provided	MR
		5mm	5mm	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	Provided	NA
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA	100mm	NA
		NA	Provided	NA
		NA	Provided	NA
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump 			
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		225lpm	225lpm	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		450lpm	450lpm	MR
		40m	40m	MR


	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 ltrs	10,000 ltrs	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection and shortcoming issued vide letter dated 02.02.2021 found removed except point 1 & point-4 which will be rectified by the applicant as per declaration submitted vide letter at C-75.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.6/DFS/MS/2017/School/1733 dated 01.12.2017 is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010 subject to condition that temporary rooms will be used until constructed & Complied as per guidelines issued vide this department letter No. 149 dated 15.03.2021 and fresh FSC from this department.

Note:

Do (NW) - ~~_____~~
 DCPD (W/2)
 16/04/2021


 Signature of the Inspecting Officer
 Name :- A.K.Sharma
 Designation:- ADO/Rohini