

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2021 / School / WZ / 369

Dated: 10/5/21

FIRE SAFETY CERTIFICATE

Certified that the **Rishikul Modern School, Main Saboli Road, Rajeev Colony, Narela, Delhi-110040** comprised of Ground and one upper floor owned/occupied by **Rishikul Modern School** was issued FSC by this department vide letter No **F-6/DFS/MS/School/2016/WZ/1625** dated 03.11.2016. The building was inspected by the officer concerned of this department on 01.04.2021 in the presence of Sh. Ramesh Kumar (Chairman), and observed that all the fire prevention and fire safety arrangements as provided in the building found in good working condition. The premises have deemed complied with the requirements under **Circular No. F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011** issued by Director of Education and the building/ premise is fit for occupancy **Group B Educational** with effect from10/5/21..... for a period of three years, subject to compliance of the conditions mentioned below.

Issued on10/5/21..... at New Delhi

Yours faithfully

(Dharampal Bhardwaj)
Dy. CHIEF FIRE OFFICER
WEST ZONE

Copy to :-

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi-54.
2. The Principal, Rishikul Modern School, Main Saboli Road, Narela, Delhi-40.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Rishikul Modern School, Main Saboli Road, Rajeev Colony , Narela, Delhi-110040.
2. Type of Occupancy : Educational
3. Building Comprised : Ground + One upper floor.
4. Type of Case : Renewal
5. Details of Previous NOC : Letter No. F.6/DFS/MS/SCHOOL/2016/WZ/1625 Dated-03/11/2016
6. Fire Safety directives letter No : Nil
7. Date of inspection : 01/04/2021
8. Name of Inspecting Officer : ADO (BW)
9. Name and designation of officers
From the building side : Sh. Ramesh Kumar (Chairman)
10. Year of Construction : 2007 & 2015
11. Applicant's letter No. : E Mail id , Dated-09/03/2021

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	6.0 m	6.0 m	MR
	• Gate width	4.5 m	4.5 m	MR
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	NA	NA	NA
	• Upper Floors	02	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases	NA	NA	NA
	• Upper Floor	1.50 m	1.10 m & 1.8 m	MR(old case)
	• Basements	NA	NA	NA
	c. Protection of exits	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.00 m	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	NA	NA	NA

	<ul style="list-style-type: none"> Upper floors 	12 a/c per hour	Natural Ventilation	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers 	07	08	MR
	<ul style="list-style-type: none"> Types 	ABC	ABC	MR
	<ul style="list-style-type: none"> IS marking 	Yes	Yes	MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor 	NA	NA	NA
	<ul style="list-style-type: none"> Length of hose reel hose 	NA	NA	NA
	<ul style="list-style-type: none"> Nozzle diameter 	NA	NA	NA
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors 	NA	NA	NA
	<ul style="list-style-type: none"> Location of Main Panel 	NA	NA	NA
	<ul style="list-style-type: none"> Location of Repeater Panel 	NA	NA	NA
	<ul style="list-style-type: none"> Alternate source of power 	NA	NA	NA
	<ul style="list-style-type: none"> Hooters' Location 	NA	NA	NA
8.	MOEFA			
9.	Public Address System			
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement 	NA	NA	NA
	<ul style="list-style-type: none"> Ground Floor 	NA	NA	NA
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	NA	NA	NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	NA	NA	NA
	<ul style="list-style-type: none"> Number of hydrants per floor 	NA	NA	NA
	<ul style="list-style-type: none"> Hose Box 	NA	NA	NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants 	NA	NA	NA
	<ul style="list-style-type: none"> Hose Box 	NA	NA	NA
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> ➤ Discharge of main Pump 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Head of Main pump 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Number of main pumps 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Jockey Pump out put 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Jockey pump head 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Standby Pump out put 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Standby Pump Head 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Auto Starting/Manual Stopping 	NA	NA	NA
		NA	NA	NA

Qw

	➤ Pump House Access	NA	NA	NA
	• Terrace level	-	-	-
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power Supply	-	-	-
	➤ Auto Starting of pump	NA	NA	NA
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15.	Exit Signage.	NA	NA	NA
16.	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

Handwritten signature

--	--	--	--

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules it is recommended for renewal of Fire Safety Certificate issued vide letter no. F-6/DFS/MS/School/2016/WZ/1625 under rule 35 of the Delhi Fire Service Rules 2010.

DO (WZ)

08/04/2021

Dy chd (WZ) ~~DO~~ put up as per circular



Signature of Inspecting Officer

Name : Rajeev Kumar Sinha

Designation : ADO/B.W.

9/4/2021

DO / NW

Necessary connections has been made in DFA & resubmitted wt.

Dy chd (WZ)

8/5/2021

12/04/2021

ADO/B.W

F.T letter is put up to sign please

ADO (B.W) 5/5/21

7/5/2021

DFO (WZ)