

C-24

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE, NEW DELHI


No. F6/DFS/MS/School/2021/ 328

Dated: 16/04/2021

**FIRE SAFETY CERTIFICATE**

Certified that the Royal Indian Public School, Located at D-55 A, Sita Puri-I, Street No. 17, Dabri Palam Road, New Delhi-110045 comprised of Ground + 02 Upper Floor owned/occupied by Royal Indian Public School was issued FSC vide Letter No. F6/DFS/MS/School/2018/SZ/228 Dated 09-12-2018. The premises was re inspected by the officers concerned of this department on 15/03/2021 in the presence of Ms Rakhi Mishra (Teacher) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class " Educational" with effect from 16/4/21 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 16.4.21..... at New Delhi by.

  
(Sunil Chaudhary)  
Dy. Chief Fire Officer  
Delhi Fire Service.

Copy to: -

1. The Principal Royal Indian Public School, Located at D-55 A, Sita Puri-I, Street No. 17, Dabri Palam Road, New Delhi-110045.
2. The Director of Education Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.
3. The Deputy Commissioner, MCD Najafgarh Zone Office Delhi-110043.

**Following fire safety directives must be adhered to:-**

1. **The school activities are not allowed at terrace & choukidar room shall not be used for any purpose.**
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used as per building by laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
9. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expired.

N/11

**INSPECTION REPORT**

1. Name & address of the building: Royal Indian Public School, Located at D-55 A, Sita Puri-I, Street No. 17, Dabri Palam Road, New Delhi-110045.
2. Type of Occupancy : Educational ( Ground + 2 Upper Floor & Toilet chokidar Room at terrace)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2018/SZ/228 Dated 09-12-2018
5. Fire Safety directives Letter No. : N/A
6. Date of inspection : 15-03-2021
7. Name of the Inspecting Officer : ADO (DWK)
8. Name and designation of Officer  
from the building side : Ms Rakhi Mishra (Teacher)
9. Year of Construction : 2004-05
10. Applicant's letter No. : Email Dated 25-03-2021

No. of Students=300  
 No. of class rooms=23  
 Plot area=300 Sq.m<sup>2</sup>  
 Covered area=200 sqm<sup>2</sup>

S No	Minimum standards on fire prevention and fire safety U/R 33	Requirement as per FSC dt. 09-12-2018	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	05 & 4.5 mtr	MR
	• Gate width	4.5mtr	Directly accessible from road	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02 No's	02 No's	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	150 cm/additional staircase of 75 cm if less than 150 cm	150 cm & 100-80 cm	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	Required	01	MR
	e. Width Of Corridor	150 cms	350cm, 230cm & 120 cm	MR (old case)
	f. Door Size	100 cms	100 to 90cm	MR (old case)
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA

4.	Smoke managements System	NA	NA	NA
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper floors</li> </ul>	Required	Natural ventilation provided	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	08 nos. ABC & CO <sub>2</sub> ISI marked	14 Provided ISI marked	MR MR MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	01 no's  30mtr 5m	Provided  Provided Provided	MR  MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	Provided	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	NA NA NA	NA NA NA	NA NA NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> <li>Size of riser/down- comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	NA NA NA	Provided NA NA	NA NA NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	NA NA	NA NA	NA NA
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> <li>Ground Level</li> <li>Discharge of main pump</li> <li>➤ Head of main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Staring/Manual stopping</li> <li>➤ Pump House Access</li> <li>Terrace level</li> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power supply</li> <li>➤ Auto starting of pump</li> </ul>	NA NA NA NA NA NA NA NA NA NA NA NA NA NA	NA NA NA NA NA NA NA NA NA NA NA NA NA NA	NA NA NA NA NA NA NA NA NA NA NA NA NA NA
		450 lpm	Provided	MR
		40Mtr	Provided	MR
		Required	Provided	MR
		NA	NA	NA

14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000Ltr	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and firesafety as required under the rules the NOC issued vide letter no. F6/DFS/MS/School/2018/SZ/228 Dated 09-12-2018 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

**Note; - Toilet, stairs mumty & chokider room are seen at terrace.**

Signature of the Inspecting Officer  
 Name *Uday Kir Singh*  
 Designation *ADDO/OWH*

*Dolew - on leave*

*Dy. Insp. / SZ*

*F.T. p. leave -*

*[Handwritten signature]*