

225

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No. F6/DFS/MS/School/WZ/2021/ 354

Dated: 3/5/2021

FIRE SAFETY CERTIFICATE

Certified that the **Sachedeva Public School**, Located at **FP-Block, Maurya Enclave, Pitampura, Delhi-110034**, comprised of **Two Blocks, BL-1 (Basement + Ground + 02 Upper Floors) & BL-2 (Ground + 01 Upper Floor)** was issued FSC by this department Vide Letter No. F6/DFS/MS/SCHOOL/2018/1361 Dated 12.06.2018. The said premise was re inspected by the officer concerned of this department on 03.04.2021 in the presence of **Dr Virendra Vats (Administrative Officer)** and found that the premises / building have deemed complied with the fire prevention and fire safety requirements in accordance D.O.E Cir. No. 262-362 dated 17-01-2005 and found that the premises/building is fit for occupancy class "Educational" Group B with effect from 3/5/21 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on 3/5/21 at New Delhi by.


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
(West Zone)

Copy to: -

1. The Director, Directorate of Education Old Secretariat Delhi – 110054.
2. The Principal, Sachedeva Public School, FP-Block, Maurya Enclave, Pitampura, Delhi-110034.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time. It should not bolted /locked.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any loss of life any property due to the non-functional of any fire safety measures, management shall be held responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.
9. The basement shall be used as per BBL.

INSPECTION REPORT

1. Name & address of the building: **Sachedeva Public School, Located at FP Block, Maurya Enclave, Pitampura, Delhi – 110034.**
2. Type of Occupancy : Educational {Two Block = BL-1(Basement + Ground + 2 Upper Floors) & BL – 2(Ground + 01 Upper Floors)}
3. Type of Case : Renewal
4. Details of previous NOC: F6/DFS/MS/SCHOOL/2018/1361 Dated 12.06.2018
5. Fire Safety directives Letter No. : D.O.E Cir. 262-362 dated 17-01-2005
6. Date of inspection : 03.04.2021
7. Name of the Inspecting Officer : S.P. Bhardwaj ADO (WP)
8. Name and designation of Officer
from the building side : Dr Virendra Vats (Administrative Officer)
9. Year of Construction : 1988
10. Applicant's letter No. : email dated 18.03.2021

S No	Minimum standards on fire prevention and fire safety U/R 33	D.O.E. Cir.No.262-362 dated 17-01-2005/ letter dated 12.06.2018	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 m	Provided	MR
	• Gate width	5 m	4.9 m Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	3	Provided	MR
	• Basements	3	Provided 5 nos	MR
	b. Width of staircases			
	• Upper floors	1.5m	BL-1 = 1x1.8 m & 2x1.6 m BL -2 = 1x1.4 m, 1x1.6 m & 1x1.75 m	MR
	• Basements	1.5m	1x90 cm, 2x165 cm, 1x180 cm & 1x140 cm	MR
	c. Protection of exits			
	• Fire check door	NA	Provided	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	02	Provided	MR
	e. Width Of Corridor	1.5m	Provided	MR
	f. Door Size	1m	Provided	MR
3.	Compartmentation			
	• Fire check door		NA	NA
	• Sealing of electrical shafts		NA	NA
	• Fire Rating of shaft door		NA	NA
	• Water Curtain		NA	NA
	• Fire Dampers		NA	NA

S.P. Bhardwaj

M123

4.	Smoke managements System					
	<ul style="list-style-type: none"> Basements Upper floors 	Exhaust Fans	Provided		MR	
		NA	NA		NA	
5.	Fire Extinguishers					
	<ul style="list-style-type: none"> Total numbers Types IS marking 	20 nos. ABC & CO ₂ ISI marked	25 Provided		MR	
			Provided			MR
			Provided			MR
6.	First – Aid Hose Reels					
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	03	Provided		MR	
		30m	Provided		MR	
		5mm	Provided		MR	
7.	Automatic fire detection and alarming system					
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA		NA	
		NA	NA		NA	
		NA	NA		NA	
		NA	NA		NA	
		NA	NA		NA	
8.	MOEFA	Required	Provided		MR	
9.	Public Address System	Required	Provided		MR	
10.	Automatic Sprinkler System					
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	Required	Provided		MR	
		NA	NA		NA	
		NA	NA		NA	
11.	Internal Hydrants:					
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	100 mm	Provided		MR	
		02	Provided		MR	
		Required	Provided		MR	
12.	Yard Hydrants					
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA		NA	
		NA	NA		NA	
13.	Pumping Arrangements:					
	<ul style="list-style-type: none"> Ground Level Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	NA	NA		NA	
		NA	NA		NA	
		NA	NA		NA	
		NA	NA		NA	
		NA	NA		NA	
		NA	NA		NA	
		NA	NA		NA	
		NA	NA		NA	
		NA	NA		NA	
		NA	NA		NA	
		450 lpm, 180 lpm & 220 lpm for BL2	Bl-1=450 lpm & 180 lpm Bl-2= 220 lpm		MR	
		40Mtr	Provided		MR	
		Required	Provided		MR	
		Required	Provided		MR	

SR

2/24

14.	Captive water Storage for firefighting:			
	• Underground tank capacity	25,000 ltrs.	50,000 ltrs	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	15,000Ltr	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	ABC Type of Fire Extinguishers provided near Electrical Panel	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards of fire prevention and fire safety requirements as per D.O.E. Cir 262-362 dated 17-01-2005, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/SCHOOL/2018/1361 Dated 12.06.2018 under rules 37 of the Delhi Fire Service Rules 2010 under the DFS Act 2007 is recommended.

S. P. Bhardwaj, ADO (WP)

~~Signature~~

~~Signature~~

O. (WEST)/...113
DATED... 5/4/2021

~~Signature~~
05/04/2021

~~DCFS (W2)~~

~~Signature~~
6/4/2021

~~AAOP/WP~~

FF is put up for signature ph.

~~Signature~~
5/4/2021

~~Signature~~
12/4/21