

C-22

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

No.F.6 DFS/MS/School/2021/SZ/ 332

Dated: 16 / 4 / 2021

FIRE SAFETY CERTIFICATE

Certified that the Sarvodaya Kanya Vidyalaya located at Aya Nagar, New Delhi 110047 comprised of Two blocks, ground plus One upper floors & One New Blocks Ground plus Three upper floors was granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2011/SZ/1172 Dt. 04/08/2017. The said premises was re-inspected by officer concerned of this department on 07/04/2021 in presence of Smt. Babita (Vice Principal) of the school and found that **Sarvodaya Kanya Vidyalaya, Aya Nagar (ID-1923063) running in Ground plus three Upper floor only** and said school building have deemed complied with the fire prevention and fire safety requirements in accordance with DOE Circular dated 01/03/2011 and that the building is fit for occupancy class "**Educational Building Group – B**" with effect from 16 / 4 / 2021 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 16 / 4 / 2021 at New Delhi by



(Sunil Chawdhary)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service



Copy to: -

1. The Principal, Sarvodaya Kanya Vidyalaya, Aya Nagar, New Delhi, 110047 (ID-1923063)
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

INSPECTION REPORT

1	Name & Address of the Building	Sarvodaya kanya Vidyalaya, at Aya Nagar New Delhi 110047 (ID-1923063)		
2	Type of Occupancy	Educational		
3	Building Comprised of	Ground plus Three upper floor		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/School/2011/SZ/1172 Dt. 04/08/2017 (for Two old block- Ground + One Upper floors & One New Block Ground + Three Upper Floor) Now One Block, Ground + Three Upper floor is Sarvodaya kanya Vidyalaya, Aya Nagar, & GBSSS Aya Nagar comprised of two blocks, G+1 upper floors having FSC vide even no 69 dated 28/01/2021		
6	Fire Safety Directives Letter No	F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011		
7	Date of Inspection	07/04/2021		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Smt. Babita (Vice Principal)		
10	Year of construction	2016		
11	Applicant letter No.	Gmail ID Dated 24/03/2021		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	Required	7 mtr	MR
	• Gate width	Required	5 x 2 mtr	MR
	• Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	02 Nos	04 Nos	MR
	➤ Basement floor.	-NA-	-NA-	-NA-
	b) Width of Staircase			
	➤ Upper floors	1.50 mtr	1.80 mtr each	MR
	➤ Basement floor	-NA-	-NA-	-NA-
	c) Protection of exits			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	One	02Nos provided	MR
	e) Width of corridor	-NA-	-NA-	-NA-
	f) Door size	1 mtr	1 mtr	MR
3	Compartmentation.			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4.	Smoke Management system.			
	• Basement	30a/c per hour	-NA-	-NA-
	• Upper floors	12a/c per hour	-NA-	-NA-
5.	Fire Extinguishers.			
	• Total numbers	Required	35 Nos	MR
	• Types	CO ² &ABC	CO ² & ABC	MR
	• ISI Marking	ISI mark	Provided	MR
6.	First Aid Hose Reels.			


N/14

	• Total area	-NA-	-NA-	-NA-
	• Location	-NA-	-NA-	-NA-
19.	Fire Control Room.			
	• Detector system panel.	-NA-	-NA-	-NA-
	• Flow switch panel.	-NA-	-NA-	-NA-
	• PA system panel.	-NA-	-NA-	-NA-
	• Battery backup.	-NA-	-NA-	-NA-
	• Building floor plan.	-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.	-NA-	-NA-	-NA-

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/School/2011/SZ/1172 Dt. 04/08/2017 (for Two old block- Ground + One Upper floors & One New Block Ground + Three Upper Floor), renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.


 Signature of the Inspecting Officer
 Name: Sh. Rajesh Kumar
 Design: ADO (BCP)

~~DO (SD)~~

~~DO (SD)~~

F.T.

~~DO (SD)~~

~~ADO (BCP)~~

As approved, F.T. letter is put up for your signature pl.

1/14
12/14

~~DO (SD)~~

MS. 1/14