

921

FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[See sub-rule (1) of rule 35]  
**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**


No. F.6/DFS/MS/School/2021/SZ/ 342

Dated: 22/04/2021

**FIRE SAFETY CERTIFICATE**

Certified that the Sarvodaya Kanya Vidyalaya (ID: 1925037, Morning Shift) & Sarvodaya Boys Vidyalaya (ID: 1925009, Evening Shift) located at Molarband, New Delhi-44 comprised of Old Buildings – Ground + 1 upper floor, New Building – Ground + 3 upper floors has been issued Fire Safety Certificate Vide letter No. F.6/DFS/MS/School/2017/SZ/1570 dated 03/11/2017. The premises was re-inspected by the officer concerned of this department on 07.04.2021 in the presence of Sh. Bali Ram Nath (HOS) and found to have complied with the fire prevention and fire safety arrangements in accordance with circular No. F6/Estate/CC/Fire/Safety/2011/3298-3398 dated 01/03/2011 and that the building / premises is fit for occupancy class "Educational" (Group-B) with effect from 22/04/2021 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS Rules, 2010

Issued on 22/04 /2021 at New Delhi by



(SUNIL CHAUDHARY)

DY. CHIEF FIRE OFFICER (SZ)

Copy to: -

1. The Principal, Sarvodaya Kanya Vidyalaya (ID: 1925037, Morning Shift), Molarband, New Delhi-110044
2. The Director of Education, GNCT of Delhi, Old Secretariat, Delhi-110054

**Conditions for the validity of Fire Safety Certificate:**

1. All the means of escape / entry / exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
3. Any loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of fire fighting system.
5. This Fire Safety Certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3. of UBBL-2016), if any.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.Delhigovt.nic.in](http://www.dfs.Delhigovt.nic.in).

## INSPECTION REPORT

1.	Name & address of the building	Sarvodaya Kanya Vidyalaya (ID: 1925037, Morning Shift) & Sarvodaya Boys Vidyalaya (ID: 1925009, Evening Shift), Molarband, New Delhi-110044		
2.	Type of Occupancy	Educational		
3.	Building Comprised of	Old Block (G+1) =04 Blocks New Block (G+3) =01 Block.		
4.	Type of Case	Renewal		
5.	Details of previous NOC	F.6/DFS/MS/School/2017/SZ/1570 dated 03/11/2017		
6.	Fire Safety directives Letter No	DOE Cir. Dated 01/03/2011		
7.	Date of Inspection	07.04.2021		
8.	Name of the Inspecting Officer	ADO (SJ)		
9.	Name and Designation of Officer from the building side	Sh. Bali Ram Nath (HOS)		
10.	Year of Construction	1960 & 2016		
11.	Applicant's letter No.	Email dated 25/03/2021		
S. No	Minimum standards on fire prevention and fire safety U/R 33	NBC/BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Required	6m ✓	MR
	• Gate width	Required	4.5m ✓	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	Old Blk=2+1+1+1+1 New Blk= 2 Nos.	Old Blk 3+1+1+1+1 New Blk= 2 Nos.	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.50 m /0.75m 1.50m	Old Blk-1.5, 1.45, 1.45, 1.5, 1.5 & 1.5m New Blk- 1.60m each	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	Required	One ✓	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1m	1m ✓	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	NA	NA
5.	Fire Extinguishers			
	• Total numbers	38 Nos	40 Nos. ✓	MR
	• Types	ABC / CO <sub>2</sub>	ABC-30, CO <sub>2</sub> -10	MR
	• ISI marking	ISI Marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	New Blk= 2 Nos	New Blk= 2 Nos ✓	MR
	• Length of hose reel hose	30m	30m	MR
	• No. of diameter	5mm	5mm	MR

7.	Automatic fire detection and alarming system			NA	NA	NA
	<ul style="list-style-type: none"> <li>Type of detector</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	NA	NA	NA	NA	
8.	MOEFA	NA	NA	NA	NA	
9.	Public Address System	NA	NA	NA	NA	
10.	Automatic Sprinkler System			NA	NA	NA
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	NA	NA	NA	NA	
11.	Internal Hydrants			NA	NA	NA
	<ul style="list-style-type: none"> <li>Size of riser/down- comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	NA	NA	NA	NA	
12.	Yard Hydrants			NA	NA	NA
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	NA	NA	NA	NA	
13.	Pumping Arrangements					
	<ul style="list-style-type: none"> <li>Ground Level</li> </ul>					
	<ul style="list-style-type: none"> <li>Discharge of main pump</li> <li>Head of main pump</li> <li>Number of main pumps</li> <li>Jockey pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Staring/Manual stopping</li> <li>Pump House Access</li> </ul>	NA	NA	NA	NA	
	<ul style="list-style-type: none"> <li>Terrace level</li> </ul>					
	<ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power supply</li> <li>Auto starting of pump</li> </ul>	450 LPM (New Blk)	450 LPM x 2 (New Blk)	MR	MR	
		40m	40m each	MR	MR	
		Required	Provided	MR	MR	
		Required	Provided	MR	MR	
14.	Captive water Storage for fire fighting					
	<ul style="list-style-type: none"> <li>Underground tank capacity <ul style="list-style-type: none"> <li>Draw of connection</li> <li>Fire service inlet</li> <li>Access to tank</li> </ul> </li> <li>Overhead Tank capacity</li> </ul>	NA	NA	NA	NA	
		NA	NA	NA	NA	
		NA	NA	NA	NA	
		10,000 Ltr.	10,000 Ltr	MR	MR	
		Required	Provided	MR	MR	
15.	Exit Signage					
16.	Provision of Lifts					
	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> <li>Pressurization of lift lobby</li> <li>Communication in lift Car</li> <li>Fireman's Grounding Switch</li> <li>Lift Signage</li> </ul>	NA	NA	NA	NA	
		NA	NA	NA	NA	
		NA	NA	NA	NA	
		NA	NA	NA	NA	
		NA	NA	NA	NA	
17.	Standby power supply			NA	NA	NA
18.	Refuge Area					
	<ul style="list-style-type: none"> <li>Total area</li> </ul>	NA	NA	NA	NA	
		NA	NA	NA	NA	

19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F.6/DFS/MS/School/2017/SZ/1570 dated 03/11/2017, renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

*[Signature]*  
15/04/2021

Signature of the Inspecting Officer  
Name : Ashok Kumar Jaiswal  
Designation: ADO (SJ)

DO (SD)

*[Signature]*  
16/04/21

*[Signature]*  
DeFO (SZ)

F.7.

*[Signature]*  
16/4/21

*[Signature]*  
DO (SD)

F.T. is added for sign. pl.

*[Signature]*  
22/4/2021

*[Signature]*  
DYCFO (SZ)

MS. *[Signature]*