

c/21

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001


No F 6 / DFS / MS / 2021/ School/WZ/ 346

Dated: 22/04/2021

FIRE SAFETY CERTIFICATE

Certified that **The Vivekanand School (ID-1310448)** located at **,Shiv Mandir Colony, Narela, Delhi-110040** comprised of Ground + one upper floor owned/occupied by **The Vivekanand School** was issued fire safety certificate for Ground Floor only vide **letter no. F6/DFS/MS/School/2018/586 Dated-05/04/2018**. The premises was inspected by the officer concerned of this department on dated-01.04.2021 in the presence of Sh. Devi Ram Khatri (Chairman) and observed that management has added one more floor but it is not in use and kept sealed. The fire prevention & fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with the requirements of **Circular No. F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011** issued by Director of Education and that the building / premises at **Ground Floor Only** is fit for occupancy of **Group B (Educational)** with effect from 22/04/2021 for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on ... 22/04/2021 ... at New Delhi


(sunil choudhary)
Dy. Chief Fire Officer
West Zone

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Principal , The Vivekanand School, Shiv Mandir Colony, Narela, Delhi-110040.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : The Vivekanand School (ID-1310448), Shiv Mandir Colony, Narela Delhi-110040
2. Type of Occupancy : Educational
3. Building Comprised : Ground ~~Floor only~~ and one upper floor but school is running in ground floor only. 1st floor is sealed by owner.
4. Type of Case : Renewal
5. Details of Previous NOC : Letter No. F.6/DFS/MS/SCHOOL/2018/586 Dated-05/04/2018 For G.F only
6. Fire Safety directives letter No : Nil
7. Date of inspection : 01/04/2021
8. Name of Inspecting Officer : ADO (BW)
9. Name and designation of officers
From the building side : Sh. Devi Ram Khatri (Chairman)
10. Year of Construction : 2005
11. Applicant's letter No. : Letter No. TVS/MAR/2021/, Dated-15/03/2021

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	6.0 m	6.0 m	MR
	• Gate width	4.5 m	4.5 m	MR
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	NA	NA	NA
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.00 m	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	NA	NA	NA

B

	<ul style="list-style-type: none"> • Upper floors 	NA	NA	NA
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	07	12	MR
	<ul style="list-style-type: none"> • Types 	ABC	ABC	MR
	<ul style="list-style-type: none"> • IS marking 	Yes	Yes	MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor 	NA	NA	NA
	<ul style="list-style-type: none"> • Length of hose reel hose 	NA	NA	NA
	<ul style="list-style-type: none"> • Nozzle diameter 	NA	NA	NA
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors 	NA	NA	NA
	<ul style="list-style-type: none"> • Location of Main Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Location of Repeater Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Alternate source of power 	NA	NA	NA
	<ul style="list-style-type: none"> • Hooters' Location 	NA	NA	NA
8.	MOEFA			
9.	Public Address System			
		NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basement 	NA	NA	NA
	<ul style="list-style-type: none"> • Ground Floor 	NA	NA	NA
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	NA	NA	NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	NA	NA	NA
	<ul style="list-style-type: none"> • Number of hydrants per floor 	NA	NA	NA
	<ul style="list-style-type: none"> • Hose Box 	NA	NA	NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants 	NA	NA	NA
	<ul style="list-style-type: none"> • Hose Box 	NA	NA	NA
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> • Ground Level 			
	<ul style="list-style-type: none"> ➤ Discharge of main Pump 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Head of Main pump 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Number of main pumps 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Jockey Pump out put 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Jockey pump head 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Standby Pump out put 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Standby Pump Head 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Auto Starting/Manual Stopping 	NA	NA	NA
		NA	NA	NA

2

	➤ Pump House Access	NA	NA	NA
	• Terrace level	NA	NA	NA
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power Supply	-	-	-
	➤ Auto Starting of pump	NA	NA	NA
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15.	Exit Signage.			
16.	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

R

--	--	--	--	--

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules it is recommended for renewal of Fire Safety Certificate issued vide letter no.F-6/DFS/MS/School/2018/586 under rule 35 of the Delhi Fire Service Rules 2010.

ADO (B.W.)
5/4/21

DO (B.W.)
G+1 bldg.
Make connection in DFA

Signature of Inspecting Officer

Name : Rajeev Kumar Sinha

Designation : ADO/B.W.

ADO (B.W.)
02/04/2021
ADO (B.W.) Connected DFA is put up.

DO (B.W.)
ADO (B.W.)
9/4/21
It is a G+1 of bldg. and not covered in Rule-27 of DFS Rules-2010. Make DFA as per C-15

ADO (B.W.)
12/04/2021
ADO (B.W.) DFA extracted and put up.

DO (B.W.)
ADO (B.W.)
13/4/21
ADO (B.W.)
15/04/2021
By C/O (S2 & P2)

F.T.