

4/29

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2021/ School/WZ/ 347

Dated: 22/04/2021

FIRE SAFETY CERTIFICATE

Certified that **White Leaf Public School** located at , **Narela Road, Bawana, Delhi-110039** comprised of **Two Blocks, Ground+one upper floor** owned/occupied by **White Leaf Public School** was issued fire safety certificate vide letter no. **F-6/DFS/MS/2017/School/WZ/635 Dated-04/05/2017**. The premises was inspected by the officer concerned of this department on dated-05.04.2021 in the presence of Smt. Anila Rani (Manager) and found that the fire prevention & fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the requirements under rule 33 of Delhi Fire Service Rules, 2010 and the building / premises is fit for occupancy of **Group B (Educational)** with effect from 22/04/2021 for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on22/04/2021 at New Delhi



(sunil choudhary)
Dy. Chief Fire Officer
West Zone

OLR

Copy to : -

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Principal , White Leaf Public School, Narela Road, Bawana, Delhi-110039.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **WWW.dfs.Delhigovt.nic.in**

INSPECTION REPORT

1. Name & address of the building : White Leaf Public School, Narela Road ,Bawana , Delhi-110039.
 2. Type of Occupancy : Educational
 3. Building Comprised : Two Blocks (Ground + One upper floor)
 4. Type of Case : Renewal
 5. Details of Previous NOC : Letter No. F.6/DFS/MS/2017/School/WZ/635 Dated-04/05/2017
 6. Fire Safety directives letter No : Nil
 7. Date of inspection : 05/04/2021
 8. Name of Inspecting Officer : ADO (BW)
 9. Name and designation of officers :
 From the building side : Smt. Anila Rani (Manager)
 10. Year of Construction : 1999 & 2010
 11. Applicant's letter No. : E Mail id , Dated-26/03/2021

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Requirement	Provided at site	Remarks MR/NMR
1.	Access to building	6.0 m	6.0 m	MR
	• Road width	4.5 m	4.5 m	MR
	• Gate width	NA	NA	NA
	• Width of internal road			
2.	Number, Width, Type & Arrangement of Exits	NA	NA	NA
	a. Number of staircases	02	02	MR
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases	1.50 m	1.50 m each	MR
	• Upper Floor	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	1.00 m	Provided	MR
	f. Door Size			
3.	Compartmentation	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System	NA	NA	NA
	• Basements	12 a/c per hour	Natural Ventilation	MR
	• Upper floors			

B

5.	Fire Extinguishers	09	15	MR
	<ul style="list-style-type: none"> Total numbers Types IS marking 	ABC	ABC	MR
		Yes	Yes	MR
6.	First-Aid Hose Reels	NA	NA	NA
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	NA	NA	NA
		NA	NA	NA
7.	Automatic fire detection and alarming system	NA	NA	NA
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
	<ul style="list-style-type: none"> Hooters' Location 	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System	NA	NA	NA
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11.	Internal Hydrants	NA	NA	NA
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12.	Yard Hydrants	NA	NA	NA
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13.	Pumping Arrangements	NA	NA	NA
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping Pump House Access 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA

Pa

	<ul style="list-style-type: none"> • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	- NA	- NA	- NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		-	-	-
		NA	NA	NA
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity <ul style="list-style-type: none"> ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
15.	Exit Signage.	NA	NA	NA
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	NA	NA	NA
		NA	NA	NA
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

B

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules it is recommended for renewal of Fire Safety Certificate issued vide letter no. F-6/DFS/MS/2017/School/WZ/635 under rule 35 of the Delhi Fire Service Rules 2010.

(Signature)
ADO (B.W.)
8/4/21

Do (NW)

It is not covered under Rule-27. Make correction in DFA

(Signature)
08/04/2021

~~ADO (B.W.)~~ Corrected DFA is Putup

(Signature)
ADO (B.W.)
9/4/21

Make as per C-20

(Signature)
12/04/2021

~~ADO (B.W.)~~ Corrected DFA is Putup

(Signature)
ADO (B.W.)
13/4/21

~~Do (NW)~~

(Signature)
15/04/2021

By C20 (S2R/W2)

F. T.

~~ADO Bapatna~~

Signature of Inspecting Officer

Name : Rajeev Kumar Sinha

Designation : ADO/B.W.