

C-18

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001



No F 6 / DFS / MS / 2021 / 382

Dated: 24/5/2021

FIRE SAFETY CERTIFICATE

Certified that **M.C. Primary Pratibha School** located at **Bhalaswa Village, Delhi-110033** comprised of **03 Blocks (Two blocks Ground floor & One block Ground +01 upper floor)** owned/ occupied by **M.C. Primary Pratibha School** was issued Fire Safety Certificated by this department vide letter no. **No.F6/DFS/MS/School/2017/WZ/335 dated 08.03.2017 (Ground floor)**. The premises was re-inspected by the officer concerned of this department on **16.03.2021** in presence of **Mr. Vimal Chander (Teacher)** and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class Group B Educational with effect from **24/5/21** for a period of three years, subject to compliance of the conditions mentioned below:

Issued on **24/5/21** at New Delhi by.


(Atul Garg)
Director
Ph:-011-23414000


Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 54.
2. The Principal, M.C Primary Pratibha School, Bhalswa Village, Delhi-110033.

Conditions for the validity of Fire Safety Certificate:

- 1 All the means of escape/entry/exit shall be kept free from any obstruction.
- 2 All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
- 3 All the staff members must know the correct method of operation of firefighting system.
- 4 The owner / occupier shall submit a declaration **every year in Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in./wps/wcm/connect/doi/fire/FIRE/Home/Forms>.
- 5 This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
- 6 "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

INSPECTION REPORT

- | | |
|--|--|
| 1. Name & address of the building | : M.C Primary Pratibha School, Bhalswa Village, Delhi-110033. |
| 2. Type of Occupancy | : Educational |
| 3. Type of Case | : Add/Alt 03 Blocks (02 block- Ground floor & 01 block G + 01 upper floor) |
| 4. Details of previous NOC | : F6/DFS/MS/School/2017/WZ/335 Dated: 08.03.2017 Ground Only |
| 5. Fire Safety directives letter No | : Director of Education Circular dated 01.03.2011 |
| 6. Date of inspection | : 16.04.2021 |
| 7. Name of the Inspecting Officers | : ADO (RN) |
| 8. Name and designation of officers from the building side | : Mr. Vimal Chander (Teacher) |
| 9. Year of Construction | : 1993 & 2013, 2019 |
| 10. Applicant's letter No. | : Online E-mail ID dated: 05.04.2021 |

Plot Area-4452 m2 Covered Area: 1286 m2 No of class rooms -14 nos. No of students---620 nos.


| Minimum Standards on fire prevention and fire safety U/R 33 | | Director of Education | Provided at site | Remarks MR/NMR |
|---|---|-----------------------|------------------|----------------|
| 1 | Access to building | | | |
| | • Road width | 06m | 06m | MR |
| | • Gate width | 4.5m | 4..5m | MR |
| | • Width of internal road | NA | NA | NA |
| 2 | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | | | |
| | • Upper Floors | 01 | 01 | MR |
| | • Basements | NA | NA | NA |
| | b. Width of staircases | | | |
| | • Upper Floors | 1.5m | 1.5m | MR |
| | • Basements | NA | NA | NA |
| | c. Protection of exits | | | |
| | • Fire check door | NA | NA | NA |
| | • Pressurization | NA | NA | NA |
| | d. No. of continuous staircases to terrace | NA | NA | NA |
| | e. Width of Corridor | NA | NA | NA |
| f. Door Size | 1 m | 1m | MR | |
| 3 | Compartmentation. | | | |
| | • Fire check door | NA | NA | NA |
| | • Sealing of electrical shafts | NA | NA | NA |
| | • Fire Rating of shaft door | NA | NA | NA |
| | • Water Curtain | NA | NA | NA |
| | • Fire Dampers | NA | NA | NA |
| 4 | Smoke Management System. | | | |
| | • Basements | 12 a/c per hour | NA | NA |
| | • Upper floors | 12 a/c per hour | NA | NA |
| 5 | Fire Extinguishers | | | |
| | • Total numbers | 10nos | 12nos | MR |
| | • Types | ABC/Co2 | ABC-12 | MR |
| | • ISI marking | ISI Marked | | |

| | | | | |
|----|---|-----|-----|-----|
| | <ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| 7 | Automatic fire detection and alarming system. | | | |
| | <ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| 8 | MOEFA | NA | NA | NA |
| 9 | Public Address System. | | | |
| 10 | Automatic Sprinkler System. | | | |
| | <ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| 11 | Internal Hydrants | | | |
| | <ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| 12 | Yard Hydrants. | | | |
| | <ul style="list-style-type: none"> Total number of hydrants Hose Box | NA | NA | NA |
| | | NA | NA | NA |
| 13 | Pumping Arrangements. | | | |
| | <ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| 14 | Captive Water Storage for fire fighting. | | | |
| | <ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |

| | | | | |
|----|--|-----|-----|-----|
| 15 | Exit Signage. | NA | NA | NA |
| 16 | Provision of Lifts. | | | |
| | • Pressurization of Lift Shaft | N/A | N/A | N/A |
| | • Pressurization of Lift lobby | N/A | N/A | N/A |
| | • Communication In lift Car | N/A | N/A | N/A |
| | • Fireman's Grounding Switch | N/A | N/A | N/A |
| | • Lift Signage | N/A | N/A | N/A |
| 17 | Standby power supply | N/A | N/A | N/A |
| 18 | Refuge Area. | | | |
| | ➤ Total Area | N/A | N/A | N/A |
| | ➤ Location | N/A | N/A | N/A |
| 19 | Fire Control Room | | | |
| | • Detector System Panel | N/A | N/A | N/A |
| | • Flow Switch Panel | N/A | N/A | N/A |
| | • PA System Panel | N/A | N/A | N/A |
| | • Batter backup | N/A | N/A | N/A |
| | • Building Floor Plans | N/A | N/A | N/A |
| 20 | Special Fire Protection Systems for Protection of special Risks, if any: | N/A | N/A | N/A |

The fire protection systems provided in the building were tested/ checked randomly and found in good working condition, at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in director of education Circular dated 01.03.2011, it is recommended to renewal of fire safety certificate issued vide this department letter of even no. 335 dated 24.07.2014(ground floor only).



Do(NW) - ON Leave
By Cfo (NW)
20/11

(Signature)
 19/04/2021
 Signature of the Inspecting Officer
 Name :- C.L. Meena
 Designation:- ADO/RN

CF/O

(Signature)
 4/5

FIR

(Signature)
 6/09/2021

(Signature)
 7/07/2021