

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**


No. F.6/DFS/MS/CNG/2021/SZ/ 257

Dated: 25/05/2021

FIRE SAFETY CERTIFICATE

Certified that **CNG Dispensing Station** located at **Jasola, New Delhi** comprised of Single story building owned/occupied by M/s Indraprastha Gas Limited, was granted FSC by this department vide letter no. F6/MS/DFS/CNG/2018/SZ/1115 Dated 16/05/2018. The premise was re-inspected by the officer concerned of this department on 15.04.2021 in the presence of Mr. Manoj (Manager) of the said filling station and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Hazardous** (CNG Pump) as above with effect from 25/05/2021 for a period of **three years** in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010.

Issued on 25/05/2021 at New Delhi by


(Sunil Chawdhary)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Joint C.P (Lic.) First Floor, PS Defence Colony, New Delhi 110049.
2. Sh. Ajay Khatri, DGM-(Fire & Safety) (IGL) LGL Bhawan, Plot No 4, Community Centre, R. K Puram, Sector- 09, New Delhi 110049

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

INSPECTION REPORT

1	Name & Address of the Building	CNG Dispensing station, Jasola, New Delhi		
2	Type of Occupancy	Hazardous "Group -J (CNG Pump)		
3	Building Comprised of	Ground floor only		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/MS/DFS/CNG/2018/SZ/1115 Dated 16/05/2018		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	15-04-2021		
8	Name of the Inspecting Officers	Mr. Rajesh Kumar (ADO BCP)		
9	Name & Designation of Officers from the building side	Mr. Manoj (Manager)		
10	Year of construction	2000		
11	Applicant letter No.	Gmail Dated 12-04-2021		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	06 mtr -NA- -NA-	Provided -NA- -NA-	MR -NA- -NA-
2	Number, width, type and arrangements of exits.			
	a. Number of Staircase			
	<ul style="list-style-type: none"> Upper floors Basement floor 	-NA- -NA-	-NA- -NA-	-NA- -NA-
	b. Width of Staircase			
	<ul style="list-style-type: none"> Upper floors Basement floor 	-NA- -NA-	-NA- -NA-	-NA- -NA-
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	-NA- -NA-	-NA- -NA-	-NA- -NA-
	d. No. of continuous staircase to terrace	-NA-	-NA-	-NA-
	e. Width of corridor	-NA-	-NA-	-NA-
	f. Door size	-NA-	-NA-	-NA-
3	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door. Sealing of electrical shafts. Fire rating of shaft door. Water curtain Fire dampers. 	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-
4	Smoke Management system.			
	<ul style="list-style-type: none"> Basement Upper floors 	-NA- -NA-	-NA- -NA-	-NA- -NA-
5	Fire Extinguishers.			
	<ul style="list-style-type: none"> Total numbers Types ISI Marking 	Required ISI Marked	21 Nos DCP/75 kg- 4, DCP/10kg - 12 & CO ₂ - 05 Provided	MR MR MR
6	First Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor. Length of hose-reel hose. Nozzle Diameter 	-NA- -NA- -NA-	-NA- -NA- -NA-	-NA- -NA- -NA-

7	Automatic Fire Detection and Alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	Gas & Flame Required	Provided in compressors Ground floor	MR MR
		-NA-	-NA-	-NA-
		Required	Provided	MR
		Required	Technician room	MR
8.	MOEFA	-NA-	-NA-	-NA-
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper floors Sprinkler above false ceiling 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
11.	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser / Down-comer Number of Hydrant per floor Hose box. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
13.	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level ➤ Discharge of main pump. ➤ Head of main pump. ➤ Number of main pumps. ➤ Jockey Pump output. ➤ Jockey Pump head. ➤ Standby Pump output. ➤ Standby Pump head. ➤ Auto Starting/Manual Stopping. Terrace Level ➤ Discharge of pump. ➤ Head of pump. ➤ Power supply. ➤ Auto starting of pump. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
14.	Captive water storage for fire-fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. <ul style="list-style-type: none"> ➤ Draw-off connection. ➤ Fire Service Inlet. ➤ Access to tank. Overhead tank capacity. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
15.	No Smoking signage	Required	Provided in Hindi & English	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
17	Standby Power Supply	NA	Provided (DG Set)	NA
18.	Refuge Area			
	<ul style="list-style-type: none"> Total area 	-NA-	-NA-	-NA-

2/1/18

19.	Fire Control Room.			
	• Detector System Panel.	-NA-	-NA-	-NA-
	• Flow Switch Panel.	-NA-	-NA-	-NA-
	• PA system Panel.	-NA-	-NA-	-NA-
	• Battery backup	-NA-	-NA-	-NA-
	• Building floor plan	-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.	NA	Co2 flooding system connected through detectors provided in each compressor unit	MR

"No Smoking" Sign boards were found displayed both in Hindi & English at conspicuous places. No loose electric wiring was seen in the premises.

The fire protection systems provided in the building were test checked at random and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under rules, renewal of the FSC issued vide letter No. F6/MS/DFS/CNG/2018/SZ/1115 Dated 16/05/2018 under rules 37 of the Delhi Fire Service Rules 2010 is recommended.

Accordingly, DFA is put up for perusal and signature please.

16/5/18

Signature of the Inspecting Officer
 Name: Mr. Rajesh Kumar
 Designation: ADO (BCP)

DO (SD)

16/5/18

Defo (M)

~~ADO (BCP)~~

As approved, A-1 letter is put up for your signature pl

16/5/18

DO (SD)