

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE**

**NEW DELHI- 110001**

No.F6/DFS/MS/Industry/2021/SZ/261

Dated: 10/06/2021

**FIRE SAFETY CERTIFICATE**

Certified that the M/s Tin Box Company B-68, Mayapuri Industrial Area, Phase-I, New Delhi-110064, comprised of Basement, ground & Mezzanine floor, owned/occupied by M/s Tin Box Company. The premises was re-inspected by the officers concerned of this department on 15/04/2021 in the presence of Sh. Aman Mehra and found that the building/premises have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy Moderate Hazard with effect from 10/06/2021 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued on 10/06/2021 at New Delhi by.

(Atul Garg)  
Director

Delhi Fire Service

Copy to:-

M/s Tin Box Company B-68, Mayapuri Industrial Area, Phase-I, New Delhi-110064.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall not be used for any purpose.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/7

**INSPECTION REPORT**

1. Name & address of the building : M/s Tin Box Company B-68, Mayapuri Industrial Area, Phase-I, New Delhi-110064.
2. Building is comprised of : Basement (closed), ground & Mezzanine floor.( industry proposed to function at ground & mezzanine floor only)
3. Type of Occupancy : Moderate hazard
4. Type of Case : New
5. Details of Previous NOC : Nil
6. Fire Safety direction letter No : F6/DFS/MS/BP/202/58 Dated 08/01/2021
7. Date of Inspection : 15/04/2021
8. Name of the Inspecting Officers: : ADO R.K. YADAV DO D.B. Mukharjee
9. Name of the designation of Officer from the building side : Sh. Aman Mehra
10. Year of Construction : 1982
11. Applicant's letter No : Nil Dated -22/03/2021

S.No	Minimum Standards on fire prevention and fire safety requirements U/R 33	Requirement	Provided at Site	Remarks MR/NMR	
1	<b>Access to building</b>				
	Road width	12 mtrs.	18 mtrs.	MR	
	Gate width	05 mtrs.	05 mtrs.	MR	
	Width of internal road	N.A.	N.A.	N.A.	
2	<b>Number, Width, Type and Arrangement of Exits</b>				
	a. Number of Staircases	Upper Floor	2 nos.	3 nos.	MR
		Basement	N.A.	N.A.	N.A.
	B. Width of Staircases	Upper Floor	1.5 m	2 no. of 1.5 & 1.15 M	MR
		Basement	N.A.	N.A.	N.A.
	c. Protection of exits	Fire check door	Required	Provided	MR
		Pressurization	N.A.	N.A.	N.A.
	e. No. of continuous staircases to terrace	2 no.	2 no.	MR	
	g. Width of Corridor	N.A.	N.A.	N.A.	
	h. Door Size	2 M	Provided	MR	
3	<b>Compartmentation.</b>				
	Fire check door	Required	Provided	MR	
	Sealing of electrical shafts	Required	Provided	MR	
	Fire rating of shaft door	Required	Provided	MR	
	Water curtain	N.A.	N.A.	N.A.	
	Fire Dampers	N.A.	N.A.	N.A.	
4.	<b>Smoke Management System.</b>				
	Basement	Required	Provided	MR	
Upper floor	Required	Natural Ventilation provided	MR		


<b>5.</b>	<b>Fire Extinguisher</b>			
	Total numbers	08 Nos.	08 Nos.	MR
	types	CO <sub>2</sub> & ABC	CO <sub>2</sub> & ABC	MR
	IS marking	ISI marked	ISI marked	MR
<b>6</b>	<b>First-aid-Hose Reels.</b>			
	Total numbers of each floor	2 No.	Provided	MR
	Length of hose reel hose	30 M	Provided	MR
	Nozzle diameter	05 MM	Provided	MR
<b>7</b>	<b>Automatic fire detection and alarming system.</b>			
	Type of detectors	N.A.	Provided	MR
	Location of main panel	N.A.	Provided	MR
	Location of repeater panel	N.A.	Provided	MR
	Alternate source of power	N.A.	Provided	MR
	Hooters	N.A.	Provided	MR
<b>8</b>	<b>MOEFA</b>	N.A.	Provided	MR
<b>9</b>	<b>Public address System.</b>	N.A.	Provided	MR
<b>10</b>	<b>Automatic Sprinkler System.</b>			
	Basement	N.A.	N.A.	N.A.
	upper floor	Required	Provided	MR
	sprinkler above false ceiling	N.A.	N.A.	N.A.
<b>11</b>	<b>Internal Hydrants</b>			
	size of riser/down-comer	N.A.	Provided	MR
	Number of hydrants per floor	N.A.	Provided	MR
	Hose Box	N.A.	Provided	MR
<b>12</b>	<b>Yard Hydrants.</b>			
	Total number of hydrants	N.A.	Provided	MR
	Hose Box	N.A.	Provided	MR
<b>13</b>	<b>Pumping Arrangements.</b>			
	• Ground Level	N.A.	N.A.	N.A.
	➤ Discharge of main Pump	N.A.	N.A.	N.A.
	➤ Head of Main Pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting /Manual stopping	N.A.	N.A.	N.A.
	➤ Pump House Access	N.A.	N.A.	N.A.
	• Terrace Level			
	➤ Discharge of pump	900 LPM	900 LPM	MR
	➤ Head of the Pump	40M	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR


N/9

<b>14</b>	<b>Captive Water Storage for Fire Fighting.</b>			
	Underground tank capacity	N.A.	N.A.	N.A.
	Draw-off connection	N.A.	N.A.	N.A.
	Fire service inlet	N.A.	N.A.	N.A.
	Access to tank	N.A.	N.A.	N.A.
	Overhead Tank capacity	20,000 Liters	Provided	MR
<b>15</b>	<b>Exit Signage.</b>	Required	Provided	MR
<b>16</b>	<b>Provision of Lifts.</b>			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.
<b>17</b>	<b>Standby power supply</b>	Required	Provided	MR
<b>18</b>	<b>Refuge Area.</b>			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
<b>19</b>	<b>Fire Control Room</b>			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
<b>20</b>	<b>Special Fire Protection systems for protection of special Risks, if any:</b>	Required	HT & LT Panel provided	MR

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the above substantial compliance of the minimum standards of fire prevention and fire safety measures as required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

  
 Signature of Inspecting Officer  
 Name:- R.K.Yadav  
 Designation:- Asstt.Divisional Officer

  
 Signature of Inspecting Officer  
 Name:- D.B.Mukharjee  
 Designation:- Divisional Officer

By cr0 / (s2) why the file is put up after one month?

DO + ADD (P) 2/15