

FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE

[See sub-rule (1) of rule 35]

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI -110001**

No. F.6/DFS/MS/2021/SZ/ EH/116

Dated: 16 / 06 / 2021

**FIRE SAFETY CERTIFICATE**

Certified that the M/s Heineken Bar, (HMShost Hospitality Services Bharath Private Limited) located at Domestic Departures Junction, Terminal-3, IGI Airport, New Delhi-110037, building comprised to Two Tier Basement, Ground & 5 Upper Floors only & restaurant is running at 2<sup>nd</sup> Floor only owned/occupied by HMShost Hospitality Services Bharath Private Limited, have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on 31-03-2021 in the presence of Sh. Yash Yadav (Liason Officer) and found that the building/premises is fit for the occupancy class "Assembly" (Group-D)/Eating House with effect from...16 / 06 / 2021 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 16 / 06 / 2021 at New Delhi.

(ATUL GARG)  
DIRECTOR

Copy to:-

1. Addl. Commissioner, Licensing Unit, 1<sup>st</sup> Floor, Police Station, Defence Colony, New Delhi-110024.
2. Authorized Signatory, M/s Heineken Bar, (HMShost Hospitality Services Bharath Private Limited) at Domestic Departures Junction, Terminal-3, IGI Airport, New Delhi-110037

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire Safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Any Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

## INSPECTION REPORT

Total covered area of the restaurant at the ground floor is 129 m<sup>2</sup> and as per NBC (Part-IV) the no. of occupants comes out to be Approx. 72 (129/1.8=71.66). Thus capacity of restaurant is 72 persons which is covered under DFS Act 2007, Rules 2010. Subsequently inspection of Eating House is carried out as per NBC (Part-IV).

1. Name & address of the building: **M/s Heineken Bar (HMShost Hospitality Services Bharath Private Limited), Domestic Departures Junction, Terminal-3, IGI Airport, New Delhi-110037.**
2. Type of Occupancy : **Assembly (Eating House on 2<sup>nd</sup> Floor only)**
3. Building comprised of : **Two Tier Basement, Ground & 5 Upper Floors only**
4. Type of Case : **New**
5. Details of previous NOC : **F6/DFS/MS/SZ/2020/537 dated 23/12/2020 (for Terminal-3 building)**
6. Fire Safety directives Letter No. : **Nil**
7. Date of inspection : **31/03/2021**
8. Name of the Inspecting Officer : **D.O. (S.D.) & A.D.O. (S.J.)**
9. Name and designation of Officer from the building side : **Sh. Yash Yadav (Liason Officer)**
10. Year of Construction : **2010**

11. Applicant's letter received through email ID-jaya.sachwani@hmshost.net date 16/03/2021

| S No | Minimum standards on fire prevention and fire safety U/R 33   | NFPA Requirements  | Provided at site                               | Remarks MR/NMR             |
|------|---|--|--|----------------------------|
| 1.   | Access of building(T-3 Building IGI Airport FSC No. F6/DFS/MS/SZ/2020/537 dated 23/12/2020)   |  |  |                            |
|      | <ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>  | Lounge is within T-3   | As Above                                       | MR                         |
| 2.   | Number, width, Type & Arrangements of exits<br>(Provided & maintained by T-3 Bldg. Management)  |  |  |                            |
|      | a. Number of staircases   |  |  |                            |
|      | <ul style="list-style-type: none"> <li>• Upper floors</li> <li>• Basements</li> </ul>   | Lounge is within T-3<br>NA   | 3<br>NA  | MR<br>NA                   |
|      | b. Width of staircases  |  |  |                            |
|      | <ul style="list-style-type: none"> <li>• Upper floors</li> <li>• Basements</li> </ul>   | Lounge is within T-3<br>NA   | 1.5m (each)<br>NA                              | MR<br>NA                   |
|      | c. Protection of exits  |  |  |                            |
|      | <ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>   | Lounge is within T-3<br>Lounge is within T-3   | Provided<br>Provided                           | MR<br>MR                   |
|      | d. No of continuous staircase to terrace  | Lounge is within T-3   | Provided                                       | MR                         |
|      | e. Width Of Corridor  | Lounge is within T-3   | Provided                                       | MR                         |
|      | f. Door Size  | 1.10m x 2  | 2.00m & 1.50m                                  | MR                         |
| 3.   | Compartmentation  |  |  |                            |
|      | <ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul> | Lounge is within T-3<br>Lounge is within T-3<br>Lounge is within T-3<br>NA<br>Lounge is within T-3 | Provided<br>1.5m<br>Provided<br>NA<br>Provided | MR<br>MR<br>MR<br>NA<br>MR |
| 4.   | Smoke managements System<br>(Provided & maintained by T-3 Bldg. Management)   |  |  |                            |
|      | <ul style="list-style-type: none"> <li>• Basements</li> <li>• Ground Floor</li> </ul>   | 30 ACPH<br>12 ACPH   | AS Above<br>As Above                           | MR<br>MR                   |
| 5.   | Fire Extinguishers  |  |  |                            |
|      | <ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• ISI marking</li> </ul>   | 2<br>ABC/ WCO <sub>2</sub> /CO <sub>2</sub><br>ISI marked  | 3<br>34/28/24<br>Provided                      | M/R<br>M/R<br>M/R          |

|     |   |   |                |               |
|-----|---|---|----------------|---------------|
|     | • Total number of fire extinguishers on each floor  | 3   | Provided       | MR            |
|     | • Length of hose reel hose  | 30m   | 30m            | MR            |
|     | • Nozzle diameter   | 5mm   | 5mm            | MR            |
| 7.  | Automatic fire detection and alarming system(Provided & maintained by T-3 Bldg. Management) |   |                |               |
|     | • Type of detector  | Required  | Smoke & Heat   | MR            |
|     | • Location of Main Panel  | Required  | Upper Basement | MR (Old Case) |
|     | • Location of Repeater Panel  | Required  | Provided       | MR            |
|     | • Alternate source of power   | Required  | Provided       | MR            |
|     | • Hooters' Location   | Required  | At all floors  | MR            |
| 8.  | MOEFA   | Required  | Provided       | MR            |
| 9.  | Public Address System   | Required  | Provided       | MR            |
| 10. | Automatic Sprinkler System (Provided & maintained by T-3 Bldg. Management)                  |   |                |               |
|     | • Basement  | NA  | NA             | NA            |
|     | • Upper Floor   | Required  | Provided       | MR            |
|     | • Sprinkler above false ceiling   | Required  | Provided       | MR            |
| 11. | Internal Hydrants (Provided & maintained by T-3 Bldg. Management)                           |   |                |               |
|     | • Size of riser/down- comer   | 150 mm  | Provided       | MR            |
|     | • Number of hydrants per floor  | 3   | Provided       | MR            |
|     | • Hose Box  | 3   | Provided       | MR            |
| 12. | Yard Hydrants (Provided & maintained by T-3 Bldg. Management)                               |   |                |               |
|     | • Total number of hydrants  | Lounge is within T-3                            | Provided       | MR            |
|     | • Hose Box  | Lounge is within T-3                            | Provided       | MR            |
| 13. | Pumping Arrangements (Provided & maintained by T-3 Bldg. Management)                        |   |                |               |
|     | • Ground Level  |   |                |               |
|     | ➤ Discharge of main pump  | Lounge is within T-3                            | Provided       | MR            |
|     | ➤ Head of main pump   | Lounge is within T-3                            | Provided       | MR            |
|     | ➤ Number of main pumps  | Lounge is within T-3                            | Provided       | MR            |
|     | ➤ Jockey pump out put   | Lounge is within T-3                            | Provided       | MR            |
|     | ➤ Jockey pump head  | Lounge is within T-3                            | Provided       | MR            |
|     | ➤ Standby Pump out put  | Lounge is within T-3                            | Provided       | MR            |
|     | ➤ Standby Pump Head   | Lounge is within T-3                            | Provided       | MR            |
|     | ➤ Auto Staring/Manual stopping  | Lounge is within T-3                            | Provided       | MR            |
|     | ➤ Pump House Access   | Lounge is within T-3                            | Provided       | MR            |
|     | • Terrace level   | (Provided & maintained by T-3 Bldg. Management) |                |               |
|     | ➤ Discharge of pump   | NA  | NA             | NA            |
|     | ➤ Head of the pump  | NA  | NA             | NA            |
|     | ➤ Power supply  | NA  | NA             | NA            |
|     | ➤ Auto starting of pump   | NA  | NA             | NA            |
| 14. | Captive water Storage for fire fighting (Provided & maintained by T-3 Bldg. Management)     |   |                |               |
|     | • Underground tank capacity   | Lounge is within T-3                            | Provided       | MR            |
|     | ➤ Draw of connection  | Lounge is within T-3                            | Provided       | MR            |
|     | ➤ Fire service inlet  | Lounge is within T-3                            | Provided       | MR            |
|     | ➤ Access to tank  | Lounge is within T-3                            | Provided       | MR            |
|     | • Overhead Tank capacity  | Lounge is within T-3                            | Provided       | MR            |

N/3


|     |  |   |          |    |
|-----|--|---|----------|----|
| 15  | Exit Signage   | Required  | Provided | MR |
| 16. | Provision of Lifts   | (Provided & maintained by T-3 Bldg. Management) |          |    |
|     | ➤ Pressurization of Lift Shaft   | Lounge is within T-3                            | Provided | MR |
|     | ➤ Pressurization of lift lobby   | Lounge is within T-3                            | Provided | MR |
|     | ➤ Communication in lift Car  | Lounge is within T-3                            | Provided | MR |
|     | ➤ Fireman's Grounding Switch   | Lounge is within T-3                            | Provided | MR |
|     | ➤ Lift Signage   | Lounge is within T-3                            | Provided | MR |
| 17. | Standby power supply   | Required  | Provided | MR |
| 18. | Refuge Area  | (Provided & maintained by T-3 Bldg. Management) |          |    |
|     | ➤ Total area   | Lounge is within T-3                            | Provided | MR |
|     | ➤ Location   | Lounge is within T-3                            | Provided | MR |
| 19. | Fire control room  | (Provided & maintained by T-3 Bldg. Management) |          |    |
|     | ➤ Detector system panel  | Required  | Provided | MR |
|     | ➤ Flow Switch Panel  | Required  | Provided | MR |
|     | ➤ PA System Panel  | Required  | Provided | MR |
|     | ➤ Battery backup   | Required  | Provided | MR |
|     | ➤ Building Floor Plans   | Required  | Provided | MR |
| 20. | Special Fire Protection Systems for Protection of special Risks, if any; | Lounge is within T-3                            | Provided | MR |

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. MCB and Conduit Metal Wiring have also been provided.

Keeping in view of the substantial compliance of the minimum standards of fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer  
 Name : S.K. Dua  
 Designation : D.O. (S.D.)

Signature of the Inspecting Officer  
 Name : A.K. Jaiswal  
 Designation : A.D.O. (S.J.)

DeFO (S2) 

C.F.O.



