

C/26

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No. F.6/DFS/MS/ MN/School/2021/ 390

Dated: 16/06/2021

**FIRE SAFETY CERTIFICATE**

Certified that the **Sanatam Dharam Public School**, located at East Punjabi Bagh Road no. 10, New Delhi-110026 comprised Ground plus Two upper floors owned/ occupied by Sanatan Dharam public School has already issued FSC by this department vide letter No. F.6/DFS/MS/School/WZ/2018/374 dated 07/03/2018. The premises was re-inspected by officer concern of this department on 06/04/2021 in the presence of Sh. Umesh Kumar Chhikara (Principal) and observed that fire prevention and fire safety arrangements provide in the premises, found in good working condition. The premises have therefore, deemed complied with the fire prevention and fire safety requirements in accordance with the circular issued by Circular no. 262-263 dated 17/01/2005 and that the building/premises is fit for occupancy class "**Educational Building**" Group-B, as above with effect from ...16/06/2021... for a period of **Three years**, subject to the compliance of the conditions mentioned below.

Issued on 16/06/2021 at New Delhi by

  
(Dharampal Bhardwaj)  
Dy. Chief Fire Officer  
Delhi Fire Service

Copy to: -

1. The Principal, Sanatam Dharam Public School, located at East Punjabi Bagh Road no. 10, New Delhi-110026.
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

**Following fire safety directives must be adhered to:-**

1. All the fire safety arrangements provided therein shall be maintained in good
2. Working condition at all times.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The basement shall be used strictly as per building bye laws.
7. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

**INSPECTION REPORT**

1. Name & address of the building : Sanatan Dharam public School, East Punjabi Bagh, Road No. 10, New Delhi-110026.
2. Type of Occupancy : Educational(Ground + two upper Floors)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/SCHOOL/2018/WZ/374 dated 07/03/2018
5. Fire Safety directives letter No : N/A
6. Date of inspection : 06/04/2021
7. Name of the Inspecting Officers : Sarabjeet Singh, ADO (Moti Nagar)
8. Name and designation of officers from the building side : Sh. Umesh Kumar Chhikara (Principal)
9. Year of Construction : 1985 &1992
10. Applicant's letter No. : E-mail dated 01.03.2021

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	BBL /NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> </ul>	06 mts	Provided	MR
	<ul style="list-style-type: none"> <li>• Gate width</li> </ul>	4.5 mts	Provided	MR
	<ul style="list-style-type: none"> <li>• Width of internal road</li> </ul>	N/A	N/A	N/A
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	-	-	-
	<ul style="list-style-type: none"> <li>• Upper Floors</li> </ul>	02	04 provided	MR
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	N/A	N/A	N/A
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> </ul>	1.50 mts	1.40mts,1.45mts,1.00mts,1.10mts	MR(old case)
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	N/A	N/A	N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Pressurization</li> </ul>	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	N/A	N/A	N/A
	g. Width of Corridor	1.50 mts	2.40 mts Provided	MR
	h. Door Size	1.00 mts	1.00 mts provided	MR
3	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Sealing of electrical shafts</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Fire Rating of shaft door</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Water Curtain</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Fire Dampers</li> </ul>	N/A	N/A	N/A
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	30 a/c per hour	N/A	N/A
	<ul style="list-style-type: none"> <li>• Upper floors</li> </ul>	12 a/c per hour	N/A	N/A
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> </ul>	23	Provided	MR
	<ul style="list-style-type: none"> <li>• Types</li> </ul>	CO <sub>2</sub> , ABC type	Provided	MR
	<ul style="list-style-type: none"> <li>• IS marking</li> </ul>	ISI marked	Provided	MR

SP

निम्न हो तो कृपया लौटाएं :

	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	03	03 provided	MR
		30 mts	30 mts provided	MR
		05 mm	05 mm Provided	MR
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
8	<b>MOEFA</b>	N/A	N/A	N/A
9	<b>Public Address System.</b>	Required	Provided	MR
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	100 mm	Provided	MR
		03	Provided	MR
		03	Provided	MR
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	MR	MR	MR
		MR	MR	MR
13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>Ground Level <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/ Manual stopping</li> <li>Pump House Access</li> </ul> </li> <li>Terrace level <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		450Lpm&180Lpm	Provided	MR
		40 MH	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14	<b>Captive Water Storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity</li> <li>Draw-off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> <li>Overhead Tank capacity</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		5,000 ltrs	5,000 ltrs Provided	MR
15	<b>Exit Signage.</b>	Required	Provided	MR

16	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	<b>Standby power supply</b>			
18	<b>Refuge Area.</b>			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	<b>Fire Control Room</b>			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:			
		N/A	N/A	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no.F6/DFS/MS/SCHOOL/2018/WZ/374, Dated-07/03/2018 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended

96/ADO/MN  
15/04/2021

Received on  
19/04/2021

~~DO (west)~~

Where is form 'J' & 'K'  
19/4

~~DO (MN)~~

~~ADO (MN)~~

Sir, Form 'J' & 'K' duly filled & attached on opposite side.

~~DO (west)~~

10/04/2021

Signature of the Inspecting Officer  
15/04/2021

Name: Sarabjeet Singh  
Designation: ADOMN)

23/04/2021