

420

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, NEW DELHI**


No: F.6/DFS/MS/MN/School/2021/393

Dated: 18/06/2021

FIRE SAFETY CERTIFICATE

Certified that the building of Maharishi Dayanand Public School, Block -- 9, Arya Samaj Bhawan, Ramesh Nagar, New Delhi comprised of ground plus one upper floor, owned and occupied by Maharishi Dayanand Public School was issued FSC vide letter No. F6/DFS/MS/school/2018//WZ/858 dated 27/04/2018. The premises was inspected by the officer concerned of this department on 07/04/2021 in the presence of Sh. Narender Arya (Manager) and observed that all the fire prevention & Fire Safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with the fire prevention & fire requirements in accordance F.16/Estate/CC/Fire Safety 2011/3298 - 3398 dated 01.03.2011 and the premises is fit for occupancy class "Educational" Group B with effect from18/06/2021 for a period of three years, subject to compliance of the condition mentioned above.

Issued on18/06/2021.....at New Delhi by.


(Dharampal Bhardwaj)
DY.Chief Fire Officer,
Delhi Fire Service.

Copy to:-

1. The Principal, Maharishi Dayanand Public School, Block -- 9, Arya Samaj Bhawan, Ramesh Nagar, New Delhi
2. Director of Education, North Delhi Municipal Corporation, Dr. S.P.M Civic Centre, Minto Road, New Delhi-110002.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building : Maharishi Dayanand Public School Located at, Arya Samaj mandir, Ramesh Nagar New Delhi-110015.
2. Type of Occupancy : Educational 2 Blocks (Ground + 1 Upper Floor)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/WZ/858 dated 21/04/2018
5. Fire Safety directives Letter No. : DOE 3298-3398 dated 1-3-11
6. Date of inspection : 07/04/2021
7. Name of the Inspecting Officer : Sarabjeet Singh, ADO (MN)
8. Name and designation of Officer from the building side : Sh. Narender Arya (Manager)
9. Year of Construction : 1985
10. Applicant's letter No. : Email Dated - 05/04/2021

The Said School is running at Ground plus one upper floor in a building comprised of Ground plus one upper floor.

S No	Minimum standards on fire prevention and fire safety U/R 33	Circular No. 262-362 dated 17/01/2005	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	Provided	MR
	• Gate width	Accessible	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5 m	100cm,102cm	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	1	Provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1m	1m	MR
	g. Hall	2X1.5 m	2X1.97 m,1X1.16 m	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA

SP

14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage	NA	NA	NA
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010

DO (West)

Sarabjeet Singh
26/05/2021
Sarabjeet Singh
ADO (MN)

DCFD (W2)
06/5/2021
19/5/2021

ADP (M.N)
Sir, R.T is put up for your personal & sig. pls.
Dy. CTD (W2)
14/06/2021