

C-63

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001


No. F.6/DFS/MS/EH/SZ/2021/ 118

Dated 24/06/2021

FIRE SAFETY CERTIFICATE

Certified that **M/s China Garden Takashi Terrace Bar and Café** (A Unit of Four Seasons Cuisine India Pvt Ltd) located at **ground and three upper floors** of M-73, M-Block Market, Greater Kailash-II, New Delhi 110048 in the building comprised of Basement, Ground Plus Three Upper Floors was issued Fire Safety Certificate by this department vide letter no. F.6/DFS/MS/EH/2017/ SZ/1104 dated 26/07/2017 in the name of **M/s China Garden Restaurant**. The restaurant premise was re-inspected by the officer concerned of this department on 21/06/2021 in the presence of Mr. Harish Kumar (Manager) of the restaurant and found that the said premise have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy **Class D "Assembly Building"** for ground & 03 upper floor only as above with effect from 24/06/2021 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 24 / 06 /2021 at New Delhi by


(Sunil Chawdhary)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service

Copy to: -

1. The Dy. Health Officer, Public Health Department, South Zone, Green Park, Delhi.
2. M/s China Garden Takashi Terrace Bar and Café (A Unit of Four Seasons Cuisine India Pvt Ltd) M-73, M-Block Market, Greater Kailash-II, New Delhi 110048

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

2	Type of Occupancy	Group-D Assembly Building.	
3	Building Comprised of	Basement, Ground + Three upper floors	
4	Type of Case	Renewal	
5	Details of Previous NOC	F.6/DFS/MS/EH/2017/ SZ/1104 dated 26/07/2017	
6	Fire Safety Directives Letter No	Nil	
7	Date of Inspection	21/06/2021	
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)	
9	Name & Designation of Officers from the building side	Mr. Harish Kumar (Manager)	
10	Year of construction	2006-07	Restt. at ground + 3rd floor of the bldg.
11	Applicant letter No.	Online No. 20201010125550 dated 04/01/2021	

S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Required	09 mtr Provided	MR
		N/A	Directly accessible	N/A
		N/A	N/A	N/A
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	Required	Two nos	MR
	➤ Basement floor.	Required	Two nos	N/A
	b) Width of Staircase			
	➤ Upper floors	Required	1.25 & 1.10 mtr	MR (old case)
	➤ Basement floor	Required	1.25 & 1.10 mtr	MR (old case)
	c) Protection of exits			
	➤ Fire check door	N/A	N/A	N/A
	➤ Pressurization	N/A	N/A	N/A
	d) No. of continuous staircase to terrace	Required	One	MR
	e) Width of corridor	N/A	1.50 m	N/A
	f) Door size	Required	1.50 m	MR (old case)
3	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door. Sealing of electrical shafts. Fire rating of shaft door. Water curtain Fire dampers. 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4	Smoke Management system.			
	<ul style="list-style-type: none"> Basement Upper floors 	30 ACPH	N/A	N/A
		12 ACPH	Provided	MR
5	Fire Extinguishers.			
	<ul style="list-style-type: none"> Total numbers Types ISI Marking 		20 Nos	MR
		ABC/CO ₂	ABC-16 & CO ₂ -04	MR
		ISI marked	Provided	MR
6	First Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor. Length of hose-reel hose. Nozzle Diameter 	One at each	Provided	MR
		30m	Provided	MR
		5mm	Provided	MR
7	Automatic fire detection & alarming system.			

	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	Required	Smoke & Heat	MR
		N/A	Ground floor	N/A
		N/A	N/A	N/A
		Required	Each floor	M/R
		Required	Provided	M/R
8	MOEFA	Required	Provided	MR
9	Public Address System	N/A	N/A	N/A
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement 	Required	Provided	M/R
	<ul style="list-style-type: none"> Ground floor & above floor 	Required	Provided	M/R
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	N/A	N/A	N/A
11	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer 	Required	100 mm	M/R
	<ul style="list-style-type: none"> Number of Hydrant per floor 	Required	01	M/R
	<ul style="list-style-type: none"> Hose box. 	Required	01	M/R
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Hose box. 	N/A	N/A	N/A
13	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> ➤ Discharge of main pump. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Head of main pump. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Number of main pumps. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Jockey Pump output. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Jockey Pump head. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Standby Pump output. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Standby Pump head. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Auto Starting/Manual Stopping. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Pump house access. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Terrace Level 			
	<ul style="list-style-type: none"> ➤ Discharge of pump. 	900 LPM	900 & 180 LPM	MR
	<ul style="list-style-type: none"> ➤ Head of pump. 	40 m	Provided	MR
	<ul style="list-style-type: none"> ➤ Power supply. 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Auto starting of pump. 	NA	Provided	NA
14	Captive water storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Draw-off connection. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Fire Service Inlet. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Access to tank. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Overhead tank capacity. 	5,000 Ltrs	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Pressurization of lift lobby. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Communication in lift car. 	Required	Provided	MR
	<ul style="list-style-type: none"> Fireman's switch. 	Required	Provided	MR
	<ul style="list-style-type: none"> Lift signage. 	Required	Provided	MR
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area			
	<ul style="list-style-type: none"> Total area 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Location 	N/A	N/A	N/A

19	Fire Control Room.			
	<ul style="list-style-type: none"> • Detector system panel. • Flow switch panel. • PA system panel. • Battery backup. • Building floor plan. 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20	Special Fire Protection System for the Protection of special Risk, if any.	N/A	N/A	N/A

The Fire protection systems provided in the premises were test checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F.6/DFS/MS/EH/2017/ SZ/1104 dated 26/07/2017, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

11/4
22/16

Signature of the Inspecting Officer

Name: Sh. Rajesh Kumar

Designation: ADO (BCP)

DO (SD) - on leave

Sh. Rajesh Kumar
[Signature]

M.S. [Signature]

F.T. please.

ADO/BCP

As approved, F.T. letter is put up for your signature P1

Sh. Rajesh Kumar
[Signature]

11/4
22/16

[Signature]
M.S. [Signature]