

C62

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE**  
**NEW DELHI**

No. F6/DFS/MS/School/WZ/2021/ 394

Dated: 23/06/2021


**FIRE SAFETY CERTIFICATE**

Certified that the **Prudence School (A Unit of Jindal Charitable Society)** Located at **PS-2, C-3 Block, Ashok Vihar, Phase-II, Delhi-110052**, comprised of 03 Blocks (**BL-A=G + 3UF**), (**BL-B= B+G+3UF**) & (**BL-C=B+Stilt+G+3 Upper Floors**) was issued FSC by this department vide Letter No. **F6/MS/DFS/School/2018/WZ/1214 Dated 24.5.2018**. The said premises was re-inspected by the officer concerned of this department on 16.6.2021 in the presence of Ms. Rachna Babbar (Vice Principal) & Sh. Karan Singh (Representative) and found that the premises have deemed complied with the fire prevention and fire safety requirement an accordance with rule 33 of the Delhi Fire Services Rules 2010 & that the premises is fit for occupancy class "Educational" Group B with effect from 23/06/2021 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on ...23/06/2021... at New Delhi by.



(Dharampal Bhardwaj)  
Dy. Chief Fire Officer  
(West Zone)

  
23/06/2021

Copy to: -

1. The Director, Directorate of Education Old Secretariat Delhi – 110054.
2. The Secretary ( Jindal Cheritable Society), Prudence School, PS-2, C-3 Block, Ashok Vihar, Phase-II, Delhi-110052

## CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time. It should not bolted /locked.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any loss of life any property due to the non-functional of any fire safety measures, management shall be held responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.
9. The basement shall be used as per BBL.

Ado S.P. Bhandari (Samvit)

ALL S  
436, 37, 38, 39  
संख्या-1, नारायण-01 301



Society) Located at PS-2, C-3 block, Ashok vihar Ph-II, Delhi - 110052.

2. Type of Occupancy : Educational 03 Blocks (BL-A=G+ 3UF)(BL-B= B+G+3UF ) & ( BL-C=B+Stilt+G+3 Upper Floor Only )
3. Type of Case : Renewal
4. Details of previous NOC : F6/MS/DFS/School/2018/WZ/1214 Dated 24.5.2018
5. Fire Safety directives Letter No. : Old Case
6. Date of inspection : 16.06.2021
7. Name of the Inspecting Officer : S.P. Bhardwaj, ADO (WP)
8. Name and designation of Officer  
from the building side : Ms. Rachna Babbar (Vice Principal) & Sh. Karan Singh (Representative)
9. Year of Construction : 2004-05
10. Applicant's letter No. : email dated 11.06.2021

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC Requirement/letter dated 24.05.2018	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	6 mtr 5.0 mtr NA	09mtr 5mtrs NA	MR MR NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases <ul style="list-style-type: none"> <li>• Upper floors</li> <li>• Basements</li> </ul>	BL-A=2 BL-B=2 BL-C=2 BL-B&C=2 each	BL-A=2 BL-B=2 BL-C=2 BL-B=2 BL-C=2	MR MR
	b. Width of staircases <ul style="list-style-type: none"> <li>• Upper floors</li> <li>• Basements</li> </ul>	1.5mtrs each 1.5m&1m Each block	A-BL=1x128cm&1x145cm B- BL=2x125cm C- BL=2x148cm BL-B=2x144cm BL-C=2x150cm	MR Old case) MR (Old Case)
	c. Protection of exits <ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	NA NA	NA NA	NA NA
	d. No of continuous staircase to terrace	1	Provided	MR
	e. Width Of Corridor	1.5 mtr	Provided	MR
	f. Door Size	1.0 mtr	110 cm Provided	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	30 NA	Exhaust fans NA	MR NA



	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	ABC & CO <sub>2</sub> ISI marked	Provided Provided	MR MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	Required 30m 5mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper Floor</li> <li>• Sprinkler above false ceiling</li> </ul>	NA NA NA	NA NA NA	NA NA NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> <li>• Size of riser/down- comer</li> <li>• Number of hydrants per floor</li> <li>• Hose Box</li> </ul>	4 inch dia Required Required	Provided Provided Provided	MR MR MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> <li>• Hose Box</li> </ul>	2 Required	Provided Provided	MR MR
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> <li>• Ground Level</li> <li>• Discharge of main pump</li> <li>➤ Head of main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Staring/Manual stopping</li> <li>➤ Pump House Access</li> <li>• Terrace level</li> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power supply</li> <li>➤ Auto starting of pump</li> </ul>	NA NA NA NA NA NA NA NA NA NA 900 lpm&180 lpm 50M Required Required	NA NA NA NA NA NA NA NA NA NA Provided Provided Provided Provided	NA NA NA NA NA NA NA NA NA NA MR MR MR MR
14.	Captive water Storage for firefighting:			
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	Old Case NA NA NA BL-A & B=10,000 ltrs. BL-C=30000 ltrs	150000 lts. Provided Provided Provided Provided	MR NA NA NA MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	<ul style="list-style-type: none"> <li>➤ Pressurization of Lift Shaft</li> <li>➤ Pressurization of lift lobby</li> <li>➤ Communication in lift Car</li> </ul>	NA NA NA	NA NA NA	NA NA NA



2/11

	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety requirements under the rules renewal of Fire Safety Certificate issued vide letter no. F6/MS/DFS/School/2018/WZ/1214 Dated 24.5.2018 under rules 37 of the Delhi Fire Service Rules 2010 under the DFS Act 2007 is recommended.

S. P. Bhardwaj, ADO (WP)

*[Signature]* 17/6/21

~~D.O/West~~

D.O. (WEST)/135  
DATED. 17/06/21

*[Signature]*  
17/06/2021

~~Defo (WZ)~~

*[Signature]*  
22/6/2021

~~ADO w/z FT~~

FT is put up for *[Signature]*

~~Defo/WZ~~

*[Signature]*  
23/6/2021

*[Signature]*  
22/6/21

~~w/z cell~~