

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No. F6/DFS/MS/NDZ/2021/ 270

Dated:.../.../2021
22 06

FIRE SAFETY CERTIFICATE

Certified that the **State Bank Of India Building** located at **11 Sansad Marg, New Delhi**, comprising of A- block (G+ Mezzanine and four upper floor), B- block (ground and first floor), C- block (basement , ground and eight upper floor) and D-block (basement, ground and 13th upper floor) owned/occupied by SBI was granted NOC by this department vide letter No. F6/DFS/MS/91/901 dated 21.05.91. The premises was re-inspected by the officer concerned of this department on 14/06/21 in the presence of Sh. P.K. Gupta CM (P&E) and Sh. Geetam Singh , fire officer and found that the block -D has deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises (**block -D except basement**) is fit for occupancy class **Business Building**, with effect from 22/06/2021 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 22/06/2021 at New Delhi by.


(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

1. The Chief Architect, NDMC , Palika Kendra , New Delhi
2. Sh. Y.P Matta, AGM (P & I) , SBI , 11 Sansad Marg, New Delhi.

Condition for the validity of fire safety certificate

1. This FSC is valid only for D- block except basement.
2. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
3. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".

N/18

INSPECTION REPORT

1.	Name & address of the building	State Bank Of India ,11 Sansad Marg, New Delhi
2.	Type of occupancy: -	Business occupancy – Block -D comprised of combined basement beneath block C & D, Ground and thirteen upper floors.
3	Type of case: -	Renewal
4	Details of previous FSC: -	F6/DFS/MS/91/901 dated 21.05.91
5	Fire safety directives No.-	N/A
6	Date of inspection: -	14.06.2021
7	Name of the inspecting officer: -	Sh. Ravinder Singh (ADO/CC) Sh. Rajinder Atwal , DO (CD)
8	Name & designation of officer From the building side (joint Inspection)	Sh. P.K Gupta CM (P& E) Sh. Geetam Singh, Fire Officer
9	Year of construction:-	1973
10	Applicant's letter No:-	Agmpre.ihodel@sbi.co.in dated 26.03.21

SBI Building having four block naming A(Mezzanine and four upper floor) ,B (Ground and first floor),C(Basement ,ground and eight floor) and D (basement, ground and thirteen upper floor).

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement/ Existing fire safety arrangements	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	09 meter <i>Cl</i>	Provided	MR
	2) Gate width	N/A	N/A	N/A
	3)Width of internal road	Accessible	Front side accessible	MR
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02 Nos.	02 Nos	MR
	2. Basements	02 Nos.& ramp	02Nos & ramp	MR
	B. Width of staircase			
	1. Upper floors	1.20 mtr .	1.20 mtr .	MR
	2. Basements	1.20 mtr .	1.20mtr .	MR
	C. Protection of exits			
	1. Fire check door	N/A	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	N/A	N/A	N/A
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	N/A	N/A	N/A
3.	Compartmentation			
	1) Fire check door	Required	Provided	MR
	2) Sealing of electrical shafts	Required	Provided	MR
	3) Fire rating of shaft door	Required	Provided	MR
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			

	1) Basements	12 ACPH	Mechanical	MR
	2) Upper floors	12 ACPH	Natural	MR
5.	Fire Extinguishers			
	1) Total numbers	60nos	Provided	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number at each floor	01	Provided	MR
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR
	3) Nozzle diameter	05 mm	05 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors smoke type	Required	Provided	MR
	2) Location of main panel	Required at gr. floor	Provided	MR
	3) Location of repeater panel	Required	Provided	MR
	4) Alternate source of power	Required	Provided	MR
	5) Hooter's Location	Required at each floor	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	Required	Provided	MR
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	100 mm	100 mm	MR
	2) Number of hydrants per floor	01	Provided	MR
	3) Hose box	01	Provided	MR
12.	Yard Hydrants			
	1) Total number of hydrants	04 nos	Provided	MR
	2) Hose box	04 nos	Provided	MR
13.	Pumping Arrangement			
	1) Ground level			
	a) Discharge of main pump	2280 LPM	2280 LPM	MR
	b) Head of main pump	100 meter	100 meter	MR
	c) Number of main pump	01 nos	01 nos	MR
	d) Jockey pump out put	180 LPM	180 LPM	MR
	e) Jockey pump head	100 meter	100 meter	MR
	f) Stand by pump output	2280 LPM	2280 LPM	MR
	g) Stand by pump head	100 meter	100 meter	MR
	h) Auto starting/Manual stopping	Required	Provided	MR
	2) Terrace level	Required	Provided	MR
	a) Discharge of pump	450LPM	450LPM	MR
	b) Head of pump	40m	40m	40m
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Underground tank capacity	50,000 liter	50,000 liter	MR
	a) Draw-off connection	Required	Provided	MR
	b) Fire service inlet	Required	Provided	MR

N/120

	c) Access to tank	Required	Provided	MR
	d) Overhead tank capacity	20,000 ltr.	20,000 ltr.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	Required	Provided	MR
	d) Fireman's switch	Required	Provided	MR
	e) Lift signage	Required	Provided	MR
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	Provided	N/A
	a) Detector system panel	N/A	Provided	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	Required	Provided	MR
	d) Battery backup	Required	Provided	MR
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any: ABC & CO²			Provided

The fire protection systems provided in the building were randomly tested, checked and found functional of block -D except basement at the time of inspection.

Further, Block A, B & C has not complied of shortcomings issued vide letter No F6/DFS/ADO/CC/831 dated 22.07.2019 in toto due pandemic situation and requested to give 60 days' time to complete the entire work as retrofitting and renovation work is under process (letter enclosed at C-118).

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures in D- block as required under the rules, if agreed, we may renew the FSC issued vide letter no. F6/DFS/MS/91/901 dated 21.05.91 for D-block only except basement, under rule 35 of the Delhi Fire Service rules 2010. Accordingly, DFA is prepared and put up for kind perusal and signature please.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Rajinder Atwal
 Name :- Rajinder Atwal
 Designation :- DO (CD)

Ravinder Singh
 Name :- Ravinder Singh
 Designation :- ADO (CC)

Dy. CFO (msz)

OK Somur
 17/6/21

RFO (H.Dw)

Depo

18/6
17/6/21



वर्तमान हो तो कृपया लौटाएं :