

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

No. F.6/DFS/MS/BNQT/SZ/2021/

274

Dated: 23/06/2021

FIRE SAFETY CERTIFICATE

Certified that **M/s Ten** (A Unit of JPS Catering Pvt. Ltd.) B-10, DDA Community Centre, Triveni Complex, Saikh Sarai, New Delhi-110016 comprised of Lower Ground Floor, Ground Floor plus two upper floors has Banquet Hall at Lower Ground Floor was issued fire safety certificate by this department vide letter no. F6/DFS/MS/BANQUET/2018/SZ/805 dated 24/04/2018. The Banquet Hall was re-inspected by the officer concerned of this department on 18/06/2021 in the presence of Ms. Nisha Verma and found that the said premise have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy **Class D "Assembly Building"** (Banquet Hall) with effect from 23/06/2021 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 23/06/2021 at New Delhi by



(Sunil Chawdhary)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service

Copy to: -

1. The Dy. Health Officer, Public Health Department, South Zone, Green Park, Delhi 110016
2. **M/s Ten** (A Unit of JPS Catering Pvt. Ltd.) B-10, DDA Community Centre, Triveni Complex, Saikh Sarai, New Delhi-110016

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

INSPECTION REPORT

1	Name & Address of the Building	M/s Ten (A Unit of JPS Catering Pvt. Ltd.) B-10, DDA Community Centre, Triveni Complex, Saikh Sarai, New Delhi-110016		
2	Type of Occupancy	Assembly 'Group-D' (Banquet Hall)		
3	Building comprised of	Lower Ground floor, Ground Plus Two Upper Floors, Banquet hall is at Lower Ground Floor.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/BANQUET/2018/SZ/805 dated 24/04/2018		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	18/06/2021		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Ms. Nisha Verma		
10	Year of construction	2013		
11	Applicant letter No.	MHA Portal ID 20210409172113 dated 09/04/2021		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	06 mtr	09 m	MR
	• Gate width	Required	3 mtr	MR
	• Width of internal road	NA	N/A	N/A
2	Number, width, type & arrangement of exits			
	a. Number of Staircase			
	• Upper floors	N/A	N/A	N/A
	• Basement floor	-NA-	N/A	N/A
	b. Width of Staircase			
	• Upper floors	-NA-	N/A	N/A
	• Basement floor	-NA-	N/A	N/A
	c. Protection of exits			
	• Fire check door	-NA-	N/A	N/A
	• Pressurization	-NA-	N/A	N/A
	d. No. of continuous staircase to terrace	-NA-	N/A	N/A
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	2 mtr	Provided total 05 no of exits having width of 2.5 m, 1.37 m, 1.37 m, 0.88 & 0.88 mtr	MR
3	Compartmentation.			
	• Fire check door.	-NA-	N/A	N/A
	• Sealing of electrical shafts.	-NA-	N/A	N/A
	• Fire rating of shaft door.	-NA-	N/A	N/A
	• Water curtain	-NA-	N/A	N/A
	• Fire dampers.	-NA-	N/A	N/A
4	Smoke Management system.			
	• Basement	30 a/c per hour	Exhaust Fans	MR
	• Upper floors	-NA-	N/A	N/A
5	Fire Extinguishers.			
	• Total numbers		06 No's	MR
	• Types	ABC / CO2	ABC & Co2	MR
	• ISI Marking	ISI marked	Provided	MR
6	First Aid Hose Reels.			
	• Total numbers on each floor.	Required 01 Nos	02 Nos Provided	MR
	• Length of hose-reel hose.	30m	Provided	MR
	• Nozzle Diameter	5mm	Provided	MR
7	Automatic fire detection & alarming system.			

	• Type of detectors	-NA-	-NA-	-NA-
	• Location of Main Panel	-NA-	-NA-	-NA-
	• Location of Repeater Panel	-NA-	-NA-	-NA-
	• Alternate source of power	-NA-	-NA-	-NA-
	• Hooper's location	-NA-	-NA-	-NA-

8	MOEFA	Required	Provided	MR
9	Public Address System	Required	Provided	MR
10	Automatic Sprinkler System			
	• Basement / Lower ground floor	Required	Provided	MR
	• Upper floors	-NA-	-NA-	-NA-
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
11	Internal Hydrants.			
	• Size of Riser/Down-comer	-NA-	-NA-	-NA-
	• Number of Hydrant per floor	-NA-	-NA-	-NA-
	• Hose box.	-NA-	-NA-	-NA-
12	Yard Hydrants.			
	• Total number of hydrants.	-NA-	02 Nos provided	MR
	• Hose box.	-NA-	Provided	MR
13	Pumping arrangements.			
	• Ground Level			
	➤ Discharge of main pump.	-NA-	-NA-	-NA-
	➤ Head of main pump.	-NA-	-NA-	-NA-
	➤ Number of main pumps.	-NA-	-NA-	-NA-
	➤ Jockey Pump output.	-NA-	-NA-	-NA-
	➤ Jockey Pump head.	-NA-	-NA-	-NA-
	➤ Standby Pump output.	-NA-	-NA-	-NA-
	➤ Standby Pump head.	-NA-	-NA-	-NA-
	➤ Auto Starting / Manual Stopping.	-NA-	-NA-	-NA-
	➤ Pump House Access	-NA-	-NA-	-NA-
	• Terrace Level			
	➤ Discharge of pump.	450 LPM	900 & 180 LPM	MR
	➤ Head of pump.	40 mtr	46 m	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14	Captive water storage for Fire Fighting.			
	• Underground tank capacity.	-NA-	-NA-	-NA-
	➤ Draw-off connection.	-NA-	-NA-	-NA-
	➤ Fire Service Inlet.	-NA-	-NA-	-NA-
	➤ Access to tank.	-NA-	-NA-	-NA-
	• Overhead tank capacity.	5,000 Ltrs	10,000 Ltrs	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of lift shaft.	-NA-	-NA-	-NA-
	• Pressurization of lift lobby.	-NA-	-NA-	-NA-
	• Communication in lift car.	-NA-	-NA-	-NA-
	• Fireman's switch.	-NA-	-NA-	-NA-
	• Lift signage.	-NA-	-NA-	-NA-
17	Standby Power Supply	Required	Provided (DG Set)	MR
18	Refuge Area			
	• Total area	-NA-	-NA-	-NA-

	• Location	-NA-	-NA-	-NA-
19	Fire Control Room.			
	• Detector System Panel.	-NA-	-NA-	-NA-
	• Flow Switch Panel.	-NA-	-NA-	-NA-
	• PA system Panel.	-NA-	-NA-	-NA-
	• Battery backup	-NA-	-NA-	-NA-
	• Building floor plan	-NA-	-NA-	-NA-
20	Special Fire Protection System for the Protection of special Risk, if any :	-NA-	-NA-	-NA-

The Fire protection systems provided in the premises were test checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/BANQUET/2018/SZ/805 dated 24/04/2018 renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

[Handwritten Signature]
22/06/2021

Signature of the Inspecting Officer
Name: Rajesh Kumar
Designation: ADO (BCP)

DO/SO - on leave

DO/CS2 F.T. please.

[Handwritten Signature]

~~ADO/BCP~~

As approved, F.T. letter is put up for your signature pl

[Handwritten Signature]
23/6

DO/CS2 *[Handwritten Signature]*

MS. 1011