

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F.6/DFS/MS/School/2021/NDZ/ 408

Dated: 28/6/21

FIRE SAFETY CERTIFICATE

Certified that R. A. Geeta Co-Ed Sr. Sec. School at Shankar Nagar, Delhi-110051, comprised of ground plus one upper floor owned/occupied by R. A. Geeta Co-Ed Sr. Sec. School was issued FSC vide letter No. F.6/DFS/MS/School/2018/NDZ/1084 dated 16/05/2018. The school building have complied with the fire prevention and fire safety requirements in accordance with the circular No-F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated-01/03/11 issued by the Director of Education and verified by the officer concerned of this department on dated 16/06/2021 in the presence of Sh. Yashpal Singh, Principal of the school and found that the school building is fit for occupancy class "B" 'Educational Building' for ground plus one floor with effect from 28/6/21 for a period of **three** years, in accordance and further subject with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 & also conditions printed overleaf..

Issued on 28/6/21 at New Delhi by

  
25/6/21

(Dr. S. K. Tomar)  
Dy. Chief Fire Officer



To,  
The Principal,  
R. A. Geeta Co-ED Sr. Sec. School,  
Shankar Nagar, Delhi-110051

Copy:-  
The Dy. Director of Education,  
B- Block, Yamuna Vihar,  
Delhi-110053

## CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry

### INSPECTION REPORT

1. Name & address of the building : R. A. Geeta Co-Ed, Sr. Sec. School, Shankar Nagar, Delhi- 110051
2. Building is comprised of : Ground plus one upper floor
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC letter : F.6/DFS/MS/School/2018/NDZ/1084 dated- 16/05/2018
6. Fire Safety direction letter No. : F16/Estate/CC/Fire Safety/2011/3298 to 3398 dated- 01/03/11
7. Date of Inspection : 16/06/2021
8. Name of the Inspecting officers : ADO Nagender Singh
9. Name and designation of Officer from the building side : Sh. Yashpal Singh, Principal
10. Year of Construction : 1977 & 2010
11. Applicant's email ID : rageetaschool@gmail.com dated- 01/04/2021

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	Circular Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	<p style="text-align: center;">6 m</p> <p style="text-align: center;">N/A</p> <p style="text-align: center;">N/A</p>	<p style="text-align: center;">08 m</p> <p style="text-align: center;">N/A</p> <p style="text-align: center;">N/A</p>	<p style="text-align: center;">MR</p> <p style="text-align: center;">N/A</p> <p style="text-align: center;">N/A</p>
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	<ul style="list-style-type: none"> <li>• Upper floor</li> <li>• Basement</li> </ul>	<p style="text-align: center;">2 nos.</p> <p style="text-align: center;">N/A</p>	<p style="text-align: center;">3 nos.</p> <p style="text-align: center;">N/A</p>	<p style="text-align: center;">MR</p> <p style="text-align: center;">N/A</p>
	B. Width of Staircases			
	<ul style="list-style-type: none"> <li>• Upper floor</li> <li>• Basement</li> </ul>	<p style="text-align: center;">1.5 m / .75m</p> <p style="text-align: center;">N/A</p>	<p style="text-align: center;">1.5 m, 1.5 m &amp; 1.05 m</p> <p style="text-align: center;">N/A</p>	<p style="text-align: center;">MR</p> <p style="text-align: center;">N/A</p>
	c. Protection of Exits.			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	<p style="text-align: center;">N/A</p> <p style="text-align: center;">N/A</p>	<p style="text-align: center;">N/A</p> <p style="text-align: center;">N/A</p>	<p style="text-align: center;">N/A</p> <p style="text-align: center;">N/A</p>
	d. No. of Continuous Staircases to Terrace	2 nos.	2 nos.	MR
	e. Width of Corridor	1.50 m	1.50 m	MR
	f. Door Size	1 m	1 m	MR
03	Compartmentation.			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire rating of shaft door</li> <li>• Water curtain</li> <li>• Fire dampers</li> </ul>	<p style="text-align: center;">N/A</p> <p style="text-align: center;">N/A</p> <p style="text-align: center;">N/A</p> <p style="text-align: center;">N/A</p> <p style="text-align: center;">N/A</p>	<p style="text-align: center;">N/A</p> <p style="text-align: center;">N/A</p> <p style="text-align: center;">N/A</p> <p style="text-align: center;">N/A</p> <p style="text-align: center;">N/A</p>	<p style="text-align: center;">N/A</p> <p style="text-align: center;">N/A</p> <p style="text-align: center;">N/A</p> <p style="text-align: center;">N/A</p> <p style="text-align: center;">N/A</p>
04	Smoke Management System.			
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper floor</li> </ul>	<p style="text-align: center;">N/A</p> <p style="text-align: center;">N/A</p>	<p style="text-align: center;">N/A</p> <p style="text-align: center;">N/A</p>	<p style="text-align: center;">N/A</p> <p style="text-align: center;">N/A</p>
05.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	<p style="text-align: center;">7 nos.</p> <p style="text-align: center;">ABC/CO<sub>2</sub></p> <p style="text-align: center;">ISI marked</p>	<p style="text-align: center;">10 nos.</p> <p style="text-align: center;">ABC/ CO<sub>2</sub></p> <p style="text-align: center;">ISI marked</p>	<p style="text-align: center;">MR</p> <p style="text-align: center;">MR</p> <p style="text-align: center;">MR</p>

N/III

06	First-Aid-Hose Reels.			
	Total numbers on each floor	N/A	N/A	N/A
	• Length of hose reel hose	N/A	N/A	N/A
	• Nozzle diameter	N/A		N/A
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter	N/A	N/A	N/A
08	MOEFA	N/A	N/A	N/A
09	Public Address System.	N/A	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	• Head of main pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump head	N/A	N/A	N/A
	• Auto starting /manual stopping	N/A	N/A	N/A
	• Pump house access	N/A	N/A	N/A
	➤ Terrace Level			
	• Discharge of pump	N/A	N/A	N/A
	• Head of the pump	N/A	N/A	N/A
	• Power supply	N/A	N/A	N/A
	• Auto starting of pump	N/A	N/A	N/A
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	N/A	N/A	N/A
	• Overhead tank capacity	N/A	N/A	N/A
15	Exit Signage.			
		N/A	N/A	N/A

16	Provision of Lifts.			
	<ul style="list-style-type: none"> <li>• Pressurization of lift shaft</li> <li>• Pressurization of lift lobby</li> <li>• Communication in lift car</li> <li>• Firemen's grounding switch</li> <li>• Lift signage</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	Standby Power Supply	N/A	N/A	N/A
18	Refuge Area.			
	<ul style="list-style-type: none"> <li>• Total area</li> <li>• Location</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> <li>• Detector system panel</li> <li>• Flow switch panel</li> <li>• PA system panel</li> <li>• Battery backup</li> <li>• Building floor plans</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if Any:	N/A	N/A	N/A

The Fire protection systems provided in the building were Tested/Checked and found functional, at the time of inspection.

Keeping in view of the compliance of the minimum standards of fire prevention and fire safety measures required as per circular No.F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated-01/03/11 issued by Director of Education, it is recommended to renew FSC under rule 37 of the Delhi Fire Service Rules, 2010.

*(Signature)*  
 (Nagender Singh)  
 ADO (Shahdara)

Dy. CEO (NDZ) *F.S. Pl.*

*(Signature)*  
 17/6/21



*(Signature)*  
 ADO (Shahdara)

*FT is placed for signatures please*

*(Signature)*  
 Dy. CEO (NDZ)

*(Signature)*  
 25/6/21

*(Signature)*  
 23/6

*(Signature)*  
 M.S. Cell