

C-26

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001

No.F6/DFS/MS/EH/NDZ/2021/ 120

Dated:-28/6/2021

FIRE SAFETY CERTIFICATE

Certified that the **M/S DIGGIN CAFÉ** located at **A-12, First floor, Connaught Place, New Delhi**, building is **comprised** of basement, ground & first floor. Earlier, the fire safety certificate (FSC) was granted by this department vide letter No. F6/DFS/MS/EH/2018/480 dated 22/03/2018 to Rodeo restaurant at first floor. The premises was re-inspected by the officers concerned of this department on dated 21.06.21 in presence of Col A.S. Bedi and found that the said premises, has deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 that the premises, is fit for occupancy class **Assembly Building Group-D (Restaurant on 1st floor only)** with effect from - ~~22/03/2018~~ 28/6/21 for period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on28/6/21..... at New Delhi by.


25/6/21

(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Officer

Copy to:-

1. The Jt. Commissioner of police (Licensing)
1st Floor, Police Station Defence Colony, New Delhi Online ID no. 2021031511289 dated 02.04.21
2. The Executive Engineer (Bldg.), NDMC, Palika Kendra, New Delhi.
3. The Manager, M/S DIGGIN CAFÉ located at A-12, First floor, Connaught Place, New Delhi.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
9. Any flammable material for interior decoration is prohibited.

2/12
INSPECTION REPORT

1. Name & address of the building DIGGIN CAFÉ (Baba Shri Chand magic Enterprises India Pvt Ltd) at A-12 first floor, Connaught Place New Delhi.
2. Type of occupancy:- Assembly Building Group-D, building is B + Gr. + 01 Upper floors, but Restaurant is running at 1st floor.
3. Type of case:- Renewal (New Name) *the*
4. Details of previous FSC:- F6/DFS/MS/2018/EH/480 dated 22/03/2018.
5. Fire safety directives No.- N/A
6. Date of inspection:- 21/06/21
7. Name of the inspecting officer:- Sh. Rajinder Atwal (DO/CD) & Sh. Ravinder Singh (ADO/CC)
8. Name & designation of officer from the building side:- Col. A.S Bedi
9. Year of construction:- Old
10. Applicant's letter No:- ID No 2021031511289 dated 02.04.21

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement/ Existing fire safety arrangements	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	09 mtr.	12 mtr.	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02	02	MR
	2. Basements	01	01	MR
	B. Width of staircase			
	1. Upper floors	1.25 & .90 mtr.	1.25 & 0.90 to 1.17 mtr.	MR(old case)
	2. Basements	0.90 mtr.	0.90 mtr.	MR(old case)
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	01	01	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	1.0 mtr.	1.0 mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 ACPH	N/A	N/A
	2) Upper floors	12 a/c per hr.	Natural	MR

N/14

		hour		
5.	Fire Extinguishers			
	1) Total numbers	04 Nos.	04 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number at first floor	01	Provided	MR
	2) Length of hose reel hose	30 mtr.	Provided	MR
	3) Nozzle diameter	05 mm	Provided	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	Required	Provided	MR
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A

13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 & 180 LPM	Provided	MR
	b) Head of pump	40 mtr.	Provided	MR
	c) Power supply	Required	Provided	MR


covered please return to :

	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	Required	Provided	MR
	d) Over head tank capacity	5000 ltr.	5000 ltr.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area			
	Total area location	N/A	N/A	N/A
19.	Fire Control Room			
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			NA

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.


Keeping in view of the compliance of minimum standards of fire prevention and fire safety measures as required under the rules, if agreed, the FSC issued vide letter No. F6/DFS/MS/EH/2018/480 dated 22/03/2018, renewal under Rule 35 of the Delhi Fire Service rules 2010, is recommended for approval.

Signature of the Inspecting Officer


 24/6/21

Name :- Rajinder Atwal
Designation :- DO (CD)


Signature of the Inspecting Officer

 24/6/21

Name :- Ravinder Singh
Designation :- ADO (CC)



F.I. P.I.

 24/6/21

