

C-26

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE**

**NEW DELHI- 110001**

No.F6/DFS/MS/School/2021/SZ/ 410

Dated: 28/06/21


**FIRE SAFETY CERTIFICATE**

Certified that the **New Delhi Public School**, A-Block, Vikaspuri, New Delhi-110018, comprised of ground floor plus three upper floors, owned/occupied by New Delhi Public School was issued FSC by this department vide letter no. F6/DFS/MS/School/2018/SZ/1400 dated 14/06/2018. The School building was re-inspected by the officer concerned of this department on 16/06/2021 in the presence of Sh. Naresh Sharma (Manager) and found that School building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on..... 28/06/21..... at New Delhi.



(Sunil Chawdhary)  
Dy. Chief Fire Officer  
Delhi Fire Service



Copy to:-

1. The Principal,  
New Delhi Public School,  
A-Block, Vikaspuri, New Delhi-110018.
2. Director of Education,  
GNCT of NCT of Delhi, Old Secretariat,  
New Delhi-110054.

N/S

**INSPECTION REPORT**

1. Name & address of the building : New Delhi Public School, A-Block, Vikaspuri, New Delhi-18.
2. Building is comprised of : **Ground plus three upper Floors**
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/school/2018/SZ/1400 Dt.- 14/06/2018
6. Fire Safety direction letter No : Nil
7. Date of Inspection : 15/06/2021
8. Name of the Inspecting Officers: : ADO R.K. YADAV
9. Name of the designation of Officer  
from the building side : Sh. Naresh Sharma (Manager )
10. Year of Construction : 2003-2004
11. Applicant's letter No : Nil Dated 09/06/2021

S.No	Minimum Standards on fire prevention and fire safety requirements U/R 33	Requirement	Provided at Site	Remarks MR/NMR	
1	<b>Access to building</b>				
	Road width	6 m	06 m	MR	
	Gate width	4.5 mtrs.	4.5 mtrs.	MR	
	Width of internal road	N.A.	N.A.	N.A.	
2	<b>Number, Width, Type and Arrangement of Exits</b>				
	a. Number of Staircases	Upper Floor	03 no.	03 no.	MR
		Basement	N.A.	N.A.	N.A.
	B. Width of Staircases	Upper Floor	N.A.	N.A.	N.A.
		Basement	1.50 m	1.60,1.60 &1.70 m	MR
	c. Protection of exits	Fire check door	N.A.	N.A.	N.A.
		Pressurization	N.A.	N.A.	N.A.
	e. No. of continuous staircases to terrace	01 no.	01 no.	MR	
	g. Width of Corridor	1.50 m	2.15 & 2.10 m	MR	
	h. Door Size	1.0 m	1.12 m	MR	
	3	<b>Compartmentation.</b>			
		Fire check door	N.A.	N.A.	N.A.
Sealing of electrical shafts		N.A.	N.A.	N.A.	
Fire rating of shaft door		N.A.	N.A.	N.A.	
Water curtain		N.A.	N.A.	N.A.	
Fire Dampers		N.A.	N.A.	N.A.	
4	<b>Smoke Management System.</b>				
	Basement	N.A.	N.A.	N.A.	
	Upper floor	Required	Natural Ventilation	MR	


N/12

<b>5.</b>	<b>Fire Extinguisher</b>			
	Total numbers	16 Nos.	16 Nos.	MR
	types	CO <sub>2</sub> & ABC	CO <sub>2</sub> & ABC	MR
	IS marking	ISI marked	ISI marked	MR
<b>6</b>	<b>First-aid-Hose Reels.</b>			
	Total numbers of each floor	01 Nos.	Provided	MR
	Length of hose reel hose	30 m	30 m	MR
	Nozzle diameter	05 mm	05 mm	MR
<b>7</b>	<b>Automatic fire detection and alarming system.</b>			
	Type of detectors	N.A.	N.A.	N.A.
	Location of main panel	N.A.	N.A.	N.A.
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	N.A.	N.A.	N.A.
	Hooters	N.A.	N.A.	N.A.
<b>8</b>	<b>MOEFA</b>	N.A.	N.A.	N.A.
<b>9</b>	<b>Public address System.</b>	N.A.	N.A.	N.A.
<b>10</b>	<b>Automatic Sprinkler System.</b>			
	basement	N.A.	N.A.	N.A.
	upper floor	N.A.	N.A.	N.A.
	sprinkler above false ceiling	N.A.	N.A.	N.A.
<b>11</b>	<b>Internal Hydrants</b>			
	size of riser/down-comer	100 mm	Provided	MR
	Number of hydrants per floor	01Nos.	Provided	MR
	Hose Box	01Nos.	Provided	MR
<b>12</b>	<b>Yard Hydrants.</b>			
	Total number of hydrants	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
<b>13</b>	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>● Ground Level</li> <li>➤ Discharge of main Pump</li> <li>➤ Head of Main Pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby pump out put</li> <li>➤ Standby pump Head</li> <li>➤ Auto Starting /Manual stopping</li> <li>➤ Pump House Access</li> </ul>	N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
	<ul style="list-style-type: none"> <li>● Terrace Level</li> <li>➤ Discharge of pump</li> <li>➤ Head of the Pump</li> <li>➤ Power supply</li> <li>➤ Auto Starting of pump</li> </ul>	450 & 180 LPM	450 & 180 LPM	MR
		40 m	40 m	MR
		Required	Provided	MR
		Required	Provided	MR


<b>14</b>	<b>Captive Water Storage for Fire Fighting.</b>			
	Underground tank capacity	N.A.	50,000 ltrs	MR
	Draw-off connection	N.A.	N.A.	N.A.
	Fire service inlet	N.A.	Two way	N.A.
	Access to tank	N.A.	N.A.	N.A.
	Overhead Tank capacity	10,000 ltrs	30,000 ltrs	MR
<b>15</b>	<b>Exit Signage.</b>			
	Required	Required	Provided	MR
<b>16</b>	<b>Provision of Lifts.</b>			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.
<b>17</b>	<b>Standby power supply</b>			
	Required	Required	Provided	MR
<b>18</b>	<b>Refuge Area.</b>			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
<b>19</b>	<b>Fire Control Room</b>			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
<b>20</b>	<b>Special Fire Protection systems for protection of special Risks, if any:</b>			
	Required	Required	Provided	MR


The fire protection systems provided in the building were test checked and found functional at the time of inspection.


In view of the deemed compliance of the minimum standards on fire prevention and fire prevention and Fire safety measures as required under the rules the FSC issued vide letter no. F.6/DFS/MS/school/2018/SZ/1400 Dt.- 14/06/2018 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

  
 Signature of the Inspecting Officer  
 Name R K YADAV  
 Designation ADO (JKP)

DO(South West)

  
 26/06/2021  
 Dy C/S (S)

F.T. placed.  


  
 ADO (JKP)

F.T Letter is put up for signature Meas