

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No. F6/DFS/MS/School/2021/NDZ/322

Dated: 01/07/2021

To,

The Manager,
Dev Public School,
Street No. 4, East Rohtas Nagar,
Shahdara, Delhi-110032

Subject:-Issuing of Fire Safety Certificate.

Sir,


With reference to your email ID devpublicschool2011@gmail.com dated 17/03/2021 on the subject cited above, it is informed that the shortcomings communicated vide letter No. F.6/MS/DFS/08/2136 dated 25/07/2008, vide letter No. F6/DFS/MS/School/2018/NDZ/4274 dated 10/10/2018 & vide letter No. F6/DFS/MS/School/2020/NDZ/07 dated 01/01/2020 have not been complied yet (The copy of the same is enclosed for reference).

In view of the above Fire Safety Certificate cannot be considered at this stage. Therefore, you are once again requested to rectify the said shortcomings under intimation to this office for further consideration in the matter.

Yours Faithfully,


30/6/21

(Dr. S. K. Tomar)
Dy. Chief Fire Officer



cl6

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/School/2018/NDZ / 4274

Dated: 10/10/18

To,

The Manager,
M/s Dev Public School,
Street No.-4, East Rohtas Nagar,
Shahdara, Delhi- 110032.

Sub: - Regarding issuance of Fire Safety Certificate for M/s Dev Public School at Street No.-4, East Rohtas Nagar, Shahdara, Delhi-110032.

Madam,

Please refer your letter no. Nil dated 07/08/2018, on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out inspection on 18/09/18 in presence of Sh. Aadesh Kumar Sharma, Manager of the school. During the Inspection it was observed that the shortcomings as communicated earlier vide letter no. F6/MS/DFS/08/2136 dated 25/07/2008 is yet to be rectified. Copy of the same is enclosed for your ready reference.

Yours faithfully


(Vipin Kental)
Chief Fire Officer
Delhi Fire Service

o/c
OR

To,

Manager
Dev Public School
Street No.4, East Rohtas Nagar,
Shahdara, Delhi -32.

Sub: Issuing of NOC for Dev Public School at Street No.4, East Rohtas Nagar,
Shahdara, Delhi -32

Sir,

Please refer to your letter dt.30.06.08 on the subject cited above. In this regard, it is to inform you that the officer concerned with respect to the circular no.262-362 dated 17.01.2005 (issued by the Director of Education), carried out the inspection of the above said premises from fire safety angle. The school building is comprised of, ground plus three upper floors is not accessible for fire vehicle. At the time of inspection Mr. Sanjay Kumar was present. During the inspection the following points/shortcomings were observed-

1. ISI marked fire extinguishers of various capacities, CO2 type ABC Type were not provided.
2. Down comer system with proper landing valves, hose boxes with proper delivery hoses and branch pipe at each level was not provided.
3. First aid hose reels at each level were not provided.
4. Overhead tank of 5000 lts. on terrace connected with fire Pump Cap.450 lpm with 40 mtrs head and Jockey pump cap.180 lpm with 40 mtrs head was not provided.
5. Manual alarm was not provided.
6. Alternative means of escape i.e second staircase was not provided.

In view of above observations the NOC/fire clearance for the school building can not be considered in the interest of the student/occupant's safety, at this stage. The authority concerned are suggested to comply with all the fire safety recommendations as circulated/issued by the Director of Education as per above said circular, under the intimation to this department for further course of action.

Yours faithfully


Dy. CHIEF FIRE OFFICE
DELHI FIRE SERVICE

Copy to :-

Director of Education
GNTC of Delhi, Room No.212- A,
Old Secretariat, Delhi

