

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F.6/DFS/MS/2021/CNG/ 290

Dated: 29/06/2021

FIRE SAFETY CERTIFICATE

Certified that the CNG Dispensing station located at Madanpur Khadar, New Delhi, comprised of Single Story building owned/Occupied by Indraprastha Gas Limited was issued Fire Service Certificate by this department vide letter No. F6/DFS/MS/CNG/2018/SZ/1114 Dated 16.05.2018. The premises was re-inspected by the officer concerned of this department on 17/06/2021 in the presence of Sh. Gautam Pathak (Manager) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "Hazardous" (CNG Pump) as above with effect from the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 of Delhi Fire Service Rules, 2010 and subject to compliance of the conditions mentioned below .

Issued on 29/06/2021 at New Delhi by.

**(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER (S.Z.).**

Copy to :-

1. Sh. Alok Sharma, Chief General Manager (Fire & Safety), IGL Bhawan, Plot No.4, Community Centre, RK Puram, Sector- 9, New Delhi-110022.
2. The Addl. Comm. of Police (Lic.), First floor, P.S. Defence Colony, New Delhi-110049.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc. shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".

2/17

INSPECTION REPORT

1. Name & address of the building : CNG Dispensing station, Madanpur khadar, New Delhi
2. Building is comprised of : Ground floor only.
3. Type of Occupancy : Hazardous "Ground- J"
4. Type of Case : Renewal
5. Details of Previous NOC : F6/DFS/MS/CNG/2018/SZ/1114 Dated 16.05.2018.
6. Fire Safety direction letter No : F.5 (3A)/DFS/CNG/2000/111 Dated 29-03-2000
7. Date of Inspection : 17/06/2021
8. Name of the Inspecting Officers: : A.D.O. (S.J.)
9. Name and designation of Officer from the building side : Sh. Gautam Pathak
10. Year of Construction : 2001-01
11. Applicant's letter received through email ID-ajay.khatri@igl.co.in dated 08/06/2021

S.No	Minimum Standards on fire prevention and fire safety as per old NOC.	Old NOC Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 m	Provided	MR
	Gate width	N.A.	N.A.	N.A.
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	Upper Floor	N.A.	N.A.	N.A.
	Basement	N.A.	N.A.	N.A.
	B. Width of Staircases			
	Upper Floor	N.A.	N.A.	N.A.
	Basement	N.A.	N.A.	N.A.
	c. Protection of exits			
	Fire check door	N.A.	N.A.	N.A.
	Pressurization	N.A.	N.A.	N.A.
	e. No. of continuous staircases to terrace	N.A.	N.A.	N.A.
	g. Width of Corridor	N.A.	N.A.	N.A.
	h. Door Size	N.A.	N.A.	N.A.
3	Compartmentation			
	Fire check door	N.A.	N.A.	N.A.
	Sealing of electrical shafts	N.A.	N.A.	N.A.
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	Basement	N.A.	N.A.	N.A.
	Upper floor	N.A.	N.A.	N.A.

(Signature)

5.	Fire Extinguisher			
	Total numbers	Required	44 Nos	MR
	Types	CO ₂ & ,DCP	DCP (75kg) – 13, DCP (9kg)-21, CO2 (4.5kg)-6, Co2 (45kg)-4	MR
	IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	N.A.	N.A.	N.A.
	Length of hose reel hose	N.A.	N.A.	N.A.
	Nozzle diameter	N.A.	N.A.	N.A.
7	Automatic fire detection and alarming system in compressor and in filling area.			
	Type of detectors	Gas & Flame	Provided in compressor	MR
		Required	Ground floor	MR
	Location of main panel	N.A.	N.A.	N.A.
	Location of repeater panel	Required	Provided	MR
	Alternate source of power	Required	Technician room	MR
	Hooters			
8	MOEFA	N.A.	N.A.	N.A.
9	Public address System.	N.A.	N.A.	N.A.
10	Automatic Sprinkler System.			
	Basement	N.A.	N.A.	N.A.
	upper floor	N.A.	N.A.	N.A.
	sprinkler above false ceiling	N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of riser/down-comer	N.A.	N.A.	N.A.
	Number of hydrants per floor	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
12	Yard Hydrants.			
	Total number of hydrants	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
13	Pumping Arrangements.			
	➤ Ground Level	N.A.	N.A.	N.A.
	➤ Discharge of main Pump	N.A.	N.A.	N.A.
	➤ Head of Main Pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting /Manual stopping	N.A.	N.A.	N.A.
	➤ Pump House Access	N.A.	N.A.	N.A.
	➤ Terrace Level	N.A.	N.A.	N.A.
	➤ Discharge of pump	N.A.	N.A.	N.A.
	➤ Head of the Pump	N.A.	N.A.	N.A.
	➤ Power supply	N.A.	N.A.	N.A.
	➤ Auto Starting of pump	N.A.	N.A.	N.A.

2/19

14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N.A.	N.A.	N.A.
	Draw-off connection	N.A.	N.A.	N.A.
	Fire service inlet	N.A.	N.A.	N.A.
	Access to tank	N.A.	N.A.	N.A.
	Overhead Tank capacity	N.A.	N.A.	N.A.
15	No Smoking Signage.(Hindi & English)	Required	Provided in Hindi And English	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.
17	Standby power supply	N.A.	Provided DG	N.A.
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for protection of special Risks, if any:	Required	Co ₂ flooding system connected through detectors provided in each compressor unit.	MR

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/CNG/2018/SZ/1114 Dated 16.05.2018. renewal under rule 37 of the Delhi Fire Service rules 2010 is recommended.

DO(SD) on CL

Dy CFO(SZ)

F.T. please -

[Signature]
22/6

A DO(SJ)
Dy. CFO(SZ)

F.T. is put up for signature pl.

Signature of the Inspecting Officer
Name : Ashok Kumar Jaiswal
Designation : A.D.O. (S.J.)

[Signature]
22/06/2021

[Signature]
23/06/2021

तल्ल हो तो कृपया लौटार् :