

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No.F6/DFS/MS/CNG/2021/NDZI/ 292

Dated: 30/06/2021

FIRE SAFETY CERTIFICATE

Certified that the CNG Dispensing station at Dilshad Garden, Delhi -110095, comprised of ground floor only, owned/occupied by Indraprastha Gas Limited was issued NOC vide letter No. F6/DFS/MS/CNG/2015/573 dated 21/04/2015. The CNG station was re-inspected by the officer concerned of this department in the presence of Mr. Kaustubh Panwar, Area Manager and found that the CNG Station have deemed fit for occupancy CNG Station for ground floor with effect from 30/06/2021 for a period of **three** years, subject to conditions, printed overleaf.

Issued on 30/06/2021 at New Delhi by


30/6/21

(Dr. Sanjay Tomar)
Dy. Chief Fire Officer



To,
The General Manager (Fire & safety)
IGL Bhawan,
Plot No. 04, Community Center,
R.K. Puram Sec. 09, New Delhi-110022

CONDITIONS

1. No trade susceptible to cause to CNG by generating heat, mechanical/electrical spark should be allowed within the licensed premises.
2. Overhead electrical cable and loose/naked wiring shall not be allowed across the licensed premises. The electrical equipment, electrical gadgets and fitting in the premises shall conform to hazardous area classification for the at purpose and be of a type approved by the CCE.
3. In premises "NO Smoking" signs board both Hindi and English shall be displayed in such a manner as to be easily readable by all people.
4. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
5. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
6. Noting contravention of the explosive Act. 1884 and rules their under 1983, and static and mobile pressure vessels (unfired) Rules 1981 as modified from time to time.
7. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
8. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
9. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
10. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

1. Name & address of the building : CNG Dispensing station at Dilshad Garden
Delhi by IGL
2. Building is comprised of : Ground floor
3. Type of Occupancy : CNG Storage & Dispensing Unit
4. Type of Case : Renewal
5. Details of Previous NOC letter : F6/DFS/MS/CNG/2015/573 dt-21/04/2015
6. Fire Safety directive letter No. : OISD-179
7. Date of Inspection : 14/06/2021
8. Name of the Inspecting officers : ADO Mehmood
9. Name and designation of Officer
from the building side : Mr. Kaustubh Panwar (Area Manager)
10. Year of Construction : 2005
11. Applicant's Letter No. : E-mail Dt.18/03/2021 & 07/06/2021

S.No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	As per Directives	Provided at Site	Remarks MR/NMR
01	Access to Building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	12 mtr. 4.5 mtr. N/A	15 mtr. 06 mtr. N/A	MR MR N/A
02	Number, width, Type and Arrangement of Exits			
	<ul style="list-style-type: none"> • Number of staircases • Width of staircases 	N/A N/A	N/A N/A	N/A N/A
03	Compartmentation	Required	Provided	MR
04	Smoke Management System.	Required	Provided	MR
05	Fire extinguishers			
	<ul style="list-style-type: none"> • DCP type 10 kg. • DCP type 75 kg. • CO2 type 4.5 kg • IS marking 	15 nos. 03 nos. 04 nos. ISI marked	29 nos. 11 nos. 04 nos. ISI marked	MR MR MR MR
06	First-Aid-Hose Reels			
	Total numbers on each floor	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Length of hose reels hose • Nozzle diameter 	N/A N/A	N/A N/A	N/A N/A
07	Automatic Fire Detection and Alarming System.			
	<ul style="list-style-type: none"> • Type of detectors • Location of main panel • Alternate source of power • Hooper's location 	Gas Required Required Required	Provided Provided Provided Provided	MR MR MR MR
08	MOEFA	N/A	N/A	N/A
09	Public Address System	N/A	N/A	N/A
10	Automatic Sprinkler System	N/A	N/A	N/A
11	Internal Hydrants	N/A	N/A	N/A
12	Yard Hydrants	N/A	N/A	N/A

13	Pumping Arrangements			
	• Terrace Level	N/A	N/A	N/A
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto Starting of pump	N/A	N/A	N/A
14	Captive Water Storage for Fire Fighting.	N/A	N/A	N/A
15	Exit Signage / No Smoking Signage	Required	Provided	MR
16	Provision of Lifts.	N/A	N/A	N/A
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area	N/A	N/A	N/A
19	Fire Control Room	N/A	N/A	N/A
20	Special Fire Protection System			
	• CO2, DCP local application	Required	Provided	MR
	• Hand held explosive meter	02 nos.	Provided	MR

The fire protection system provided in the CNG station were tested/checked and found functional at the time of inspection..

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety as per OISD-179, renewal of Fire Safety Certificate is recommended.

Mehmood
14/6/2024

Signature of the Inspection Officer
Name: - Mehmood
Designation- A.D.O (TP)

Received on - 24/6/24

DY.CFO (NDZ)

Mehmood
24/6/24

ADO (TP)

Sir

*A RT letter is being for
signature of you*

Dy CFO (NDZ)

Mehmood
30/6/24

Mehmood
24/6/2024

ADO (TP)

MSC 11



Please return to :