

C-49

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI


No.F6/DFS/MS/SZ/2021/ 421

Dated: 2/7/2021

**FIRE SAFETY CERTIFICATE**

Certified that the building St. Gregorios School, Located at, Sector-11, Dwarka, New Delhi-110075, comprised of Ground + 3 Upper floors owned / occupied by St. Gregorios School, was issued FSC vide Letter No. F6/DFS/MS/School/2017/SZ/301 Dated-03/03/2017. The premises was re inspected by the officers concerned of this department on 28/06/2021 in the presence of Sh. M. Boyaz (Principal) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education GNCT of Delhi circular No: 262 – 263 dated 17/01/2005 and that the premises is fit for occupancy class B “Educational building” with effect from 2/7/21 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 2/7/21..... at New Delhi by.

  
(Sunil Chaudhary)  
Dy. Chief Fire Officer  
Delhi Fire Service.

Copy to:

1. Sh. M. Boyaz (Principal) St. Gregorios School, Sector-11, Dwarka, New Delhi-110075
2. Directorate of Education Old Secretariat Delhi – 110054

**Following fire safety directives must be adhered to:-**

- 1 **The 4th Floor shall not be used for any purpose without getting FSC from this department.**
- 2 **The FSC shall be null & void if 4<sup>th</sup> floor is being used for any purpose.**
- 3 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 4 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 5 The trained staff should be available round the clock.
- 6 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 7 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 8 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
- 9 Basement shall be used strictly as per building bye laws.
- 10 The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

N/17

INSPECTION REPORT

1. Name & address of the building: St. Gregorios School, Located at, Sector-11, Dwarka, New Delhi-110075.
2. Type of Occupancy : Educational (Ground+ 03 Upper Floors)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2017/SZ/301 Dated- 03/03/2017
5. Fire Safety directives Letter No. : DOE Circular No. 262-263 Dated 17/01/2005 & F6/DFS/MS/BP/2018/117 Dated 25/04/2018
6. Date of inspection : 28-06-2021
7. Name of the Inspecting Officer :Udai vir Singh, ADO (DWK)
8. Name and designation of Officer  
from the building side :Sh. M. Boyaz (Principal)
9. Year of Construction : 2009
10. Applicant's letter No. : Email Dated 25/06/2021

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC Requirement As per N/7	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 mtrs	12 mtr	MR(Old Case)
	• Gate width	4.5mtrs	5.7 mtr	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors			
	• Basements	04 Nos.	04 Nos.	MR
	b. Width of staircases	NA	NA	NA
	• Upper floors			
	• Basements	1.5m	4x142cm	MR(Old case)
	c. Protection of exits	NA	NA	NA
	• Fire check door			
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
		02 Nos.	Provided	MR
	e. Width Of Corridor	1.5 mtr	1.42 mtr	MR
	f. Door Size	1 mtr	01 mtr	MR(Old Case)
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA



N/18

4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	12 a/c per hour	Natural ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	15 Nos.	15 Nos.	MR
	• Types	ABC & CO <sub>2</sub>	ABC & CO <sub>2</sub>	MR
	• IS marking	ISI marked	ISI marked	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	02	02	MR
	• Length of hose reel hose	30m	30m	MR
	• Nozzle diameter	5mm	5mm	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	100 mm	100 mm	MR
	• Number of hydrants per floor	02	02	MR
	• Hose Box	02	02	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 & 180LPM	450 & 180LPM	MR
	➤ Head of the pump	40Mtr	40Mtr	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR

N/19

14.	Captive water Storage for fire fighting:			
	• Underground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	Provided	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	5,000Ltr	5,000Ltr	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	D.G Set	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	CO2 fire extinguisher provided near electric panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/School/2017/SZ/301 Dated-03/03/2017 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

**Note :- Earlier the school building was comprised of Ground + 03 Upper Floors but now one more has been added. The FSC is recommended for renewal for Ground + 03 Upper Floors only.**

Signature of the Inspecting Officer  
 Name *Uday Vir Singh*  
 Designation *DO/SU*

*DO/SU*  
 29/06/2021  
 By *cto (S2)*

Dr. F.T. letter is put-up for your kind perusal and