

C-33

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**


No. F.6/DFS/MS/EH/2021/SZ/ 123

Dated: 1/7 /2021

FIRE SAFETY CERTIFICATE

Certified that the Eating House in the name & style of **Ms Dramz Whisky Bar and Lounge Private Limited**, at **ground & two upper floors** in the building comprised of **Basement (Sealed With Brick Wall)**, ground and two upper floors at premise located at 1580, Ward No 1, Kalka Das Marg, Mehrauli, New Delhi 110030, have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Delhi Fire Service on 25/06/2021 in the presence of Sh. Harjinder Singh / Manager and that the premises is fit for occupancy class "**Group-D Assembly**" (Restaurant for Ground & Two upper floors) with effect from the date of issue of this certificate for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 1/7 /2021 at New Delhi by


(Atul Garg)
Director

Copy to: -

1. The Dy. Health Officer, SDMC, Public Health Department, Green Park, Aurobindo Marg, New Delhi - 110016. (Ref. ID No 2021061213797 dated 12-06-2021)
2. The Joint Commissioner of Police (Lic.), 1st Floor, P.S. Defence Colony, New Delhi-110049
3. Ms Dramz Whisky Bar & Lounge Pvt. Ltd, at 1580, Ward No 1, Kalka Das Marg, Mehrauli, New Delhi 110030

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire-fighting system.
4. The owner/occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

INSPECTION REPORT

1	Name & Address of the Building	Ms Dramz Whisky Bar & Lounge Pvt. Ltd, at 1580, Ward No 1, Kalka Das Marg, Mehrauli, New Delhi 110030		
2	Type of Occupancy	Assembly 'Group-D' Ground plus 02 upper floors		
3	Building comprised of	Basement, (Sealed with brick wall) Ground plus 02 upper floors (Height 9.50m)		
4	Type of Case	New		
5	Details of Previous NOC	Nil		
6	Fire Safety Directives Letter No	UBBL 2016/ NBC Part IV		
7	Date of Inspection	25/06/2021		
8	Name of the Inspecting Officers	DO (South) & ADO (BCP)		
9	Name & Designation of Officers from the building side	Sh. Harjinder Singh / Manager		
10	Year of construction/ date of conversion	2010/2013		
11	Applicant letter No.	Online Id 2021061213797 dated 12-06-2021		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	UBBL/ NBC Requirement	Provided at Site	Remarks
1	Access to Building.			
	• Road width	06m	12m ✓	MR
	• Gate width	NA	NA	-NA-
	• Width of internal road	NA	NA	-NA-
2	Number, width, type & arrangement of exits			
	m. Number of Staircase			
	• Upper floors	2 Nos	03 nos	MR
	• Basement floor	-NA-	01	-NA-
	n. Width of Staircase			
	• Upper floors	1.50 m each	2.0m & 1.50 m (Steel staircases) and 1.35m	MR
	• Basement floor	-NA-	NA	-NA-
	o. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	-NA-	NA	-NA-
	p. No. of continuous staircase to terrace	01	01	MR
	q. Width of corridor	N/A	N/A	N/A
	r. Door size	1.50m each	1.50m each	MR
3	Compartmentation.			
	• Fire check door.	Required	Provided at kitchen	MR
	• Sealing of electrical shafts.	N/A	N/A	N/A
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
4	Smoke Management system.			
	• Basement	30 ACPH	N/A	N/A
	• Upper floors	12 ACPH	Natural ventilation ✓	MR
5	Fire Extinguishers.			
	• Total numbers	06 Nos	08 Provided ✓	MR
	• Types	ABC / CO2	ABC & Co2	MR
	• ISI Marking	ISI marked	Provided	MR
6	First Aid Hose Reels.			
	• Total numbers on each floor.	One	Provided	MR
	• Length of hose-reel hose.	30m	Provided	MR
	• Nozzle Diameter	5mm	Provided	MR
7	Automatic fire detection & alarming system.			
	• Type of detectors	NA	Provided	NA

	<ul style="list-style-type: none"> Location of Main Panel Location of Repeater Panel Alternate source of power Hooper's location 	NA	Provided	NA
		N/A	NA	N/A
		N/A	NA	N/A
		N/A	NA	N/A
8	MOEFA	Required	Provided	MR
9	Public Address System	-NA-	Provided	-NA-
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Upper floors 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	N/A	N/A	N/A
11	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer 	Required	Provided	MR
	<ul style="list-style-type: none"> Number of Hydrant per floor 	Required	Provided	MR
	<ul style="list-style-type: none"> Hose box. 	Required	Provided	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Hose box. 	-NA-	-NA-	-NA-
13	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level 			
	➤ Discharge of main pump.	-NA-	-NA-	-NA-
	➤ Head of main pump.	-NA-	-NA-	-NA-
	➤ Number of main pumps.	-NA-	-NA-	-NA-
	➤ Jockey Pump output.	-NA-	-NA-	-NA-
	➤ Jockey Pump head.	-NA-	-NA-	-NA-
	➤ Standby Pump output.	-NA-	-NA-	-NA-
	➤ Standby Pump head.	-NA-	-NA-	-NA-
	➤ Auto Starting / Manual Stopping.	-NA-	-NA-	-NA-
	➤ Pump House Access	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Terrace Level 			
	➤ Discharge of pump.	450 LPM	900lpm	MR
	➤ Head of pump.	40m	Provided	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14	Captive water storage for Fire Fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. 	-NA-	-NA-	-NA-
	➤ Draw-off connection.	-NA-	-NA-	-NA-
	➤ Fire Service Inlet.	-NA-	-NA-	-NA-
	➤ Access to tank.	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Overhead tank capacity. 	20,000 Ltrs	20,000ltrs	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Pressurization of lift lobby. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Communication in lift car. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Fireman's switch. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Lift signage. 	-NA-	-NA-	-NA-
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area			
	<ul style="list-style-type: none"> Total area 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Location 	-NA-	-NA-	-NA-
19	Fire Control Room.			

	• Detector System Panel.	-NA-	-NA-	-NA-
	• Flow Switch Panel.	-NA-	-NA-	-NA-
	• PA system Panel.	-NA-	-NA-	-NA-
	• Battery backup	-NA-	-NA-	-NA-
	• Building floor plan	-NA-	-NA-	-NA-
20	Special Fire Protection System for the Protection of special Risk, if any :	-NA-	-NA-	-NA-
			-NA-	-NA-

The Fire protection systems provided in the building were test checked at random and found functional at the time of inspection

Keeping in view of the substantially satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, it is recommended to grant Fire Safety Certificate under rule 35 (3) of the Delhi Fire Service Rules, 2010.

Accordingly DFA is put up for approval and signature please.

Sh. S. K. Dua
25/6/21

Signature of the Inspection Officer
Name: Sh. S. K Dua
Designation: DO (SD)

Rajesh Kumar
28/6

Signature of the Inspecting Officer
Name: Rajesh Kumar
Designation: ADO / BCP

DLFO (G2)
[Signature]
28/6

C.F.O. (D. off)

Director
[Signature]
29/06/2021 (Seal with
mark with)
Shud be im bald kely

ADO/DO
[Signature]

As approved, F.T. letter is put up
for your signature P1

Director
[Signature]
1/07/2021

[Signature]
30/06/2021