

c-45

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/GH/NDZ/2021/ 205

Dated:-7/7/2021

**FIRE SAFETY CERTIFICATE**

Certified that the **Blue Triangle Family Hostel, YWCA** located at **Ashok Road, New Delhi** comprised of Ground + 02 Upper floors, Ground floor (Reception + 01 hall + 01 staff room + 09 guest rooms), 1<sup>st</sup> floor (15 guest rooms + 03 stores + 01 office) and 2<sup>nd</sup> floor 15 guest rooms + 03 stores + 02 offices + 01 staff room), total 39 guest rooms was granted FSC by this department vide letter No.F6/DFS/MS/GH/NDZ/2018/467 dated 21/03/2018. The premises was re-inspected by the officers concerned of this department on 28/06/21 in the presence of Sh. Satish Kumar and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Residential Group A-1 Ground floor+1st floor to 2<sup>nd</sup> floor(09+15+15), total 39 guest rooms** with effect from 7/7/21 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued 7/7/21 at New Delhi by.



(Dr. S.K.Tomar)  
Dy. Chief Fire Officer  
Delhi Fire Service

Copy to:-

1. The Addl. Commissioner of Police (Lic), First Floor, P.S. Defence Colony New Delhi.  
Online mail id [btfhywcaofdelhi01@gmail.com](mailto:btfhywcaofdelhi01@gmail.com) dated 14/04/2021.
2. The Manager,  
Blue Triangle Family Hostel, YWCA at Ashok Road, New Delhi.

**Condition for the validity of fire safety certificate**

1. This FSC is only for Guest house excluding Auditorium.
2. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
3. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".

**INSPECTION REPORT** N/20

1. Name & address of the building : Blue Triangle Family Hostel, YWCA at Ashok Road, New Delhi
2. Type of occupancy : Residential Building- lower ground ( auditorium )  
Ground floor (Reception + 01 hall + 01 staff room + 09 guest rooms), 1<sup>st</sup> floor (15 guest rooms + 03 stores + 01 office) and 2<sup>nd</sup> floor 15 guest rooms + 03 stores + 02 offices + 01 staff room)
3. Type of case:- : Renewal
4. Details of previous FSC : F6/DFS/MS/GH/NDZ/2018/467 dated 21/03/2018
5. Fire safety directives No. : N/A
6. Date of inspection:- 28/06/21
7. Name of the inspecting officer : Sh. Ravinder Singh (ADO/CC)  
Sh. Rajinder Atwal ( DO/CD )
8. Name & designation of officer : Mr. Satish Kumar ( manager)
9. From the building side :- 2007
10. Year of construction :- 2007
11. Applicant's letter No. :- mail id [btfhwywcaofdelhi01@gmail.com](mailto:btfhwywcaofdelhi01@gmail.com) dated 14/04/2021.

Old Case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement existing fire safety arrangements	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	06 mtr.	18.5 mtr.	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02 No.	02 No.	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	1.20 mtr. Existing	1.20 mtr. each	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	NA	NA	NA
	D. No. of continuous staircase to terrace	01	01	MR
	E. Width of corridor	1.5 mtr.	1.70 mtr.	MR
	F. Door size	1 Mtr.	1 Mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 ACPH	N/A	N/A
	2) Upper floors	12 ACPH	Natural	MR
5.	Fire Extinguishers			
	1) Total numbers	16 Nos.	16 Nos.	MR
	2) Types	ABC & CO2	ABC, CO2 & W.CO2	MR
	3) ISI marking	Required	Provided	MR

9



N/M

6.	First-Aid Hose Reel			
	1) Total number of each floor	02 No.	02 No.	MR
	2) Length of hose reel hose	30 m	30 m	MR
	3) Nozzle diameter	5 mm	5 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	NA	NA	NA
	2) Upper floors	NA	NA	NA
	3) Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	1) Size of riser/down-comer	NA	NA	NA
	2) Number of hydrants per floor	NA	NA	NA
	3) Hose box each floor	NA	NA	NA
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level			
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump output	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	450 LPM	MR
	b) Head of pump	40 mtr.	40 mtr.	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	NA	NA	NA
	a) Draw-off connection	NA	NA	NA
	b) Fire service inlet	NA	NA	NA
	c) Access to tank	NA	NA	NA
	d) Over head tank capacity	3000 Ltrs.	3000 Ltrs.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A

N/22

	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	NA	NA	NA
	d) Fireman's switch	NA	NA	NA
	e) Lift signage	NA	NA	NA
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	NA	NA	NA
	Total area location	N/A	N/A	N/A
19.	Fire Control Room			
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	NA	NA	NA
	d) Battery backup	NA	NA	NA
	e) Building floor plan	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

Auditorium in lower ground is not checked as it is a run/manage by institutional management.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter no. F6/DFS/MS/GH/NDZ/2018/467 dated 21/03/2018, renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended.

Signature of the Inspecting Officer

*[Handwritten Signature]*  
1/7/21

Name: - Sh. Rajinder Atwal  
Designation: - DO (CD)

Signature of the Inspecting Officer

*[Handwritten Signature]*  
21/7/21

Name :- Sh. Ravinder Singh  
Designation : ADO (CC)

*[Handwritten Signatures and Dates]*  
Dy. Insp. (CDZ)  
A. Kumar 5/7/21  
AOC/DO F.T. M.  
AOC (CC) 5/7/21



As approved, fire part up for ICW team  
led and inspected.

*[Handwritten Signature]*  
5/7/21