

C-14

FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE
 [See sub-rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001


No.F.6/DFS/MS/School/2021/SZ/ 439

Dated: 6/7 /2021

FIRE SAFETY CERTIFICATE

Certified that the Govt. Girls Senior, Secondary School, No.-1 located at Molarband, Badarpur, New Delhi-110044 was earlier comprised of three blocks of Ground + 1 upper floors owned / Occupied by Director of Education have been issued Fire Safety Certificate vide letter No. F.6/DFS/MS/School/2018/SZ/865 dated 27/04/2018. The premises was re-inspected by the officer concerned of this department on 23.06.2021 in the presence of Smt. Madhu Kumari (Principal) and observed that now the school is comprised of two blocks of Ground + 1 upper floors and all the Fire prevention and Fire Safety arrangements provided in the premises found in good working condition. The premises have therefore, deemed complied with circular No. F6/Estate/CC/Fire/Safety/2011/3298-3398 dated 01/03/2011 and that the building / premises is fit for occupancy class "Educational" (Group-B) with effect from 6/7 /2021 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS Rules, 2010

Issued on 6/7 /2021 at New Delhi by



(SUNIL CHAWDHARY)

DY. CHIEF FIRE OFFICER (SZ)

plc

Copy to: -

1. The Principal, Govt. Girls Senior, Secondary School, No.-1 Molarband, Badarpur, New Delhi-110044.
2. The Director of Education, GNCT of Delhi, Old Secretariat, Delhi-110054

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape / entry / exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
3. Any loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of fire fighting system.
5. This Fire Safety Certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3. of UBBL-2016), if any.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.Delhigovt.nic.in.

1.	Name & address of the building	Govt. Girls Senior, Secondary School, No.-1 Molarband, Badarpur, New Delhi-110044.		
2.	Type of Occupancy	Educational		
3.	Building Comprised of	Two Blocks (A & B) are Ground & 1 st Floor		
4.	Type of Case	Renewal		
5.	Details of previous NOC	F.6/DFS/MS/School/2018/SZ/865 dated 27/04/2018		
6.	Fire Safety directives Letter No	DOE Cir. Dated 17/01/2005		
7.	Date of Inspection	23.06.2021		
8.	Name of the Inspecting Officer	ADO (SJ)		
9.	Name and Designation of Officer from the building side	Smt. Madhu Kumari (Principal)		
10.	Year of Construction	2014		
11.	Applicant's letter No.	Email dated 15/06/2021		
S. No	Minimum standards on fire prevention and fire safety U/R 33	DOE Cir. Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> Road width 	Required	6m	MR
	<ul style="list-style-type: none"> Gate width 	Required	4.5m	MR
	<ul style="list-style-type: none"> Width of internal road 	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper floors 	1	A-Block= 3 Nos. B-Block=2	MR
	<ul style="list-style-type: none"> Basements 	NA	NA	NA
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper floors 	1.50 m / 0.75m	A Blk-1.70m x 2 & 1.66m B Blk-1.70m x 2	MR
	<ul style="list-style-type: none"> Basements 	NA	NA	NA
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door 	NA	NA	NA
	<ul style="list-style-type: none"> Pressurization 	NA	NA	NA
	d. No of continuous staircase to terrace	Required	One	MR
	e. Width Of Corridor	1.5m	Provided	MR
	f. Door Size	1m	1m	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door 	NA	NA	NA
	<ul style="list-style-type: none"> Sealing of electrical shafts 	NA	NA	NA
	<ul style="list-style-type: none"> Fire Rating of shaft door 	NA	NA	NA
	<ul style="list-style-type: none"> Water Curtain 	NA	NA	NA
	<ul style="list-style-type: none"> Fire Dampers 	NA	NA	NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> Basements 	30 a/c per hour	NA	NA
	<ul style="list-style-type: none"> Upper floors 	12 a/c per hour	NA	NA
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers 	12 Nos	15 Nos.	MR
	<ul style="list-style-type: none"> Types 	ABC / CO ₂	Provided	MR
	<ul style="list-style-type: none"> ISI marking 	ISI Marked	Provided	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor 	NA	NA	NA
	<ul style="list-style-type: none"> Length of hose reel hose 	NA	NA	NA
	<ul style="list-style-type: none"> Nozzle diameter 	NA	NA	NA

	<ul style="list-style-type: none"> Type of detector Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	NA	NA	NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA	NA	NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual stopping Pump House Access 	NA	NA	NA
	<ul style="list-style-type: none"> Terrace level 			
	<ul style="list-style-type: none"> Discharge of pump Head of the pump Power supply Auto starting of pump 	NA	NA	NA
14.	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw of connection Fire service inlet Access to tank Overhead Tank capacity 	NA	NA	NA
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of lift lobby Communication in lift Car Fireman's Grounding Switch Lift Signage 	NA	NA	NA
17.	Standby power supply	NA	NA	NA
8.	Refuge Area			
	<ul style="list-style-type: none"> Total area Location 	NA	NA	NA
		NA	NA	NA


M-10

19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F.6/DFS/MS/School/2018/SZ/865 dated 27/04/2018, renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Note: Earlier there are 3 Block of G+1, Now it is only 2 Block of G+1 as third block has been dismantled


 24/6/2021
 Signature of the Inspecting Officer
 Name : Ashok Kumar Jaiswal
 Designation: ADO (SJ)

~~DO (SD)~~

[Handwritten signature]
24/06


~~DeFO (S2)~~

F. T. p least.

[Handwritten signature]

~~AD (SJ)~~

F. T. is added pl.


 2/7/2021

Dy. CFO (SZ)

[Handwritten signature]

M.S. 6/1