

C-53

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEADQUARTERS: DELHI FIRE SERVICE NEW DELHI-110001

No. F6/DFS/MS/School/WZ/2021/444

Dated: 7/7/21

FIRE SAFETY CERTIFICATE

Certified that Manvi Public School, Block C – 7, Sector – 7, Rohini, Delhi 110085 comprised of Basement + Ground + Two Upper Floors owned / occupied by Manvi Public School was issued fire safety certificate by this department vide letter no F6/DFS/MS/School/2016//WZ/803 Dated 19/05/2016. The premises was re-inspected by the officer concerned of this department on 10.02.2021 in the presence of Mr. K. C. Malik (Manager) and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition. The premise have therefore deemed complied with the requirements rule 33 of the Delhi Fire Service Rules, 2010, and premise is fit for class Educational Buildings with effect from 7/7/2021 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rule, 2010.

Issued on 7 / 7 /2021 at New Delhi by


(Dhrampal Bhardwaj)
Dy.Chief Fire Officer
Tel:-01123414250

Copy to:

1. The Principal, Manvi Public School, Block-C-7, Sector- 07, Rohini, Delhi-110085
2. The Director of Education, Old Secretariat, Delhi-110054

Conditions for validity of Fire Safety Certificate;

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'j' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form "K" is available on [http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Ru les/](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/) http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

INSPECTION REPORT

1. Name & address of the building : Manvi Public School, Block C-7, Sector -07, Rohini, Delhi -85
2. Type of Occupancy : Education
3. Type of Case : B + G + 02 Upper Floor
4. Details of Previous NOC : F6/DFS/MS/School/2016//WZ/803 Dated 19/05/2016
5. Fire Safety directives letter No : NBC Part IV
6. Date of inspection : 10.02.21
7. Name of Inspecting Officer : ADO (Rohini)
8. Name and designation of officers
From the building side : Mr. K. C. Malik (Manager)
9. Year of Construction : 1999-2008
10. Applicant's letter No. : Online mail dated 29.01.2021

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	4.5 m	M.R
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	d. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	02	03	MR
	e. Width of staircases			
	• Upper Floor	1.50 m	1.50 m & 1.24 m	MR (old case)
	• Basements	1.50 m	1.50 m 1.10 x 02	MR (old case)
	f. Protection of exits			
	Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace			
	e. Width of Corridor	01	01	MR
	f. Door Size	NA	NA	NA
		1 m	1 m	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA

N-30

	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	30 a/c per hour	Exhaust	MR
	• Upper floors	12 a/c per hour	Natural Ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	08 No's ABC/CO2 ISI Marked	10 No's	MR
	• Types		ABC 10	MR
	• IS marking		Yes	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30 m	30 m	MR
	• Nozzle diameter	5 mm	5 mm	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel		NA	NA
	• Location of Repeater Panel		NA	NA
	• Alternate source of power		NA	NA
	• Hooters' Location		NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basement	Required	Provided	MR
	• Ground & Upper Floors	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA

	<ul style="list-style-type: none"> ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/Manual Stopping ➤ Pump House Access 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
	<ul style="list-style-type: none"> • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	900 LPM	Provided	NMR
		40 m	40 m	MR
		Required	Provided	MR
		Required	Provided	NMR
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		10,000 ltr	Provided	MR
15.	Exit Signage.	Required	Provided	NMR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	NA	NA	NA
		NA	NA	NA
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA

20.	Special Fire Protection System for Protection of special Risks, if any:			
-----	---	--	--	--

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F6/DFS/MS/School/2016//WZ/803 Dated 19/05/2016 is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.

Note: - In reference to the one room constructed on terrace, applicant submitted it as a load being structure for 20000 liter water tank and since inception in the year 2008-2009 to be considered under rule 35 (6) as does not affect the fire safety of the school building.

Ajay
21/2/2021

Signature of the Inspecting Officer
Name: Ajay Kumar Sharma
Designation ADO/Rohini

DO (NW)

Ajay
12/02/2021

Dy CPO (WZ) what about shortcoming communicated on 18/11/2020/16.

~~*Ajay*~~
16/02/2021

Rac K R

Ajay
16/02/2021

ADO (R) Sir, additional / renovation work found removed from terrace and one room already available since inception may kindly be considered under rule 35(6) as it does not affect fire safety of school.

Ajay
10/1/2021