

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F6/DFS/MS/School/WZ/2021/ 456

Dated: 7 .07.2021

FIRE SAFETY CERTIFICATE

Certified that the MRG School (name changed from Delhi International School) at plot No. B-5, Sector-3, Rohini, Delhi comprised of Basement + Ground + Four Upper Floors, (School is running at Basement + Ground + Three upper floor) was granted NOC by this department vide letter no. F.6/DFS/MS/School/2016/WZ/1418 Dated 19.09.2016 up to 3rd floor. The premises were re-inspected by the officers concerned of this department on dated 23.06.2021 in the presence of Mr. Rohit Gupta and observed that fire safety norms as required under Rule 33 of Delhi Fire Service Rules, 2010 have deemed complied for entire building and that the building/premise is fit for occupancy Group B Educational **for basement + ground + three upper floor only** with effect from 7/7/21 for a period of **three years**, in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 7/7/21 at New Delhi by


(Dhrampal Bhardwaj)
Dy.Chief Fire Officer
Tel:-01123414250

Copy to:

1. The Principal, MRG School (earlier known for Delhi International School) at plot No. B-5, Sector-3, Rohini, Delhi
2. The Director of Education, GNCT of Delhi Old Secretariat, Delhi-110054

Conditions for validity of Fire Safety Certificate;

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director along with a copy of this Certificate, six months prior to its expiry”.
7. The owner / occupier shall submit a declaration every year in form “K” provided in the first schedule of Delhi Fire Service Rules 2010. The form ”K” is available on
8. **The Fourth floor shall not be used for any occupancy violation of which shall be as FSC null and void of FSC.**

http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/

http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Forms

INSPECTION REPORT

Building B+G+4 Upper Floors
School running at B+G+3 upper floor

1. Name & address of the building : **MRG** (name change from) Delhi International School at plot No. B-5, Sector-3, Rohini, Delhi-110085.
2. Type of Occupancy : Educational Building "B"
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2016/WZ/1418 Dated 19.09.2016
5. Fire Safety directives letter No : DFS/MS/BP/2011/2426 dated 05.10.2011
6. Date of inspection : 23.06.2021
7. Name of the Inspecting Officers : ADO (Rohini) & DO (NWD)
8. Name and designation of officers from the building side : Sh. Rohit Gupta (Administer)
9. Year of Construction : 2013
10. Applicant's letter No. : Online application email no. nil dated 06.04.2021

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Provided	MR
	• Gate width	Accessible	5.0 mtr	M/R
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	N/A	N/A	N/A
	• Upper Floors	03	03	M/R
	• Basements	03+ one ramp	03+ one ramp	MR
	b. Width of staircases	N/A	N/A	N/A
	• Upper Floors	1.50 mtr	1.50 m	MR
	• Basements	1.50 mtr	1.50 m	MR
	c. Protection of exits	N/A	N/A	N/A
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	e. No. of continuous staircases to terrace	01	01	MR
	g. Width of Corridor	1.5 mtr	Provided	MR
	h. Door Size	1.0 mtr	1.0 mtr	MR
3	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basements	Required	Natural ventilation	MR

	➤ Head of the pump	40m	40m	MR
	➤ Power Supply	Required	Provided	M/R
	➤ Auto Starting of pump	Required	Provided	M/R
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	50,000 ltr	50,000 ltr	M/R
	➤ Draw-off connection	Required	Provided	M/R
	➤ Fire service inlet	Required	Provided	M/R
	➤ Access to tank	Required	Provided	M/R
	• Overhead Tank capacity	25,000 ltr	25,000 ltr	MR
15	Exit Signage.	Required	Provided	M/R
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	Required	Provided	M/R
	• Fireman's Grounding Switch	Required	Provided	M/R
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	Required	Provided	M/R
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	Required	Provided	M/R
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F6/DFS/MS/School/2016/WZ/1418 Dated 19.09.2016 is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.

Ajaye
24/6/21
Signature of the Inspecting Officer
Name Ajay Kumar Sharma
Designation ADO (Rohini)

Ajaye
25/06/2021

5/7/21 221

DO (NW)

By CFO (WZ)

lit. is put up for kind