

C-72

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No F 6 / DFS / MS / 2021 / w2/450

Dated: 7 / 7 / 2021

FIRE SAFETY CERTIFICATE

Certified that the **R.B. Ram Roop Vidya Mandir** located at **Near Railway Under Bridge, Shakti Nagar, Delhi- 110007** comprised of **Ground and first floors only** owned/ occupied by the **R.B. Ram Roop Vidya Mandir** was granted FSC by this department vide letter No. **F6/DFS/MS /2018/1377 dated 13.06.2018**. The premises was re-inspected by the officer concerned of this department on **23.06.2021** in the presence of **Ms. Jai Shri (Principal)** and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy Group B Educational with effect from **7/7/21**..... for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on **7/7/21**..... at New Delhi


(Dharampal Bhardwaj)
Dy.Chief Fire Officer
Ph:-011-23414250

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 54.
2. The Manager, R.B. Ram Roop Vidya Mandir, Near Railway Under Bridge, Shakti Nagar, Delhi-110007.

Conditions for the validity of Fire Safety Certificate:

- 1 All the means of escape/entry/exit shall be kept free from any obstruction.
- 2 All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
- 3 All the staff members must know the correct method of operation of firefighting system.
- 4 The owner / occupier shall submit a declaration **every year in Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on http://delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms.
- 5 This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
- 6 "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

2. Type of Occupancy : Educational
 3. Type of Case : Renewal (Ground + first floor)
 4. Details of previous NOC : F6/DFS/MS/2018/1377 Dated: 13.06.2018
 5. Fire Safety directives letter No : Director of Education Circular dated 01.03.2011
 6. Date of inspection : 23.06.2021
 7. Name of the Inspecting Officers : ADO (RN)
 8. Name and designation of officers
 from the building side : Ms. Jai Shri (Principal)
 9. Year of Construction : 1948
 10. Applicant's letter No. : Online E-mail ID dated 18.06.2021

Plot Area-10000 sq.m Covered Area:1260 sq.m No. of class rooms -22nos No. of Students- 482


	Minimum Standards on fire prevention and fire safety U/R 33	Circular of Director of Education	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6m	6m	MR
	• Gate width	Directly Accessible	Directly Accessible	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50m	1.22m & 1.24m	MR(old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1m	1m	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Natural Ventilated	MR
5	Fire Extinguishers			
	• Total numbers	06nos	12nos	MR

	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A


The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in director of education Circular dated 01.03.2011, it is recommended to grant of fire safety certificate issued vide this department letter of even no. 1377 dated 13.06.2018.

DO (W2)


25/06/2021

24 cfo (W2)


A 5/7/2021





24/06/2021
Signature of the Inspecting Officer
Name :- C.L. Meena
Designation:- ADO/RN

~~ADO/RN~~

As approved, F.T. letter is put up for your signature pl.

~~Dy cfo (W2)~~


7/7/2021


05/07/2021

MS/cell