

L-48

**FORM 'H'**  
**FORM FOR ISSUING FIRE SAFETY CERTIFICATE**  
[Refer sub - rule (1) of rule 35]  
**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE**  
**NEW DELHI**

No. F6/DFS/MS/SZ/2021/ 448

Dated: 7 /07/2021

**FIRE SAFETY CERTIFICATE**

Certified that the building Sarvodaya Kanya Vidhalaya, Block 2 & 5 Located at Pocket – 7, Sector – / Dwarka, New Delhi – 110045 comprised of Ground + 01 Upper Floors owned/ occupied by Sarvodaya Kanya Vidhalaya was granted NOC by this department vide letter no. F.6/DFS/MS/School/2017/SZ/208 Dated 10/02/2017 have complied with the fire prevention and fire safety requirements in accordance with the Director of Education Circular No-F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 and verified by the officer concerned of Fire Service on 09/02/2021 in the presence of Sh. Sunil Dagar and that the building / premises is fit for the occupancy class “Educational” Group B Sub Division (Blocks 2 & 5) with effect from 7/7/21 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 7/7/21 at New Delhi by.



(Sunil Chaudhary)  
Dy. Chief Fire Officer  
Delhi Fire Service.

Block  
6/7

**Copy to:-**

1. The Principal, Sarvodaya Kanya Vidhalaya, Block 2 & 5, at Pocket – 7, Sector – 1, Dwarka, New Delhi – 110045
2. Directorate of Education Old Secretariat Delhi – 110054.

**Following fire safety directives must be adhered to:-**

1. This NOC is only for Second & Fifth Blocks.
2. Block no-1,3 &4 should not use without getting FSC from this department.
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
4. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
5. The trained staff should be available round the clock.
6. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
7. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
9. Basement shall be used as per building bye laws.
10. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

N/18

Re inspection to see the compliance of shortcomings communicated vide letter no. F6/DFS/MS/School/2020/SZ/504 dated 13/05/2020 are complied

**INSPECTION REPORT**

1. Name & address of the building: Sarvodaya Kanya Vidhalaya, Located at Pocket – 7, Sector – 1, Dwarka, New Delhi – 110045.
2. Type of Occupancy : Educational (Ground + 01 Upper Floor) Block 2 & 5
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/School/2017/SZ/208 Dated 10/02/17
5. Fire Safety directives Letter No. : DOE Circular 3298 -3398 Dated 01/03/2011
6. Date of inspection : 19/06/2021
7. Name of the Inspecting Officer : ADO (DWK)
8. Name and designation of Officer from the building side : Sh. Sunil Dagar
9. Year of Construction : 1999
10. Applicant's letter No. : Email Dated 08/06/2021

**Total covered area for Blocks = 02 & 05 is 3181sqmtr**

S No	Minimum standards on fire prevention and fire safety U/R 33	DOE Circular dated 1/03/2011 As per N/6	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtrs	Provided	MR
	• Gate width	5mtrs	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	4 No's	Blk 2 (2 Nos.), Blk 5 ( 4 Nos.)	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5 m	Blk 2 (1.42 & 1.65 m) Blk 5 (1.58,1.60m , 1.50 & 1.60 m)	MR (Old case)
	• Basements	NA	NA	NA
	c. Protection of exits	NA	NA	NA
	• Fire check door			
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	01 each blk & 2 in block no 5	Provided	MR
	f. Door Size	1.5 mt	Provided	MR
		1.5 mtr	Provided	MR (Old case)




N/20


14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.


In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F.6/DFS/MS/School/2017/SZ/208 Dated 10/02/2017 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

  
 Signature of the Inspecting Officer  
 Name Uday Vir Singh  
 Designation ADDPWKS

ADDPWKS

  
 30/06/2021

By CEO (S2)

  
 30/6  
 ADDPWKS

his FT letter is put up for signature