

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No.F6/DFS/MS/2021/SZ/ 302

Dated: 07/ 07/2021

**FIRE SAFETY CERTIFICATE**

Certified that the M/s Reliance ambit trade pvt. Ltd. Located at Commercial plot no. 1, City Centre, sector-13, Dwarka, New Delhi – 110045, comprised of 3 basement Ground + 03 Upper Floors was issued FSC vide Letter No. F6/DFS/MS/Mercantile/2018/SZ/1222 dated 24/05/2018. The premises was re inspected by the team of officers concerned of this department on 18/06/2021 in the presence of Sh. Sunil Kumar Sharma (EGM) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy "Mercantile" with effect from 07/07/2021 for a period of three years subject to compliance of the conditions printed below.

Issued on 07/07/2021 at New Delhi by.

  
(Atul Gang)  
Director  
Delhi Fire Service

Copy to:

1. Sh. Sunil Sharma, M/s Reliance ambit trade pvt. Ltd. Located at Commercial plot no. 1, City Centre, sector-13, Dwarka, New Delhi – 110045.

**Following fire safety directives must be adhered to:-**

- 1 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 2 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 3 The trained staff should be available round the clock.
- 4 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 5 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 6 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
- 7 Basement shall be used strictly as per building bye laws.
- 8 The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

## INSPECTION REPORT

1. Name & address of the building: M/s Reliance ambit trade pvt. Ltd. Located at Commercial plot no. 1, city centre, sector-13, Dwarka, new deli – 110045.
2. Type of Occupancy : Mercantile
3. Type of Case : Renewal (3 Basement + Ground + 03 Upper Floors)
4. Details of previous NOC: F6/DFS/MS/Mercantile/2018/SZ/1222 dated 24/05/2018
5. Fire Safety directives Letter No: F6/DFS/MS /BP/2008/613 Dated 29/02/2008  
& F6/DFS/MS/BP/2012/2955 Dated 13/08/2012
6. Date of inspection : 18/06/2021
7. Name of the Inspecting Officer : DO (SW) & ADO (DWK)
8. Name and designation of Officer  
from the building side : Sh. Sunil Kumar Sharma (EGM)
9. Year of Construction : 2014
10. Applicant's letter No. : Email dated 10/06/2021

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/13	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 m	20 m	MR
	• Gate width	06 m	06 m	MR
	• Width of internal road	06 m	As per controlled Drawing	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	03 Nos.	03 Nos.	MR
	• Basements	09 Nos.	9 Nos. + 01 Ramp	MR
	b. Width of staircases			
	• Upper floors	1.5 mtr	02 mtr	MR
	• Basements	1.5 mtr - 02 mtr	2.00/1.8/1.50 mtr + 1 ramp 7.5 mtr (Two way)	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	d. No of continuous staircase to terrace	03 Nos	Provided	MR
	e. Width Of Corridor	2.40 mtr	02 to 5 mtr •	MR
	f. Door Size	1.5 mtr	1.5 mtr	MR

3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	Required	Provided	MR
	• Fire Dampers	Required	Provided	MR
4.	Smoke managements System			
	• Basements	Required	Provided	MR
	• Upper floors	Required	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	120 nos ABC& CO2	121 Nos.	MR
	• Types	ISI marked	ABC, CO2 , DCP & WCO2	MR
	• IS marking		Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	Basement 2 & 1 (7 Nos.) GF 06 Nos. & 1 <sup>st</sup> to 3 <sup>rd</sup> floor 04 Nos.	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	Heat & Smoke	Provided	MR
	• Location of Main Panel	Ground floor	Ground floor	MR
	• Location of Repeater Panel	Required	Provided at ground floor	MR
	• Alternate source of power	Required	Battery backup	MR
	• Hooters' Location	Appropriate place	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	Required	Provided	MR
11.	Internal Hydrants:			
	• Size of riser/down-comer	150 mm	Provided	MR
	• Number of hydrants per floor	04no's each floor	Provided	MR
	• Hose Box	Required	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	12 Nos.	12 Nos.	MR
	• Hose Box	Required	Provided	MR

13. Pumping Arrangements:				
<ul style="list-style-type: none"> <li>• Ground Level</li> <li>• Discharge of main pump</li> <li>➤ Head of main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Staring/Manual stopping</li> <li>➤ Pump House Access</li> <li>• Terrace level</li> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power supply</li> <li>➤ Auto starting of pump</li> </ul>	2850 lpm	Provided	MR	
	70 m	Provided	MR	
	2 Nos.	Provided	MR	
	2 X 180 lpm	Provided	MR	
	70 m	Provided	MR	
	1X2850 lpm	Provided	MR	
	70 m	Provided	MR	
	Required	Provided	MR	
	Required	Provided	MR	
	NA	NA	NA	
	NA	NA	NA	
	NA	NA	NA	
	NA	NA	NA	
	NA	NA	NA	
14. Captive water Storage for fire fighting:				
<ul style="list-style-type: none"> <li>• Under ground tank capacity</li> <li>➤ Draw off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	At ground level	1,00,000 ltr	MR	
	Required	Provided	MR	
	Required	Provided	MR	
	Required	Provided	MR	
	10 KL	20 KL	MR	
15	Exit Signage	Required	Provided	MR
16. Provision of Lifts				
<ul style="list-style-type: none"> <li>➤ Pressurization of Lift Shaft</li> <li>➤ Pressurization of lift lobby</li> <li>➤ Communication in lift Car</li> <li>➤ Fireman's Grounding Switch</li> <li>➤ Lift Signage</li> </ul>	Required	Provided	MR	
	Required	Provided	MR	
	Required	Provided	MR	
	Required	Provided	MR	
	Required	Provided	MR	
17.	Standby power supply	Required	D.G Set	MR
18. Refuge Area				
<ul style="list-style-type: none"> <li>➤ Total area</li> <li>➤ Location</li> </ul>	NA	NA	NA	
	NA	NA	NA	
19. Fire control room				
<ul style="list-style-type: none"> <li>➤ Detector system panel</li> <li>➤ Flow Switch Panel</li> <li>➤ PA System Panel</li> <li>➤ Battery backup</li> <li>➤ Building Floor Plans</li> </ul>	Required	Provided	MR	
	Required	Provided	MR	
	Required	Provided	MR	
	Required	Provided	MR	
	Required	Provided	MR	

		W/20		
20.	Special Fire Protection Systems for Protection of special Risks, if any;	CO2 trolley near HT, LT panels	Provided	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/Mercantile/2018/SZ/1222 dated 24/05/2018 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer  
 Name:-  
 Designation DO/SW

Signature of the Inspecting Officer  
 Name :-  
 Designation ADO/DWK

By CRO/SW Please speak

ADO (VDP) Vdaveer

spoken requirements are as mentioned at 14/13.

Signature

Signature

C.F.O.

Signature

Signature

