

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001


No. F6/DFS/MS/WZ/2021/ 295

Dated 07/07/2021

FIRE SAFETY CERTIFICATE

Certified that the **Netaji Subhash Place Metro Station (Line-1)** Located at **Wazirpur, New Delhi-110034**, comprised of Ground + Concourse+ Platform (**Including PD Area**) was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/Metro/2018/WZ/1621 dated 12.07.2018. The said building was re-inspected by the officer concerned of this department on 25.06.2021 in the presence of Sh. Dinkar Meena, Fire Inspector (DMRC) & Sh. Puneet, Manager facilities (P.P. Buildwell Pvt. Ltd.) and found that the premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010, and that the building is fit for occupancy Group – D ‘Assembly’ Sub Division D-7 with effect from .. 07/07/2021.....for a period of three years, in accordance with rule 36 unless renewed 37 or sooner cancelled under rule 40 subject to compliance of the conditions under rule 38 of the Delhi Fire Service, Rules 2010, printed overleaf.

Issued on .. 07/07/2021..... at New Delhi by


07/07/2021
(Dharampal Bhardwaj)
Dy. Chief Fire Officer
(West Zone)

Copy to:

1. Sh. Vivek Srivastava (JGM/E&M), Metro Bhawan, Fire Brigade Lane, Barakhamba Road, New Delhi-110001.
2. The Authorized Signatory, P.P. Buildwell Pvt. Ltd., Plot No. 1, P.P. Trade Centre, Netaji Subhash Place, Pitam Pura, Delhi-110034.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

1. Name & address of the building: Netaji Subhash Place Metro Station (Line-1)
Located at Wazirpur, Delhi-110034.
2. Type of Occupancy : Assembly
3. Type of Case : Renewal (Ground + Mezzanine (PD Area) + Metro Station at Upper Floors)
4. Details of previous NOC : F6/DFS/MS/Metro/2018/WZ/1621 dated 12.07.2018
5. Fire Safety directives Letter No. : F6/DFS/MS/BP/2004/2134 dated 16.09.2004 & F6/DFS/MS/BP/2005/1258 dated 13.06.2005
6. Date of inspection : 21.06.2021 & 25.06.2021
7. Name of the Inspecting Officer : S.P. Bhardwaj, ADO (WP)
8. Name and designation of Officer
from the building side : Sh. Dinkar Meena Fire Inspector (DMRC) & Sh. Puneet
Manager Facilities (P.P. Buildwell Pvt. Ltd.)
9. Year of Construction : 2005
10. Applicant's letter No. : email dated 22.06.2021 & 18.05.2021

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC/NFPA Requirements/letter dated 12.07.2018	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	24 m & 13.5m side road	Provided	MR
	• Gate width	5 m	Provided	MR
	• Width of internal road	6 m	5 m to 6 m	MR (Old Case)
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	Old Case	4 Nos. PF to Conc. & 2 Nos. Conc. to Ground (2 Nos. PD Area)	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	Old case	2.61m each & 2m & 1.5m (PD Area)	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	1	Service Staircase	MR (Old Case)
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	2m & 1.5m	Provided	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	NR	NR	NR
	• Fire Dampers	Required	Provided	MR
4.	Smoke managements System			

	<ul style="list-style-type: none"> Total numbers Types IS marking 	20 + 20 PD Area ABC, CO2 & WCO2 ISI marked	Provided Provided Provided	MR MR MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	4 Nos. Conc., 4 Nos. PF & 9 Nos. + 2 Nos. PD Area 30 m 45 Mtrs & 30 Mtrs PD Area 5 mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Smoke & Heat SCR & at GF (PD Area) Required Required Required	Provided Provided Provided Provided Provided	MR MR MR MR MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	NA Required Required	NA Provided in PD Area Provided	NA MR MR
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	150 mm 4 Nos. Conc., 4 Nos. PF & 9 Nos. + 2 Nos. PD Area Required	Provided Provided Provided	MR MR MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	7 Nos. Required	Provided Provided	MR MR
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> Ground Level ➤ Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access ➤ Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	1800 lpm 40 M 2 180 lpm 40 M 1800 lpm 40 M Required Required NR NR NR NR	2850 lpm 70 M Provided (2 Nos.) Provided 70 M Provided 70 M Provided Provided NR NR NR NR	MR MR MR MR MR MR MR MR MR MR NR NR NR NR
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> ➤ Under ground tank capacity ➤ Draw off connection ➤ Fire service inlet 	100,000 litres Required Required	200,000 litres Provided Provided	MR MR MR

15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	Required	Provided	MR
	➤ Flow Switch Panel	Required	Provided	MR
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	Required	Provided	MR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	CO2 flooding for ASS,HT<	Provided	MR

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view deemed compliance of the minimum standards of fire prevention and fire safety requirements under the rules, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/Metro/2018/WZ/1621 dated 12.07.2018 is recommended under rules 37 of the Delhi Fire Service rules 2010 under the DFS Act 2007.

S.P. Bhardwaj
ADO (WP)

~~DO/West~~

~~DO/West~~
25/6

~~DFS (W2)~~

~~DFS (W2)~~
25/7/2021

~~ADO/West~~

~~ADO/West~~

It is put up for signature
21/7/2021

21/7/21

D.O. (WEST)/130
DATED..25/06/21