

C-51

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE**

**NEW DELHI**


No: F.6/DFS/MS/SCHOOL/2021/ 469

Dated: /12/7 /2021

**FIRE SAFETY CERTIFICATE**

Certified that the building of **Blooming Buds Public School**, located at 1<sup>st</sup> & 2<sup>nd</sup> Floor, B-Block New Moti Nagar New Delhi – 110027 comprised of {One Block=Ground (Religious Function), + 03 Upper floors, owned/occupied by **Blooming Buds Public School**, was issued FSC vide Letter No:- F6/DFS/MS/School/2018/WZ/1161 Dated 22/05/2018. The premises was re-inspected by the officer concerned of this department on 29/06/2021 in the presence of Sh. Lav Shukla and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No.F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 and that the premises is fit for occupancy class "Educational" Group B with effect from 12/7/21 for a period of three years subject to compliance of the conditions mentioned below.

Issued on 12/7/21 at New Delhi by.

  
(Dharampal Bhardwaj)  
Dy. Chief Fire Officer  
Delhi Fire Service

09/07/2021  
09/07/2021

Copy to:-

1. To, Lav Shukla Blooming Buds Public School, , B-Block, Moti Nagar, New Delhi-110027
2. Director of Education, Old Secretariat, New Delhi-110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good
2. Working condition at all times.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The basement shall be used strictly as per building bye laws.
7. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

1. Name & address of the building: Blooming Buds Public School, Located at 1st & 2<sup>nd</sup> Floor, B-Block, New Delhi-110027
2. Type of Occupancy : Educational (One Block=Ground Floor Religious Function), 1<sup>st</sup> & 2<sup>nd</sup> Floors(For School)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2018/ WZ /1161 dated 22/05/2018
5. Fire Safety directives Letter No. : DOE 3298 -3398 dated 01/03/2011
6. Date of inspection : 29/06/2021
7. Name of the Inspecting Officer : Sarabjeet Singh, ADO (MN)
8. Name and designation of Officer from the building side : Sh. Lav Shukla
9. Year of Construction : 1967
10. Applicant's letter No. : Email dated 05/06/2021

S No	Minimum standards on fire prevention and fire safety U/R 33	DOE 3298 - 3398 dated 01/03/2011	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	07 m Provided	MR
	• Gate width	Accessible	On Road	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	1	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5 m	1X 92 cm(up to 3 <sup>rd</sup> F) 1X154 cm(up to 1 <sup>st</sup> F) 1X108 cm(up to 2 <sup>nd</sup> F)	MR(Being old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	Required	Provided	MR
	e. Width Of Corridor	1.5 m	160 cm	MR
	f. Door Size	1 m	101 cm Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	07 nos.	Provided	MR
	• Types	ABC	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	Total numbers on each floor	1	Provided	MR


7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	NA	Provided	NA
	• Number of hydrants per floor	NA	Provided	NA
	• Hose Box	NA	Provided	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 lpm	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for firefighting:			
	• Underground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	5000 Liters	Provided	MR
15.	Exit Signage	Required	Provided	NMR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no.F6/DFS/MS/School/2018/WZ/1161, Dated-22/05/2018, renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.


145/AD0/MN

~~Do (west)~~


  
-06/07/2024

Signature of the Inspecting Officer  
Name: Sarabjeet Singh  
Designation: ADOMN)

06/07/2024

  
06/07/2024

Defto (WZ)


  
7/7/2024

~~AD0/MIN~~

Sir, F.T is put up for your perusal & signature  
No. 1

Defto (WZ)

  
9/7/2024

  
09/07/2024

M/S call