

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No. F6/DFS/SZ/MS/2021/ 307

Dated: 08/07/2021

**FIRE SAFETY CERTIFICATE**

Certified that the Delhi Metro Rail Corporation Ltd. Underground Metro Station Located at Dwarka Sector 21 New Delhi. Comprised of basement + Ground floor except PD area (Upper floor) was issued FSC vide letter no. F6/DFS/MS/2018/SZ/160 dated 24-01-2018. The premises was re inspected by the officer concerned of this department on 07/01/2021 in the presence of Mr. Kumar Vaibhav (DMRC) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the building / premises is fit for the occupancy class "Assembly" Group D Sub Division D - 7 with effect from 08/07/2021 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.


Issued on 08/07/2021 at New Delhi by.



(Sunil Chaudhary)  
Dy. Chief Fire Officer,  
Delhi Fire Service.

Copy to:

1. Sh. Vivek Shrivastava, JGM/ E&M,  
DMRC, Metro Bhawan,  
Fire Brigade Lane, Barakhamba Road, New Delhi - 110001.



Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The basement shall be used as per building bye laws 1983.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expired. [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

N/99  
**INSPECTION REPORT**

1. Name & address of the building : Delhi Metro Rail Corporation Ltd.  
Underground metro station Located at Dwarka Sector 21 New Delhi.
2. Type of Occupancy : Assembly (D-7)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2018/SZ/160 dated 24-01-2018
5. Fire Safety directives Letter No. : NBC
6. Date of inspection : 07-01-2021
7. Name of the Inspecting Officer : Udai vir singh, ADO (DWK)
8. Name and designation of Officer  
from the building side : Mr. Kumar Vaibhav (DMRC)
9. Year of Construction : 2010
10. Applicant's letter No. : Email dated 16/12/2020

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC Requirements		Provided at site	Remarks MR/NMR
1.	Access of building				
	• Road width	9 mtr	12 mtr	MR(Old Case)	
	• Gate width	5 mtr	6 mtr	MR(Old Case)	
	• Width of internal road	5 mtr	6 mtr	MR(Old Case)	
2.	Number, width, Type & Arrangements of exits				
	a. Number of staircases				
	• Upper floors	NA	NA	NA	
	• Basements	Old Case	8 Nos. (from platform to concourse ar ground)	MR	
	b. Width of staircases				
	• Upper floors	NA	NA	NA	
	• Basements	2 mtr	3.6 m (on platform no 1) rest 2.2 mtr each	MR	
	c. Protection of exits				
	• Fire check door	Required	Provided	MR	
	• Pressurization	Required	Provided	MR	
	d. No of continuous staircase to terrace	NA	NA	NA	
	e. Width Of Corridor	NA	NA	NA	
	f. Door Size	1mtr	Provided	MR	
3.	Compartmentation				
	• Fire check door	Required	Provided	MR	
	• Sealing of electrical shafts	Required	Provided	MR	
	• Fire Rating of shaft door	2 Hrs	2 Hrs	MR	
	• Water Curtain	NA	NA	NA	
	• Fire Dampers	Required	Provided	MR	



14.	Captive water Storage for fire fighting	N/24		
	• Under ground tank capacity	At ground level	2,00,000 ltrs	MR
	➤ Draw of connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity			
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	DG Set	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	Required	Provided in SCR	MR
	➤ Flow Switch Panel	Required	Provided	MR
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	Required	Provided	MR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	Argonite gas flooding system protection provided for ASS; Telecom Equipment room CTER, SER & S & T UPS rooms	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter F6/DFS/MS/2018/SZ/160 dated 24-01-2018 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

**Note:- The sprinkler system as mentioned in the noting at N/13 & N/17 is not provided in entire area at platform area. It has been provided on the rail track only.**

Signature of the Inspecting Officer  
Name- Udai vir Singh  
Designation-ADO/DWK

*Udai Vir Singh*  
15/06/21

*F. I. please*

*15/06/21*