

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

C-26


No. F6/DFS/MS/GH/SZ/2021/ 196

Dated: 2/7/21

FIRE SAFETY CERTIFICATE

Certified that M/s. Hotel Star Palace located at 15A/17, WEA, Karol Bagh, New Delhi-110005 comprised of basement, ground plus three upper floors, using basement as storage, ground floor as reception & shops, first & second each having 10 guest rooms respectively, third floor having 09 guest rooms (total 29 guest rooms) and two staff rooms with pantry on terrace was granted FSC by this department vide letter No. F6/DFS/MS/GH/SZ/2018/1438 dated 20.06.2018. The premises was re-inspected by the officer concerned of this department on 22.06.2021 in presence of Smt, Harishma, manager, and found that the owner have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class residential (guest house) for basement (storage), ground floor (reception & shops), first & second floor each having 10 guest rooms respectively, third floor having 09 guest rooms (total 29 guest rooms only) with effect from 2/7/21 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed back side.

Issued on 2/7/21 at New Delhi by.

  
(Sunil Chaudhary)  
Dy. Chief Fire Officer (SZ)  
Delhi Fire Service  
0/6/21

Copy to:-

1. Director, M/s. Hotel Star Palace, 15A/17, WEA, Karol Bagh, New Delhi- 110005.
2. The Joint C.P. (Lic.), Police Station, Defence Colony, 1<sup>st</sup> floor, New Delhi

**Following Fire Safety Directives must be adhered to: -**

1. No occupancy above third floor & basement as storage purpose, shall be adhered by Owner/Occupier
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
6. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
7. All comments / directions of licensing department shall always be permitted and followed.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
9. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.
10. Basement shall be used as per BBL.
11. No temporary shed is allowed on terrace.
12. The Fire Safety Certificate is only for Guest Rooms.

## INSPECTION REPORT

1. Name & address of the building : M/s. Hotel Star Palace, 15A/17, WEA, Karol Bagh, New Delhi- 110005
2. Type of Occupancy : Lodging House
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/GH/SZ/2018/1438 dated 20.06.2018
5. Fire Safety directives letter No : Nil
6. Date of inspection : 22.06.2021
7. Name of the Inspecting Officers : P.V. Rathee, Asstt. Div. Officer (SRD)
8. Name and designation of officers from the building side : Smt. Harishma, manager
9. Year of Construction : 1990-91
10. Applicant's letter No. : Online email id [hotelstarpalace786@gmail.com](mailto:hotelstarpalace786@gmail.com) dated 17.06.2021

The said guest house is comprised of basement, ground plus three upper floors.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Fire safety arrangements as per FSC dt. 20.06.2018	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	06 mts	Provided	MR
	• Gate width	4.5 mts	Provided	MR
	• Width of internal road	N/A	N/A	N/A
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	-	-	-
	• Upper Floors	01	01	MR
	• Basements	01	01	MR being old case
	b. Width of staircases	-	-	-
	• Upper Floors	Old Case	1.05 mts	MR being old case
	• Basements	Old Case	1.37 mts	MR being old case
	c. Protection of exits	-	-	-
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	01	01	MR
	g. Width of Corridor	1.5 mts	1.5 mts.	MR
	h. Door Size	Old case	0.79 mts	MR being old case
3	<b>Compartmentation.</b>			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	<b>Smoke Management System.</b>			
	• Basements	30 a/c per hour	Exhaust fan provided	MR
	• Upper floors	12 a/c per hour	Exhaust fan provided	MR
5	<b>Fire Extinguishers</b>			
	• Total numbers	15	Provided	MR
	• Types	CO <sub>2</sub> , ABC, WCO <sub>2</sub>	Provided	MR
	• IS marking	ISI marked	Provided	MR

	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	Carbon Monoxide	Provided	MR
	• Location of Main Panel	Required	Provided near reception	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	Required	D.G. set 62.5 KVA	MR
	• Hooters' Location	N/A	N/A	N/A
8	<b>MOEFA</b>	Required	Provided	MR
9	<b>Public Address System.</b>	Required	Provided	MR
10	<b>Automatic Sprinkler System.</b>			
	• Basement	Required	Provided	MR
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	<b>Pumping Arrangements.</b>			
	• Ground Level	---	---	---
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level	-----	-----	-----
	➤ Discharge of pump	450 LPM	450 LPM	MR
	➤ Head of the pump	30 mts	30 mts each	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	<b>Captive Water Storage for fire fighting.</b>			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	Old Case	5,000 lts	MR, old case
15	<b>Exit Signage.</b>	Required	Provided	MR

16	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	Required	Provided	MR
	• Fireman's Grounding Switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
17	<b>Standby power supply</b>	Required	Provided	MR
18	<b>Refuge Area.</b>			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	<b>Fire Control Room</b>			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F6/DFS/MS/GH/SZ/2018/1438 dated 20.06.2018, renewal under rule 37 of the Delhi Fire Service rules 2010 is recommended.

DFA is put up for approval & signature please.

*25/6/21*

Name P.V Rathee  
Asstt. Div. Officer (SRD)

*D.O. (SW)*

*25/06/2021*

*Dy CFO (SR)*

*P. T. please*

*ADD (SRD)*

*P.T. Letter is put up for sign please*

*Dy. CFO (SR)*

*25/6*