

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110 001.**

No. F.6/DFS/MS/EH/2021/SZ/ 128

Dated: 12/7/21

**FIRE SAFETY CERTIFICATE**

Certified that the **M/s IKK Punjab (A unit of Superlicious Foodworks LLP)**, J-2/17, B.K. Dutt Market, Rajouri Garden, New Delhi-110027, comprised of basement, ground floor plus three upper floors but the restaurant is running at ground floor plus one upper floor. The FSC was issued vide letter no.F6/DFS/MS/EH/2018/SZ/1238 dated 25/05/2018, owned/occupied by M/s IKK Punjab (A unit of Superlicious Foodworks LLP). The restaurant was re-inspected by the officers concerned of this department on 21/06/2021 in the presence of Sh. Pawan (Manager) and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises (**Ground floor plus one upper floor**) is fit for occupancy class Group D "Assembly Building" w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on.....12/7/21.....at New Delhi.



(SUNIL CHAWDHARY)  
DY.CHIEF FIRE OFFICER

07c

Copy to:-

1. The Deputy Health Officer,  
West Zone (SDMC), Public Health Department,  
Vishal Enclave, New Delhi.
  
2. The Owner,  
M/s IKK Punjab (a unit of Superlicious Foodworks LLP),  
J-2/17, B.K. Dutt Market, Rajouri Garden, New Delhi-110027.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used as per the building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

*Ado Jaf*

1. Name & address of the building: M/s IKK Pubjab (a unit of Superlicious Foodworks LLP), J-2/17, B.K. Dutt Market, Rajouri Garden, New Delhi-110027.
2. Type of Occupancy : Group D (Assembly Building)
3. Type of Case : Renewal
4. Details of Previous NOC : F6/DFS/MS/EH/2018/SZ/1238 Dated 25/05/2018
5. Fire Safety directives letter No : N/A
6. Date of inspection : 21/06/2021
7. Name of Inspecting Officers : A.D.O. R.K.Yadav
8. Name and designation of officers  
From the building side : Sh. Pawan (Manager)
9. Year of Construction : Before 2007
10. Applicant's letter No. : ID2021040812572 dated 19/04/2021

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	UBBL-16/NBC Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>Road width</li> <li>Gate width</li> <li>Width of internal road</li> </ul>	Accessible (09 mtrs) 4.5 mtrs N/A	Provided Directly accessible from road N/A	MR MR N/A
2.	<b>Number, Width, Type &amp; Arrangement of Exits (restaurant is running at GF &amp; FF)</b>			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>Upper Floors</li> <li>Basements</li> </ul>	02 No.'s N/A	02 No.'s N/A	MR N/A
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>Upper Floor</li> <li>Basements</li> </ul>	1.5 m & 01 m N/A	Provided N/A	MR N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Pressurization</li> </ul>	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace	Required	One	MR
	e. Width of Corridor	1.5 m	Opening in hall	MR
	f. Door Size	02 m & 01 m	2.08 & 1.0M	MR
3.	<b>Compartmentation</b>			
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Sealing of electrical shafts</li> <li>Fire Rating of shaft door</li> <li>Water Curtain</li> <li>Fire Dampers</li> </ul>	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	<b>Smoke Management System</b>			
	<ul style="list-style-type: none"> <li>Basements</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Upper floors</li> </ul>	Required	Natural Ventilation	MR
5.	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	05 No.'s ABC/ CO <sub>2</sub> ISI marked	Provided Provided ISI marked	MR MR MR
6.	<b>First-Aid Hose Reels</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	One 30 mtrs 5 mm	Provided Provided Provided	MR MR MR

Delivered please return to :

7.	<b>Automatic fire detection and alarming system</b>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	N/A	N/A	N/A
8.	<b>MOEFA</b>	Required	Provided	MR
9.	<b>Public Address System</b>	N/A	N/A	N/A
10.	<b>Automatic Sprinkler System</b>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Basement</li> <li>Ground Floor &amp; Upper floor</li> <li>Sprinkler above false ceiling</li> </ul>	N/A	N/A	N/A
11.	<b>Internal Hydrants</b>	100 mm	Provided	MR
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants</li> <li>Hose Box</li> </ul>	01 No.	Provided	MR
		01 No.	Provided	MR
12.	<b>Yard Hydrants</b>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	N/A	N/A	N/A
13.	<b>Pumping Arrangements</b>			
	<ul style="list-style-type: none"> <li>Ground Level <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> </ul> </li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/Manual Stopping</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Pump House Access</li> <li>Terrace level <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>	450 LPM	Provided	MR
		40 mtrs	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	<b>Captive Water Storage for fire fighting</b>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Underground tank capacity <ul style="list-style-type: none"> <li>Draw-off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> </ul> </li> <li>Overhead Tank capacity</li> </ul>	N/A	N/A	N/A
		Required	Provided	MR
		N/A	N/A	N/A
		20000 ltrs	Provided	MR
		Required	Provided	MR
15.	<b>Exit Signage.</b>			
16.	<b>Provision of Lifts.</b>			(No Lift)
	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> <li>Pressurization of Lift lobby</li> <li>Communication In lift Car</li> <li>Fireman's Grounding Switch</li> <li>Lift Signage</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17.	<b>Standby power supply</b>	Required	Provided	MR
18.	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>Total Area</li> </ul>	N/A	N/A	N/A

Delivered please return to :

19.	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Battery backup</li> <li>• Building Floor Plans</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20.	<b>Special Fire Protection System for Protection of special Risks, if any:</b>	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the above deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC was issued vide letter no. F6/DFS/MS/EH/2018/SZ/1238 Dated 25/05/2018 renewal under the rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Note:- As per the undertaking given by the partner (placed at C-31) running restaurant only Ground & First Floor and basement is sealed by Gypsum board and never use a part of restaurant.

*R. K. Yadav*  
25/6/2021

Signature of Inspecting Officer  
Name:- R.K. Yadav  
Designation:-Asstt. Divisional Officer

DO(South West)

*K. Yadav*  
05/07/2021  
DY CFO (S2)

F.T. phase.

*sh.*

A DO (S2)

F-T letter is put up for signature please

DY CFO (S2)

*sh.*

*R. K. Yadav*  
6/7/2021

एस सी सी (इंडिया)