

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

No. F.6/DFS/MS/CNG/2021/SZ/ 310

Dated: 08/07/2021

FIRE SAFETY CERTIFICATE

Certified that **M/s Indraprastha Gas Limited Retail Outlet (CNG Pump) at Sector-3, R.K Puram, New Delhi** Comprised of Ground Floor only (01Nos, Storage Cascade at Ground floor, 01 Nos, Compressor & 02 Nos Dispenser units owned/occupied by M/s Indraprastha Gas Limited, was issued FSC by this department vide letter no. F6/MS/DFS/CNG/2018/SZ/1989 Dated 29/08/2018 for 03 cascades at ground, 03 compressor unit & 07 Dispensing units. The premise was revisited by officer concerned on 28/06/2021 in the presence of Mr. Virender Singh (Manager) and that there is a addition / alternation in the existing ground floor building and that the building have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010. The premise is fit for occupancy class Storage (CNG Pump) as above with effect from 08/07/2021 2021 for a period of **three years** in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010.

Issued on 08/07/2021 at New Delhi by

(Atul Garg)
Director

Copy to: -

1. The Joint C.P (Lic.) First Floor, PS Defence Colony, New Delhi 110049.
2. Sh. Ajay Khatri, DGM-(Fire & Safety) (IGL) LGL Bhawan, Plot No 4, Community Centre, R. K Puram, Sector- 09, New Delhi 110049

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL- 2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

INSPECTION REPORT

1	Name & Address of the Building	Indraprastha Gas Ltd, Retail Outlet (CNG Pump) at Sector-3, R. K Puram, New Delhi- 110022		
2	Type of Occupancy	Storage (CNG Pump) CNG Compressor (01 Nos), Storage Cascade (01 Nos), Dispenser (02 Nos),		
3	Building Comprised of	Ground floor only		
4	Type of Case	Renewal / <u>Additional alternation</u>		
5	Details of Previous NOC	F6/MS/DFS/CNG/2018/SZ/1989 Dated 29/08/2018		
6	Fire Safety Directives Letter No	F.5(3A)/DFS/CNG/2000/295 dated 10/07/2000		
7	Date of Inspection	28-06-2021		
8	Name of the Inspecting Officers	Mr. Rajesh Kumar (ADO BCP)		
9	Name & Designation of Officers from the building side	Mr. Virender Singh (Manger)		
10	Year of construction	2000		
11	Applicant letter No.	IGL/F&S/2021/15/64/02 Dated 18-06-2021		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	09 mtr -NA- -NA-	12 Nos Provided -NA- -NA-	MR -NA- -NA-
2	Number, width, type and arrangements of exits.			
	a. Number of Staircase			
	<ul style="list-style-type: none"> Upper floors Basement floor 	01 -NA-	01 -NA-	MR -NA-
	b. Width of Staircase			
	<ul style="list-style-type: none"> Upper floors Basement floor 	0.90 m -NA-	1.1 mtr -NA-	MR -NA-
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	-NA- -NA-	-NA- -NA-	-NA- -NA-
	d. No. of continuous staircase to terrace	-NA-	-NA-	-NA-
	e. Width of corridor	-NA-	-NA-	-NA-
	f. Door size	01 m	Provided	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door. Sealing of electrical shafts. Fire rating of shaft door. Water curtain Fire dampers. 	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-
4.	Smoke Management system.			
	<ul style="list-style-type: none"> Basement Upper floors 	-NA- -NA-	-NA- -NA-	-NA- -NA-
5.	Fire Extinguishers.			
	<ul style="list-style-type: none"> Total numbers Types ISI Marking 	22 nos Required ISI Marked	Co2 Flooding – 45 Kg- 02 Nos, DCP 75 Kg- 02 Nos, DCP – 10 Kg- 10 Nos, & CO2 – 4.5 kg 04 Nos DCP/75 kg- 03, DCP/10kg – 14 & CO ₂ - 04 Provided	MR MR MR
6.	First Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor. Length of hose-reel hose. 	-NA- -NA-	-NA- -NA-	-NA- -NA-

7	Automatic Fire Detection and Alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	Gas & Flame	Provided in compressors	MR
		Required	Ground floor	MR
		-NA-	-NA-	-NA-
		Required	Provided	MR
		Required	Technician room	MR
8.	MOEFA	-NA-	-NA-	-NA-
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper floors Sprinkler above false ceiling 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
11.	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser / Down-comer Number of Hydrant per floor Hose box. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
13.	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump. Head of main pump. Number of main pumps. Jockey Pump output. Jockey Pump head. Standby Pump output. Standby Pump head. Auto Starting/Manual Stopping. Terrace Level Discharge of pump. Head of pump. Power supply. Auto starting of pump. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
14.	Captive water storage for fire-fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. Draw-off connection. Fire Service Inlet. Access to tank. Overhead tank capacity. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
15.	No Smoking signage	Required	Provided in Hindi & English	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
17	Standby Power Supply	NA	Provided (DG Set)	NA
18.	Refuge Area			
	<ul style="list-style-type: none"> Total area Location 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-

19.	Fire Control Room.			
	<ul style="list-style-type: none"> • Detector System Panel. • Flow Switch Panel. • PA system Panel. • Battery backup • Building floor plan 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.	Co2 flooding system connected through detectors provided in each compressor unit		MR

“No Smoking” Sign boards were found displayed both in Hindi & English at conspicuous places. No loose electric wiring was seen in the premises.

Keeping in view of the substantially satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, it is recommended to issue Fire Safety Certificate under rule 35 (3) of the Delhi Fire Service Rules, 2010

Accordingly, DFA is put up for perusal and signature please.



Signature of the Inspecting Officer
 Name: Mr. Rajesh Kumar
 Designation: ADO (BCP)

DO (SD)

King
29/06

DeFO

[Signature]
30/6

CFD

King
1/7

[Signature]
07/07/2007

[Signature]

As approved, f.t. letter is
 being for your signature pl

[Signature]
1/7



return to:
 एस सी सी (इंडिया)