

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001**

No. F.6/DFS/MS/Bldg/2018/SZ/ 306

Dated: 08/07/2021

**FIRE SAFETY CERTIFICATE**

Certified that M/s Kiwanis Bhawan (Kiwanis Club of New Delhi) located at B-35, Qutab Institutional Area, New Delhi-110016 comprised of basement, ground + 05 upper floors was issued FSC by this department vide letter No F6/DFS/MS/Bldg/2018/SZ/2334 Dated 16-10-2018. The premise was re-inspected by officer concerned of this department on 29/06/2021 in the presence of Ms. Sweta (Admin officer) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that building is fit for occupancy class "Mix Occupancy" (Institutional & Business) as above with effect from the date of issue of this certificate for period of Three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued 08/07/2021 at New Delhi by

(ATUL GARG)  
DIRECTOR

Copy to: -

1. Secretary General, M/s Kiwanis Bhawan (Kiwanis Club of New Delhi), B-35, Qutab Institutional Area, New Delhi-110016.
2. Executive Engineer (Bldg), South MCD, Dr. SPM Civic Centre, Minto Road, New Delhi-2

**Conditions for the validity of Fire Safety Certificate:**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

