

C-82

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2021 / School / WZ / 464


Dated: 8/7/21

FIRE SAFETY CERTIFICATE

Certified that **National Public School** located at **Safiabad Road, Narela, Delhi-110040** comprised of Ground and two upper floors owned/occupied by **National Public School** was issued FSC by this department vide letter No **F-6/DFS/MS/2017/School/WZ/1596** dated 08.11.2017. The building was inspected by the officer concerned of this department on 22.06.2021 in the presence of Sh. Sant Lal (Manager), and observed that all the fire prevention and fire safety arrangements as provided in the building found in good working condition. The premises have deemed complied with the requirements under rule 33 of the Delhi Fire Service Rules, 2010 and the building/ premise is fit for occupancy **Group B Educational** with effect from8/7/21..... for a period of three years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...8/7/21..... at New Delhi

Yours faithfully


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
WEST ZONE

Copy to :-

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi-54.
2. Principal, National Public School, Safiabad Road, Narela, Delhi-40.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : National Public School, Safiabab Road, Narela, Delhi-110040.
 2. Type of Occupancy : Educational
 3. Building Comprised : Ground+Two upper floors
 4. Type of Case : Renewal
 5. Details of Previous NOC : Letter No. F.6/DFS/MS/2017/SCHOOL/WZ/1596 Dated-08/11/2017
 6. Fire Safety directives letter No : DFS Act 2007 & NBC Part-IV
 7. Date of inspection : 22 /06/2021
 8. Name of Inspecting Officer : ADO (BW)
 9. Name and designation of officers
 From the building side : Sh. Sant Lal (Manager)
 10. Year of Construction : 1992 & 2013
 11. Applicant's letter No. : Letter No. NPS/2021-22/016 , Dated-26/05/2021

| S. No. | Minimum Standards on fire prevention and fire safety U/R 33 | NBC Requirement | Provided at site | Remarks MR/NMR |
|--------|---|-----------------|-------------------------------|----------------|
| 1. | Access to building | | | |
| | • Road width | 6.0 m | 9.0 m | MR |
| | • Gate width | 4.5 m | 4.5 m | MR |
| | • Width of internal road | NA | NA | NA |
| 2. | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | NA | NA | NA |
| | • Upper Floors | 02 | 03 | MR |
| | • Basements | NA | NA | NA |
| | b. Width of staircases | NA | NA | NA |
| | • Upper Floor | 1.50 m each | 1.04 m, 1.60 m & 2.30 m(Ramp) | MR(old case) |
| | • Basements | NA | NA | NA |
| | c. Protection of exits | NA | NA | NA |
| | • Fire check door | NA | NA | NA |
| | • Pressurization | NA | NA | NA |
| | d. No. of continuous staircases to terrace | NA | NA | NA |
| | e. Width of Corridor | 01 | Provided | MR |
| | f. Door Size | 1.00 m | 1.00 m with door fitting | MR |
| 3. | Compartmentation | | | |
| | • Fire check door | NA | NA | NA |
| | • Sealing of electrical shafts | NA | NA | NA |
| | • Fire Rating of shaft door | NA | NA | NA |
| | • Water Curtain | NA | NA | NA |
| | • Fire Dampers | NA | NA | NA |
| 4. | Smoke Management System | | | |
| | • Basements | 30 a/c per hour | NA | NA |

a

| | | | | |
|-----|---|-----------------|---------------------|----|
| | <ul style="list-style-type: none"> Upper floors | 12 a/c per hour | Natural Ventilation | MR |
| 5. | Fire Extinguishers | | | |
| | <ul style="list-style-type: none"> Total numbers | 16 | 16 | MR |
| | <ul style="list-style-type: none"> Types | ABC | ABC | MR |
| | <ul style="list-style-type: none"> IS marking | Yes | Yes | MR |
| 6. | First-Aid Hose Reels | | | |
| | <ul style="list-style-type: none"> Total numbers on each floor | 02 | Provided | MR |
| | <ul style="list-style-type: none"> Length of hose reel hose | 30 m | Provided | MR |
| | <ul style="list-style-type: none"> Nozzle diameter | 5 mm | Provided | MR |
| 7. | Automatic fire detection and alarming system | | | |
| | <ul style="list-style-type: none"> Type of detectors | NA | NA | NA |
| | <ul style="list-style-type: none"> Location of Main Panel | NA | NA | NA |
| | <ul style="list-style-type: none"> Location of Repeater Panel | NA | NA | NA |
| | <ul style="list-style-type: none"> Alternate source of power | NA | NA | NA |
| | <ul style="list-style-type: none"> Hooters' Location | NA | NA | NA |
| 8. | MOEFA | | | |
| 9. | Public Address System | | | |
| 10. | Automatic Sprinkler System | | | |
| | <ul style="list-style-type: none"> Basement | NA | NA | NA |
| | <ul style="list-style-type: none"> Ground Floor | NA | NA | NA |
| | <ul style="list-style-type: none"> Sprinkler above false ceiling | NA | NA | NA |
| 11. | Internal Hydrants | | | |
| | <ul style="list-style-type: none"> Size of riser/down-comer | NA | NA | NA |
| | <ul style="list-style-type: none"> Number of hydrants per floor | NA | NA | NA |
| | <ul style="list-style-type: none"> Hose Box | NA | NA | NA |
| 12. | Yard Hydrants | | | |
| | <ul style="list-style-type: none"> Total number of hydrants | NA | NA | NA |
| | <ul style="list-style-type: none"> Hose Box | NA | NA | NA |
| 13. | Pumping Arrangements | | | |
| | <ul style="list-style-type: none"> Ground Level | | | |
| | <ul style="list-style-type: none"> ➤ Discharge of main Pump | NA | NA | NA |
| | <ul style="list-style-type: none"> ➤ Head of Main pump | NA | NA | NA |
| | <ul style="list-style-type: none"> ➤ Number of main pumps | NA | NA | NA |
| | <ul style="list-style-type: none"> ➤ Jockey Pump out put | NA | NA | NA |
| | <ul style="list-style-type: none"> ➤ Jockey pump head | NA | NA | NA |
| | <ul style="list-style-type: none"> ➤ Standby Pump out put | NA | NA | NA |
| | <ul style="list-style-type: none"> ➤ Standby Pump Head | NA | NA | NA |
| | <ul style="list-style-type: none"> ➤ Auto Starting/Manual Stopping | NA | NA | NA |
| | | NA | NA | NA |

R

| | | | | |
|------------|--|-------------|-------------|----|
| | ➤ Pump House Access | NA | NA | NA |
| | • Terrace level | 450 lpm | 450 lpm | MR |
| | ➤ Discharge of pump | 40 m | 40 m | MR |
| | ➤ Head of the pump | NA | NA | NA |
| | ➤ Power Supply | - | - | - |
| | ➤ Auto Starting of pump | NA | NA | NA |
| 14. | Captive Water Storage for fire fighting | | | |
| | • Underground tank capacity | NA | NA | NA |
| | ➤ Draw-off connection | NA | NA | NA |
| | ➤ Fire service inlet | NA | NA | NA |
| | ➤ Access to tank | NA | NA | NA |
| | • Overhead Tank capacity | 10,000 ltrs | 10,000 ltrs | MR |
| 15. | Exit Signage. | Required | Provided | MR |
| 16. | Provision of Lifts. | | | |
| | • Pressurization of Lift Shaft | NA | NA | NA |
| | • Pressurization of Lift lobby | NA | NA | NA |
| | • Communication In lift Car | NA | NA | NA |
| | • Fireman's Grounding Switch | NA | NA | NA |
| | • Lift Signage | NA | NA | NA |
| 17. | Standby power supply | NA | NA | NA |
| 18. | Refuge Area. | | | |
| | ➤ Total Area | NA | NA | NA |
| | ➤ Location | NA | NA | NA |
| 19. | Fire Control Room | | | |
| | • Detector System Panel | NA | NA | NA |
| | • Flow Switch Panel | NA | NA | NA |
| | • PA System Panel | NA | NA | NA |
| | • Battery backup | NA | NA | NA |
| | • Building Floor Plans | NA | NA | NA |
| 20. | Special Fire Protection System for Protection of special Risks, if any: | NA | NA | NA |

Handwritten signature

| | | | | |
|--|--|--|--|--|
| | | | | |
|--|--|--|--|--|

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules it is recommended for renewal of Fire Safety Certificate issued vide letter no.F-6/DFS/MS/2017/School/WZ/1596 under rule 35 of the Delhi Fire Service Rules 2010.

DO (WZ)

ADDO (WZ)
 24/06/2021
 5/7/2021

ADDO (WZ)
 23/6/21

Signature of Inspecting Officer

Name : Rajeev Kumar Sinha

Designation : ADO/B.W.

~~ADDO (WZ)~~ F.T letter is put up for sign please
 6/7/21

Defo (WZ)
 7/7/2021

msg call