

C-11

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE**  
**NEW DELHI**


No: F.6/DFS/MS/School/MN/ 2021/468

Dated: 12/7/2021

**FIRE SAFETY CERTIFICATE**

Certified that the Sanatan Dharam Public School (ID 1516105) located at Moti Nagar New Delhi-110015.comprised of & Ground + 1 Upper Floor owned and occupied by Sanatan Dharam Public School was issued FSC by this department vide letter No-F6/DFS/MS/School/WZ/1040 dated 14.05.2018. The premises was re-inspected by the officer concerned of this department on dated 29/06/2021 In the presence of Sh. Shashanshu Jha (Principal) and observed that Fire Prevention and Fire Safety arrangements provided in the premises, found in good working condition. The premises have therefore, deemed complied with the Fire Prevention and Fire Safety requirement in accordance with the circular issued by circular No. F6/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 and that the school building/ premises is fit for occupancy class "Education" (Group B) with effect from...12/7/21.....for a period of Three years subject to compliance of the conditions mentioned below..

Issued on ...12/7/21..... at New Delhi.

  
(Dharampal Bhardwaj)  
Dy.Chief Fire Officer,  
Delhi Fire Service.

- Copy to: 1. The principal-Sanatan Dharam Public School, Moti Nagar New Delhi-110015.  
2. The Directorate of Education Old Secretariat Delhi – 110054

Following fire safety directives must be adhered to:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.

n-4

## INSPECTION REPORT

1. Name & address of the building : Sanatan Dharam Public School Moti Nagar New Delhi-110015.
2. Type of Occupancy : Educational ( Ground + 1 Upper Floor)
- 3.
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/School/WZ/1040 dated 14/05/2018
6. Fire Safety directives Letter No. : DOE 3298-3398 dated 1-3-11
7. Date of inspection : 29/06/2021
8. Name of the Inspecting Officer : Sarabjeet Singh, ADO (MN)
9. Name and designation of Officer from the building side : Sh. Shashanshu Jha (Principal)
10. Year of Construction : 1985
11. Applicant's letter No. : Nil Dated -19/04/2021 & Email Dated 16/06/2021

The Said School is running at Ground plus one upper floor in a building comprised of Ground plus one upper floor.

S No	Minimum standards on fire prevention and fire safety U/R 33	Circular No. 3298-3398 dated 01/03/2011	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	6 m	09 m Provided	MR
		4.5 m	Provided(on Main road)	MR
		NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	1	02 Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5 m	2X120cm	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	1	Provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1m	1 mtr Provided with door frame	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA

	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA			
9.	Public Address System			
		NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto starting of pump	NA	NA	NA
14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage			
		NA	NA	NA
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply			
		NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
		NA	NA	NA

	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter no. F6/DFS/MS/School/2018/WZ/1040 dated -14/05/2018 renewal under the directorate of education circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 is recommended.

161/ADD/MNO  
09/07/2021  
01/07/2021

~~DO (W2)~~

~~Sarabjeet Singh~~  
01/07/2021

Sarabjeet Singh  
ADO (MN)

~~[Signature]~~  
06/07/2021

~~DeFO (W2)~~

~~[Signature]~~  
27/7/2021

~~AAO/M-N~~ Sir, F.T is put up for your personal & signature No.

~~DeFO (W2)~~

~~[Signature]~~  
09/07/2021

~~[Signature]~~  
29/7/2021

ms/ul