

C-12

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No F 6 / DFS / MS / 2021 / 457

Dated: 8 / 7 / 2021

**FIRE SAFETY CERTIFICATE**

Certified that **Sri Hanuman Mandir Secondary School** located at **Block-37, Shakti Nagar, Delhi-110007** comprised of **Ground +03 upper floor** owned/ occupied by **Sri Hanuman Mandir Secondary School** was issued Fire Safety Certificated by this department vide letter no. **No.F6/DFS/MS/2007/3457** dated **13.11.2007 (Ground +03)**. The premises was re-inspected by the officer concerned of this department on **28.06.2021** in presence of **Smt. Uma Sharma (Incharge)** and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by **Director of Education vide letter no 262-362 dated 17.01.2005** and the building premise is fit for occupancy class Group B Educational with effect from ... **8/7/21**..... for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on ..... **8/7/21**..... at New Delhi by.

  
(Dharampal Bhardwaj)  
Dy. Chief Fire Officer  
Ph:-011-25156707  
**o/c**

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Manager, Sri Hanuman Mandir Sec. School, Block-37, Shakti Nagar, Delhi-110007.

**Conditions for the validity of Fire Safety Certificate:**

1. **This Fire Safety Certificate is valid only first & second floor for educational occupancy only. In case of any violation, this FSC will be treated as null & void.**
2. All the means of escape/entry/exit shall be kept free from any obstruction.
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in./wps/wcm/connect/doi fire/FIRE/Home/Forms>.
6. This fire safety certificate may not in any way be treated as regularization ( Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration ( Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

1. Name & address of the building : Sri Hanuman Mandir Sec. School, Block-37, Shakti Nagar, Delhi-110007.
2. Type of Occupancy : Educational G+03 upper floors (School is running on 1<sup>st</sup> & 2<sup>nd</sup> floor only)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2007/3457 Dated: 13.11.2007 (Ground + 03)
5. Fire Safety directives letter No : Director of Education Circular dated 17.01.2005
6. Date of inspection : 28.06.2021
7. Name of the Inspecting Officers : ADO (RN)
8. Name and designation of officers from the building side : Smt. Uma Sharma (Incharge)
9. Year of Construction : 1983
10. Applicant's letter No. : online E-mail ID Dated- 28.06.2021

Ground floor- Mandir  
 First floor-School  
 Second floor- School  
 Third floor- Guard Room

Plot Area- 500 sqyard

	Minimum Standards on fire prevention and fire safety U/R 33	Circular of Director of Education	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	6m	6m	MR
	• Gate width	4.5	4.5	MR
	• Width of internal road	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50m	1.35m x2	MR(old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
e. Width of Corridor	NA	NA	NA	
f. Door Size	1 m	1m	MR	
3	<b>Compartmentation.</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	<b>Smoke Management System.</b>			
	• Basements	12 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Natural Ventilated	MR
5	<b>Fire Extinguishers</b>			
	• Total numbers	05nos	06nos	MR



	<ul style="list-style-type: none"> <li>Types</li> <li>ISI marking</li> </ul>	ABC/CO2	ABC-06	MR
		ISI Marked	Yes	MR
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> </ul>	01	Provided	MR
	<ul style="list-style-type: none"> <li>Length of hose reel hose</li> </ul>	30m	Provided	MR
	<ul style="list-style-type: none"> <li>Nozzle diameter</li> </ul>	5mm	Provided	MR
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Location of Main Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Location of Repeater Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Alternate source of power</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Hooters' Location</li> </ul>	NA	NA	NA
8	<b>MOEFA</b>	NA	NA	NA
9	<b>Public Address System.</b>	NA	NA	NA
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Upper Floor</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	NA	NA	NA
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Number of hydrants per floor</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	NA	NA	NA
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	NA	NA	NA
13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>Ground Level</li> </ul>			
	<ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Head of Main pump</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Number of main pumps</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Jockey Pump out put</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Jockey pump head</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Standby Pump out put</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Standby Pump Head</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Auto Starting/ Manual stopping</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Pump House Access</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Terrace level</li> </ul>			
	<ul style="list-style-type: none"> <li>➤ Discharge of pump</li> </ul>	220 lpm	450 lpm	MR
	<ul style="list-style-type: none"> <li>➤ Head of the pump</li> </ul>	40 m	40m	MR
	<ul style="list-style-type: none"> <li>➤ Power Supply</li> </ul>	N/A	N/A	N/A



14	<b>Captive Water Storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Draw-off connection</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Fire service inlet</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Access to tank</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Overhead Tank capacity</li> </ul>	2500 ltr	5000 ltr	MR
15	<b>Exit Signage.</b>	N/A	N/A	N/A
16	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Pressurization of Lift lobby</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Communication In lift Car</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Fireman's Grounding Switch</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Lift Signage</li> </ul>	N/A	N/A	N/A
17	<b>Standby power supply</b>	N/A	N/A	N/A
18	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>➤ Total Area</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Location</li> </ul>	N/A	N/A	N/A
19	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>Detector System Panel</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Flow Switch Panel</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>PA System Panel</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Batter backup</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Building Floor Plans</li> </ul>	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in director of education Circular no. 262-362 dated 17.01.2005, it is recommended to renewal of fire safety certificate issued vide this department letter of even no.3457 dated 13.11.2007.

*DO (W2)*

*Meena*  
29/06/2021

*DO (W2)*

*[Signature]*  
6/7/2021

*[Signature]*  
29/06/2021

Signature of the Inspecting Officer

Name :- C.L. Meena

Designation:- ADO/RN

*ADO/R-N*

As approved, F.T. letter is put up for your signature pl.

*[Signature]*  
29/06/2021

श्री लाल सा (इडिया)