

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/BNQT/2021/NDZ/ 304

Dated: 08/07/2021

FIRE SAFETY CERTIFICATE

Certified that the Shubh Milan Banquet Hall at 534, 534/4, 534/5 Jheel Khuranja, Delhi-110051 comprised of ground plus two upper floors (running at first & second floor of building) was issued FSC vide letter No. F6/DFS/MS/BNQT/2016/NDZ/1206 dated 25/11/2016. The building have complied with the fire prevention and fire safety requirements in accordance with the rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on 28/06/2021 in the presence of Sh. Anurag Kathuria, owner and found that the building is fit for occupancy class "D" 'Assembly Building' for first & second floor of the building with effect from 08/07/2021 for a period of **three** years, in accordance and further subject with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 & also conditions printed overleaf.

Issued on.....08/07/2021.....at New Delhi by


5772

(Dr. S. K. Tomar)
Dy. Chief Fire Officer

g/c 

To,

Sh. Anurag Kathuria, Owner
Shubh Milan Banquet hall,
534, 534/4, 534/5 Jheel Khuranja,
Delhi-110051

Copy to:-

The Deputy Health Officer, EDMC,
SHD (N)- Zone, Health Department,
Delhi-110032

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry

INSPECTION REPORT

1. Name & address of the building : Subh Milan Banquet Hall, 534, 534/4, 534/5
Jheel, Khuranja, Delhi-110051
2. Building is comprised of : G+2
Ground floor- office/shop, (Banquet hall
running at 1st & 2nd floor only)
3. Type of Occupancy : Assembly Building (Banquet Hall)
4. Type of Case : Renewal
5. Details of Previous NOC letter : F.6/DFS/MS/BNQT/2016/NDZ/1206
dated- 25/11/2016
6. Fire Safety direction letter No. : BBL
7. Date of Inspection : 28/06/2021
8. Name of the Inspecting officers : ADO Nagender Singh
9. Name and designation of Officer
from the building side : Sh. Anurag Kathuria, Owner
10. Year of Construction : 1985
11. Applicant's email ID : anuragmba8@gmail.com dated-03/04/2021

Sr. No	Minimum Standards on Fire Prevention and Fire Safety U/R33	BBL Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building			
	• Road width	6 m	6 m	MR
	• Gate width	4.5 m	4.5 m	MR
	12. Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	13. Upper floor	02 nos.	02 nos.	MR
	14. Basement	N/A	N/A	N/A
	B. Width of Staircases			
	15. Upper floor	1.5 m	1.8 m & 1.5 m	MR
	• Basement	N/A	N/A	N/A
	c. Protection of Exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	d. No. of Continuous Staircases to Terrace	01 no.	02 nos.	MR
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	2 m'	2 m	MR
03	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	Ventilated	Provided	MR
05.	Fire Extinguishers			
	• Total numbers	10 nos.	10 nos.	MR
	• Types	ABC /CO ₂	ABC/Co2	MR
	• IS marking	ISI marked	ISI marked	MR

06	First-Aid-Hose Reels.			
	Total numbers on each floor	01 no.	01 no.	MR
	• Length of hose reel hose	30 m	30 m	MR
	• Nozzle diameter	5 mm	5 mm	MR
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter	Required	Provided	MR
08	MOEFA	Required	Provided	MR
09	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100mm	Provided	MR
	• Number of hydrants per floor	01 no.	Provided	MR
	• Hose box	01 no.	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	• Head of main pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump head	N/A	N/A	N/A
	• Auto starting /manual stopping	N/A	N/A	N/A
	• Pump house access	N/A	N/A	N/A
	➤ Terrace Level			
	• Discharge of pump	450 LPM	450 LPM	MR
	• Head of the pump	40 m	40 m	MR
	• Power supply	Required	Provided	MR
	• Auto starting of pump	Required	Provided	MR
	•			
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	N/A	N/A	N/A
	• Overhead tank capacity	10,000 Ltrs.	10,000 Ltrs.	MR
15	Exit Signage.	Required	Provided	MR

N/12

16	Provision of Lifts.			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift signage	N/A	N/A	N/A
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if Any:	N/A	N/A	N/A

The fire protection systems provided in the building were Tested/Checked and found functional, at the time of inspection.

Keeping in view of the compliance of the minimum standards of fire prevention and fire safety measures required under the BBL requirement, it is recommended to renew Fire Safety Certificate under rule 37 of the Delhi Fire Service Rules, 2010.

N. Singh
30/6
(Nagender Singh)
ADO (Shahdara)

Dy. CFO (NDZ)

F.T. pl.

K. Kumar
30/6/21

ADOC (Shah)

FT letter is placed for signatures please

Dy. CFO (NDZ)

AS
11/7/21

K. Kumar
5/7/21

M.S. CeV

