

C-53

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE NEW DELHI-110001

No. F6/DFS/MS/School/WZ/2021/ 458

Dated: 8/7/21

FIRE SAFETY CERTIFICATE

Certified that Certified **Sun Smile Public School, (ID-1412137)**, located at **A-1/155, Aman Vihar, Delhi-110086** comprised of **Two Blocks, Ground + One Upper floor** owned/occupied by **Sun Smile Public School** was issued fire safety certificate by this department vide letter no. **F.6/DFS/MS/2009/3660 dated 02.12.2009**. The premises was re-inspected by the officer concerned of this department on **28.06.2021** in the presence of **Smt. Murti Devi** and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition and there is no additional. The premise have deemed complied with the requirements of circular issued by Director of Education, GNCT of Delhi vide letter No. 262-362 dated 17.01.2005 and the building/ premise is fit for occupancy **class "B" Educational Buildings** with effect from **8/7/2021** for a period of **three years** subject to conditions printed below.

Issued on **8/7/21** at New Delhi by

21/7/2021
(Dhrampal Bhardwaj)
Dy. Chief Fire Officer
Tel:-01123414250

Copy to:

1. The Principal, Sun Smile Public School, (ID-1412137), located at A-1/155, Aman Vihar, Delhi-110086.
2. The Director of Education, GNCT of Delhi Old Secretariat, Delhi-110054.

Conditions for validity of Fire Safety Certificate;

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'j' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form "K" is available on http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/ http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

1. Name & address of the building : Sun Smile Public School, (ID-1412137), located at A-1/155, Aman Vihar, Delhi-110086.
2. Type of Occupancy : Educational
3. Type of Case : Renewal (**Two blocks ---Ground + first floor**)
4. Details of previous NOC : F.6/DFS/MS/2009/3660 dated 02.12.2009
5. Fire Safety directives letter No : Director of Education Circular dated 17.01.2005
6. Date of inspection : 28.06.2021
7. Name of the Inspecting Officers : A. K. Sharma ADO (Rohini)
8. Name and designation of officers from the building side : Smt. Murti Devi.
9. Year of Construction : 2006
10. Applicant's letter No. : Online e-mail dated 08.04.2021

	Minimum Standards on fire prevention and fire safety U/R 33	Circular of dated 17.01.2005 Director of Education	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	6m	MR
	• Gate width	Accessible	Provided	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	01	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.0m & 0.75m	1.0 & 1.15 mtr	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	1.5m	Provided	MR
	f. Door Size	1 m	1 m	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	NA	NA
5	Fire Extinguishers			

	<ul style="list-style-type: none"> Total numbers Types ISI marking 	10nos	12nos	MR
		ABC/CO2	ABC-12nos	MR
		ISI Marked	Yes	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01	Provided	MR
		30 m	30m	MR
		5 mm	5mm	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply 			
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		450lpm	450lpm	MR
		40m	40m	MR

	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	2,500 ltr	2,500 ltr	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.6/DFS/MS/2009/3660 dated 02.12.2009 is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.

Signature of the Inspecting Officer
 Name Ajay Kumar Sharma
 Designation ADO (Rohini)

DO (NW)

[Handwritten signature]
 29/06/2021
 Dy CTO (NW)

[Handwritten signature]
 01/7/2021

Fi letter is put up for kind renewal