

6-7

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI-110 001.**

No.F.6/DFS/MS/School/2021/SZ/478

Dated: 14/7/21

**FIRE SAFETY CERTIFICATE**

Certified that the building of **Adarsh Public School**, WZ-2, Dayal Sar Road, New Delhi-110059, is comprised of Stilt, ground plus three upper floors, owned/occupied by the Adarsh Public School was inspected by the officer concerned of this department on 16/06/2021 in the presence of Ms Gagan Preet (In-charge) and found that the school management have complied with the fire prevention and fire safety requirements in accordance with the rule 35 of the Delhi Fire Service Rules 2010 and that the school building/ premises is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of three years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on.....14.7.21.....at New Delhi.

  
(Atul Garg)  
Director  
Delhi Fire Service  


Copy to:-

1. The Chairman,  
Adarsh Public School, WZ-2, Dayal Sar Road, New Delhi-110059.
2. Director of Education,  
Govt. of NCT of Delhi, Old Secretariat, New Delhi – 110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

## INSPECTION REPORT

1. Name & address of the building : Adarsh Public School, WZ-2, Dayal Sar Road, New Delhi-110059.
2. Building is comprised of : stilt, ground plus three upper floors
3. Type of Occupancy : Educational
4. Type of Case : Addition/alteration
5. Details of Previous NOC : F.6/DFS/MS/School/2016/SZ/701 dated 05/05/2016(G+1)
6. Fire Safety directives letter No : N/A
7. Date of inspection : 16/06/2021
8. Name of Inspecting Officer : A.D.O. R.K.Yadav
9. Name and designation of officers  
From the building side : Ms Gagan Preet (In-charge)
10. Year of Construction : 2014
11. Applicant's letter No. : Nil dated 12/06/21

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
<b>1.</b>	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	Accessible — —	09 m 2.95 m (02 no.'s)	M/R — —
<b>2.</b>	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	02 No. N/A	02 No. N/A	M/R No basement
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basements</li> </ul>	1.50 m N/A	1.50 m each N/A	M/R No basement
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace	02 No.	02 No.	M/R
	e. Width of Corridor	1.50 m	2.30 m	M/R
	f. Door Size	1.0 m	1.03 m (Double Door)	M/R
<b>3.</b>	<b>Compartmentation</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
<b>4.</b>	<b>Smoke Management System</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	N/A N/A	N/A Natural Ventilation	No basement M/R
<b>5.</b>	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	10 no's ABC/CO <sub>2</sub> type ISI marked	Provided Provided ISI marked	M/R M/R M/R




6.	<b>First-Aid Hose Reels</b>	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	Required 30 m 5 mm	Provided 30 m 5 mm	MR MR MR
7.	<b>Automatic fire detection and alarming system</b>				
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	
8.	<b>MOEFA</b>				
		N/A	N/A	N/A	
9.	<b>Public Address System</b>				
		N/A	N/A	N/A	
10.	<b>Automatic Sprinkler System</b>				
	<ul style="list-style-type: none"> <li>Basement</li> <li>Ground Floor</li> <li>Sprinkler above false ceiling</li> </ul>	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A	
11.	<b>Internal Hydrants</b>				
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	100 MM 1 No. 1 No.	100 MM 1 No. 1 No.	MR MR MR	
12.	<b>Yard Hydrants</b>				
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	N/A N/A	N/A N/A	N/A N/A	
13.	<b>Pumping Arrangements</b>				
	<ul style="list-style-type: none"> <li>Ground Level <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/Manual Stopping</li> </ul> </li> </ul>	N/A N/A N/A N/A N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A N/A N/A N/A N/A	
	<ul style="list-style-type: none"> <li>Pump House Access</li> <li>Terrace level <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>	N/A N/A 450 LPM 40 mtrs Required Required	N/A N/A 450 LPM 40 mtrs Provided Provided	N/A N/A M/R M/R M/R M/R	
14.	<b>Captive Water Storage for fire fighting</b>				
	<ul style="list-style-type: none"> <li>Underground tank capacity <ul style="list-style-type: none"> <li>Draw-off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> </ul> </li> <li>Overhead Tank capacity</li> </ul>	N/A N/A N/A N/A 10,000 liters Required	N/A N/A N/A N/A 10,000 ltrs Provided	N/A N/A N/A N/A M/R M/R	
15.	<b>Exit Signage.</b>				
		Required	Provided	M/R	

रकार का उद्यम

16.	<b>Provision of Lifts.</b>	<b>(No Lift)</b>		
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17.	<b>Standby power supply</b>	N/A	N/A	N/A
18.	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
19.	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Battery backup</li> <li>• Building Floor Plans</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20.	<b>Special Fire Protection System for Protection of special Risks, if any:</b>	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the above substantial compliance of the minimum standards of fire prevention and fire safety measures under the rule 35 of the Delhi Fire Service Rules 2010 it is recommended to grant Fire Safety Certificate.

  
 Signature of Inspecting Officer 22/6/2021  
 Name:- R.K. Yadav  
 Designation:- Asstt. Divisional Officer

Divisional Officer (South West)



Dy CBO (S2)  
 3/1  
 24/06/2021  
  
  
