

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/Audi/2021/SZ/1344/315

Dated: 12/07/2021

**FIRE SAFETY CERTIFICATE**

Certified that the Auditorium at India International Centre located at 40, Max Muller Marg, New Delhi-110003, comprised of Ground Floor only owned / occupied by India International Centre, was granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS/Auditorium/2018/SZ/1344 dated 08/06/18. The premises was re-inspected by the officer concerned of Fire Service on 30/06/2021 in the presence of Sh. Naresh Aggarwal (Junior Eng.) and observed that all the Fire prevention and Fire Safety arrangements provided in the premises found in good working condition. The premises have therefore, deemed complied with rule 33 of the Delhi Fire Service rules, 2010 and that the building / premises is fit for occupancy Class "Assembly" (Auditorium) with effect from 12/07/2021 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of conditions under 38 of the Delhi Fire Service rules, 2010.

Issued on 12/07/2021 at New Delhi by.



(SUNIL CHAUDHARY)  
DY. CHIEF FIREOFFICER (S.Z.).

Copy to:-

1. The Addl. Commissioner of Police (Lic.), 1<sup>st</sup> Floor, PS Defence Colony, New Dlehi-110049.
2. Authorized Signatory, Auditorium at India International Centre, 40, Max Muller Marg, New Delhi-110003.

**Conditions for the validity of Fire Safety Certificate:**

1. All the means of escape / entry / exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
3. Any loss of life or property due to non- functional fire safety measure shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of fire fighting system.
5. This Fire Safety Certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3. of UBBL-2016), if any.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in).

## INSPECTION REPORT

N/40

1. Name & address of the building: **Auditorium at India international Centre, 40, Max Muller Marg, New Delhi-110003.**
2. Type of Occupancy : **Assembly (Auditorium with 231 seats)**
3. Building Comprised of : **Ground Floor only**
4. Type of Case : **Renewal**
5. Details of previous NOC: **F6/DFS/MS/Auditorium/2018/SZ/1344 dated 08/06/18**
6. Fire Safety directives Letter No. : **N/A**
7. Date of inspection : **30/06/2021**
8. Name of the Inspecting Officer : **A.D.O. (S.J.)**
9. Name and designation of Officer  
from the building side : **Sh. Naresh Aggarwal (Junior Eng.)**
10. Year of Construction : **1961**

**11. Applicant's letter received through email ID-iicadmin2iicdelhi.in dated 15/06/2021**

S No	Minimum standards on fire prevention and fire safety U/R 33	Old NOC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6m	8 m	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	b. Width of staircases	N/A		
	• Upper floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	1	1	MR
	e. Width Of Corridor	N/A	N/A	N/A
	f. Door Size	1.50m x 2	1.7mx 2 & 0.80m	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke managements System			
	• Basements	30 ACPH	N/A	N/A
	• Upper floors	12 ACPH	Exhaust fan provided	MR
5.	Fire Extinguishers			
	• Total numbers	6 Nos	10 Nos	M/R
	• Types	ABC/w.co2	Provided	M/R
	• ISI marking	Required	Provided	M/R



6.	First – Aid Hose Reels			
	• Total numbers on each floor	2 Nos	Provided in Audi	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level	Fire Fighting system is common for entire complex		
	➤ Discharge of main pump	2280 LPM	2280 LPM	MR
	➤ Head of main pump	75 m	75 m	MR
	➤ Number of main pumps	2	2	MR
	➤ Jockey pump out put	180LPM	180LPM	MR
	➤ Jockey pump head	75 m	75 m	MR
	➤ Standby Pump out put	2280 LPM	2280 LPM	MR
	➤ Standby Pump Head	75m	75m	MR
	➤ Auto Staring/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	900 LPM	900 LPM	MR
	➤ Head of the pump	35m	35m	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	50,000 ltr	50,000 Ltr	MR

		N/92		
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	Required	Provided ( DG Set)	MR
18.	Refuge Area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	2 CO2 type Fire Extinguishers provided in projection room	MR

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. **F6/DFS/MS/Auditorium/2018/SZ/1344** dated **08/06/18** renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

~~DO (S.D.)~~

Div  
06/07

~~DUFO (S2)~~

~~ch~~  
7/7

~~APO (S.J.)~~

F.T. is added lower sign. pl.

*Ashok Jaiswal*  
5/7/2021

Signature of the Inspecting Officer  
Name : Ashok Kumar Jaiswal  
Designation : A.D.O. (S.J.)