

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No.F6/DFS/MS/School/2021/NDZ/ 482

Dated: 14/7/21

FIRE SAFETY CERTIFICATE

Certified that the E.D.M.C. Primary School (Gen.) located at Garhi Mendu, Bhajanpura, Delhi 1100053, comprised of ground plus one upper floor only (two Separate Blocks) owned/occupied by E.D.M.C. Primary School (Gen.) was issued FSC vide letter No.F6/DFS/MS/School/2018/608 dated 06/04/2021(old Block). The school building was inspected by the officer concerned of this department in the presence of Mr. Lalit Kumar, Principal of the school and observed that the school building have complied with the fire prevention and fire safety requirements in accordance with circular letter no. F16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/11 issued by Director of Education and found that the school building is fit for ground plus one upper floor occupancy class "B" 'Educational Building' with effect from 14/7/21 for a period of **three** years, subject to conditions, printed overleaf.

Issued on.....14/7/21.....at New Delhi by


(Atul Garg)
Director
Delhi Fire Service


To,
The Principal,
E.D.M.C. Primary School (Gen.),
Garhi Mendu, Bhajanpura,
Delhi 1100053

Copy:-
1) The Director of Education, EDMC,
Udyog Sadan, Plot No.419, FIE,
Patparganj Industrial Area, Delhi-110092

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

1. Name & address of the building : EDMC Primary School (Gen.)
Garhi Mendu, Bhajanpura, Delhi-110053
2. Building is comprised of : Ground plus one upper floor (Two Blocks)
(One old block and one new block)
3. Type of Occupancy : Educational
4. Type of Case : New (Addition/Alteration)
5. Details of Previous FSC letter : F6/DFS/MS/School/2018/608 dt.06/04/18(G+1)
6. Fire Safety direction letter No : Circular dated 01/03/11 issued by DOE
7. Date of Inspection : 18/04/2021
8. Name of the Inspecting officers : ADO Mehmood
9. Name and designation of officer
from the building side : Mr.Lalit Kumar, Principal
10. Year of Construction : 2002 & 2020
11. Applicant's letter No : E-mail, Dated- 09/04/21

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	Circular Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building			
	• Road width	06 mtr.	12 mtr.	MR
	• Gate width	4.50 mtr	4.50 mtr	MR
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper floor (old block)	01 nos	01 nos	MR
	• Upper floor (New block)	01 nos	01 nos	MR
	• Basement	N/A	N/A	N/A
	b. Width of Staircases			
	• Upper floor (old block)	1.50 mtr	1.60 mtr.	MR
	• Upper floor (New block)	1.50 mtr	2.0 mtr.	MR
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	N/A	N/A	N/A
	e. Width of corridor	1.50 mtr	1.5 mtr (old block) & 2.30 mtr.(New block)	MR
	f. Door Size	01 mtr.	1.0 mtr.& 1.20 mtr.	MR
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
05.	Fire Extinguishers			
	• Total numbers	08 nos.	08 nos.	MR
	• types	ABC /CO ₂	ABC /CO ₂	MR
	• IS marking	ISI marked	ISI marked	MR

06	First-Aid-Hose Reels.			
	Total numbers on each floor	N/A	N/A	N/A
	• Length of hose reel hose	N/A	N/A	N/A
	• Nozzle diameter	N/A	N/A	N/A
07	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
08	MOEFA			
09	Public Address System.			
		N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	• Head of Main pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump head	N/A	N/A	N/A
	• Auto starting /manual stopping	N/A	N/A	N/A
	• Pump house access	N/A	N/A	N/A
	➤ Terrace Level			
	• Discharge of pump	N/A	N/A	N/A
	• Head of the pump	N/A	N/A	N/A
	• Power supply	N/A	N/A	N/A
	• Auto Starting of pump	N/A	N/A	N/A
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	N/A	N/A	N/A
	• Overhead tank capacity	N/A	N/A	N/A
15	Exit Signage.			
		N/A	N/A	N/A

16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft Pressurization of lift lobby Communication in lift car Firemen's grounding switch Lift signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	Standby Power Supply	N/A	N/A	N/A
18	Refuge Area.			
	<ul style="list-style-type: none"> Total area Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> Detector system panel Flow switch panel PA system panel Battery backup Building floor plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the Circular No. F16/Estate/CC/Fire Safety/2011/3298 to 3398 dated-01/03/11 issued by Director of Education. It is recommended to issue Fire Safety Certificate.

Mehmood
19/3/2021

Signature of the Inspecting Officer
Name :- Mehmood
Designation :- A.D.O (T.P.)

Dy.CFO(NDZ)

Pl. speak. Point No. 2, Alternate Staircase Block-2.

Mehmood
28/4/21

A.D.O(T.P)

As per the Circular of Education the one hour case required 150m of 0.75m spec can provided

Mehmood
27/06/2021

Dy.CFO(NDZ)

Mehmood
30/6/21

A.D.O(T.P) CFO(NDZ)

Mehmood

